



FIRE & RESCUE NSW



COMMUNITY SAFETY DIRECTORATE
STRUCTURAL FIRE SAFETY UNIT
Amarina Avenue Greenacre NSW 2190
Locked Bag 12 Greenacre NSW 2190

www.fire.nsw.gov.au

info@fire.nsw.gov.au

ABN 12 593 473 110

Your Reference: DA 219-07-2002 MOD 3
File No: NFB/07545
Contact Officer: Stephan Netting

Telephone: (02) 9742 7400
Facsimile: (02) 9742 7483
Email: Firesafety.NSWFB@fire.nsw.gov.au

25th July 2011

Department of Planning & Infrastructure
GPO Box 39
SYDNEY NSW 2001

plan_comment@planning.nsw.gov.au

Attention: Megan Fu

Dear Ms Fu,

**Re: Development Modification - Western Sydney International Dragway
Ferrers Road Eastern Creek
DA 219-07-2002 MOD 3**

I refer to your correspondence dated the 30th May 2011 inviting Fire & Rescue NSW (FRNSW) to comment on the abovementioned modification of development consent.

FRNSW notes that the following information has been submitted for comment:

1. Section 96 Modification prepared by GAT & Associates dated October 2009.

FRNSW has no objection to the proposal, although requests:

1. That a condition be applied to the consent requiring the temporary grandstands, proposed as part of the modification, to be compliant with NSW Part H102 - Temporary Structures of the Building Code of Australia 2011.
2. That the Event Management Plan and the Emergency Response Plan, currently in place for the Western Sydney International Dragway, be reviewed and amended, where required, to include/cover the proposed events.

Please reference the abovementioned File No. in any further correspondence in relation to this matter.

Should you have any further enquiries regarding any of the above matters, please do not hesitate to contact the Structural Fire Safety Unit.

Yours faithfully

Electronically approved for release.

For Commissioner