

8<sup>th</sup> September 2015.

**BORG PANELS DA 27/95 MOD 8 RESPONSE TO RTS.**

Pamela,

In response to the EPA submission from Darryl Clift at the Bathurst regional office we have prepared the following:

1. Attached is a process diagram that illustrates the Gas Fired Co-Generation exhaust gas connection to process. As per request by Darryl Clift at the regional Bathurst Environment Protection Authority office.
2. The exhaust gas from the Co-generation plant is going to be connected directly into process as we have indicated. There will be an emergency vent which is required for safe operation of the engines. Otherwise under normal operation all exhaust gases will be redirected into the fibre drying process of MDF press 1 and exit to atmosphere at EPA point 9 & 10.
3. Attached is the revised noise report which helps clarify some of the noise impact assessment criteria that have been questioned, particularly under which terms the conclusions of the report were reached.  
Borg request that the conditions of this consent allow to including the noise compliance testing for Cogeneration plant with the annual compliance survey.
4. Borg confirm the old steam boilers were removed from the discussed location approximately 4 years ago. The boilers had not been used by CHH since approximately 2003 and had been formally decommissioned in 2007 by CHH. Many functioning parts had been removed from them over the years. It was decided as the units were in such a poor state of disrepair it was better site management to remove these items and dispose of them.

We trust this information assists in clarification of the outstanding items.

Regards  
Victor Bendevski