

Our Reference: SYD12/00625
Your Reference: DA 75/256 Mod 3
Contact: Stella Qu (gtk)
Telephone: 8849-2520



Transport
Roads & Maritime
Services

The Team Leader Mining Projects
Major Development Assessment
GPO Box 39
SYDNEY NSW 2001

Attention: Mr Kane Winwood

DA 75/256 MOD 3 – MODIFICATION TO SPRING FARM QUARRY

Dear Mr Winwood,

I refer to your letter of 22 May 2012 requesting Roads and Maritime Services (RMS) to provide comments regarding the abovementioned application for proposed modifications to Spring Farm Quarry.

RMS would like the following issues to be considered by the Department in its determination of the application:

1. Detailed design plans and hydraulic calculations of any changes to the stormwater drainage system are to be submitted to RMS for approval, prior to the commencement of any works.

Details should be forwarded to:
The Sydney Asset Management
Roads and Maritime Services
PO Box 973 Parramatta CBD 2124.

A plan checking fee will be payable and a performance bond may be required before RMS approval is issued. With regard to the Civil Works requirement please contact the RMS Project Engineer, External Works Ph: 8849 2114 or Fax: 8849 2766.

2. Prior to any Construction Certificate being issued, the developer is to submit detailed design drawings and geotechnical reports relating to the excavation of the site to RMS for assessment. The developer is to meet the full cost of this assessment.

This report will need to address the following key issues:

- a. The impact of excavation on the stability of Macarthur Bridge/Camden Bypass and detailing how the carriageway will be monitored for settlement.

Roads and Maritime Services

- b. The impact of the excavation on the structural stability of Macarthur Bridge/Camden Bypass.

The report and any enquiries should be forwarded to:

Project Engineer, External Works
Sydney Asset Management
Roads and Maritime services
PO Box 973 Parramatta CBD 2124.


Telephone 8848 2114
Fax 8849 2766

If it is necessary to excavate below the level of the base of the footings of the adjoining roadways, the person acting on the consent shall ensure that the owner of the roadway is given at least seven (7) days notice of the intention to excavate below the base of the footings. The notice is to include complete details of the work.

3. A maintenance levy towards the maintenance of local road utilised by quarry trucks (i.e. Macarthur Road) should be paid in accordance with the current levy program.

Please refer further enquiries to Stella Qu on telephone 8849 2520 or via email at Stella.Qu@rms.nsw.gov.au.

Yours sincerely



James Hall
Senior Land Use Planner
Transport Planning, Sydney Region

27 July 2012