



2 May 2019

NSW Health Infrastructure

Julian Cook
Senior Project Director
Level 14,
77 Pacific Highway,
North Sydney
NSW 2060

Re: Wyong Hospital Redevelopment

Dear Mr. Cook

Please see attached our commentary with the regard to the EIS response to submissions for the above development.

Item 1. GANSW

- *The introduction of a shelter structure or covered way along the path of travel from the north carpark to the entry; this could incorporate the car parking pay station and provide a space in which patients and visitors can seek refuge from inclement weather.*

A covered car parking pay station has been incorporated into the design as per the comments received by GANSW. Its location is noted on drawing 55372-HDR-AR-DWG-SSD1003[C]

- *Provide details of vertical shading devices to east and west facades.*

Vertical shading devices are provided to the east and west facades to mitigate heat gain. The shading devices consist of rectangular aluminum blades fixed back to the façade. Please refer to drawing 55372-HDR-AR-DWG-SSD1605[A] for further details

- *Provide details of heat-gain and glare control for the north facade.'*

Heat gain to the north façade will be minimised through glazing consisting of high performance Insulated Glazing Units (IGUs) with a low-E coating. The IGU glass provides an insulated air gap between two layers of glass minimising heat transfer from outside when outdoor temperatures are high during summer. The IGU also prevents heat loss from internal spaces when outdoor temperatures are low during winter. The low-E coating dissipates high energy solar radiation entering through the glazing. Internal roller blinds provide glare control as well as privacy for occupants.



Item 71. Bus bay

A future bus bay location has been incorporated into the precinct. Its location is noted on drawing 55372-HDR-AR-DWG-SSD1003[C]

Item 73. EOT

A location for future End of Trip facilities has been allocated on the Level 1 plan. It has been provided close to the Level 1 entry and its location is noted on drawing 55372-HDR-AR-DWG-SSD1201[C]

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Alan Boswell'.

Alan Boswell
Associate Director