

Approved Fire Gear Pty Ltd
 138 Melbourne Street
 East Maitland NSW 2323
 Ph: 02 49347147 Fax: 02 49335070
 ABN 51 001 974 385

Asset Record - Job No. 6841
WEA Hunter - 7 James Street
 7 James Street
 Argenton NSW 2284

Inspection Date: 16/01/2019
Contact: Donna
Phone: 4925 4200

Asset Register - Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Asset Number	Location	Size	Type	Brand	Pressure Test Date	Date	Service	Pass / Fail
27803	1	Entrance from carport	4.5Kg	Powder	Firebox	16/09/2018	16/01/2019	5 Yearly 4.5Kg DCP	Pass
Notes	Supplied new for pressure test								

Asset Register - Fire Blankets - AS1851.2012

Asset ID	Asset Number	Location	Size	Brand	Date	Service	Pass / Fail
27804	2	Kitchen	1.2m x 1.8m	BFI	16/01/2019	Yearly	Pass
Notes	Remount						

Asset Register - Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Asset Number	Location	Size	Type	Brand	Pressure Test Date	Date	Service	Pass / Fail
27805	3	Kitchen	1Kg	Powder	Firebox	16/11/2018	16/01/2019	Yearly	Pass
Notes	Supplied and installed new Supplied and installed 1 x loc & use								
27806	4	End of hallway from kitchen	4.5Kg	Powder	Firebox	16/09/2018	16/01/2019	5 Yearly 4.5Kg DCP	Pass
Notes	Supplied new for pressure test								
27807	5	Open class room off kitchen	4.5Kg	Powder	Firebox	16/09/2018	16/01/2019	Yearly	Pass

Description Of Work

Comments / Recommendations

--

Approved Fire Gear Pty Ltd

138 Melbourne Street

East Maitland NSW 2323

Ph: 02 49347147 Fax: 02 49335070

ABN 51 001 974 385

Asset Record - Job No. 6841

WEA Hunter - 7 James Street

7 James Street

Argenton NSW 2284

Inspection Date: 16/01/2019

Contact: Donna

Phone: 4925 4200

Technician (Print Name):

Corrina Rhind

Licence No.

Customer (Print Name):

Technician (Signature):

Corrina Rhind

Customer (Signature):