

11 September 2015

Attention: Michele Nettlefold

Mr Cameron Sargent
Team Leader
Key Site Assessments
Department of Planning and Environment
GPO Box 39
Sydney NSW 2001

RE: State Significant Development Application (SSD 6533), Remediation of Block 5, within the EPA Declaration Area, and adjacent Areas at Barangaroo.

Dear Mr Sargent,


Thank you for your letter notifying Sydney Water of the re-exhibition of the SSD application for the remediation works at Barangaroo. We have reviewed the application and provide the following comments for your consideration.

- The developer will need to make the appropriate applications to Sydney Water to obtain formal requirements for protection and monitoring to build near or over our assets, including the critical SPS 1129, located in the area nominated in the online documentation, that provides wastewater services to the Barangaroo area.
- Previous advice can only be used as an indication only, is not a formal approval for these works, and is subject to change.
- An Environmental Management Plan, structural assessments, geotechnical studies and supporting information will need to be submitted as part of the appropriate Sydney Water application. Sydney Water will confirm at application phase what additional information will be required.
- Access to our assets will need to be maintain at all times for standard and emergency operational needs
- The environmental approval for any works associated with Sydney Waters systems will need to be covered under the Environmental Impact Assessment approval.

It is recommended that the applicant continues to work with Sydney Water to confirm protection and monitoring requirements.

If you require any further information, please contact myself on 02 8849 3512 or e-mail Darryl.Foster@sydneywater.com.au

Yours Sincerely,



Darryl Foster
Manager, Asset Services

