

20 Nov 2019

Enquiries: Olivier Gaussen
Project No: 41136

Hansen Yuncken Pty Ltd
Level 3, 479 St Kilda Road
MELBOURNE

Attention: Sasha Vuckovic

Dear Sasha,

**RE: Goulburn Hospital and Health Service Re-development ECI Main Works
Response to SSDA Submission**

This letter addresses a query raised by the NSW Department of Planning, Industry and Environment in their response to the SSDA submission for the redevelopment of Goulburn Hospital (SSD-8667-Mod-2). Specifically the request was to:

Provide clarification on the function of the 'open plant area' and any resultant noise impacts on the proposed palliative care roof terrace.

Regarding the noise impacts to the Level 2 palliative care roof terrace, the noise breakout from the plant is not expected to exceed the rated background noise level (RBL) of the area, provided that the acoustic measures outlined in the acoustic report AC-RE-006-DD_09 (dated 20/11/2019) are implemented.

Please do not hesitate to contact the undersigned if you have any queries.

Yours sincerely



Olivier Gaussen

for **Wood & Grieve Engineers now part of Stantec**