

Kiosk re-location advice

From: **Cathy Lean** <CLean@northrop.com.au>

Date: Fri, 31 Jan 2020 at 09:49

Subject: RE: 112 Euston - DA revisions _ WNM mark ups

To: David Watt <david@wattnext.com.au>, martin Bednarczyk - Archispectrum
<martin@archispectrum.com.au>

Cc: Ros Read <Ros@urbanperspectives.com.au>, Megan Geddes <megan@zenithlandscapes.com.au>, Anne Trevena <anne.trevena@buildrunrepair.com>, Steven Moon <steven@codefiresafety.com.au>, colin.thomson@ghd.com <colin.thomson@ghd.com>, Vince Doan <vince.doan@traffix.com.au>, Luke Krstanovski <luke.krstanovski@visy.com.au>, Peter Sliz - Archispectrum <peter@archispectrum.com.au>, Jake Luschwitz <jake.luschwitz@visy.com.au>, Manny Martin <m.martin@umea.com.au>, Laki Revellos <lrevellos@hhconsult.com.au>

Hi David and Martin,

The substation may go in the location shown as long as there are no other services beneath it. It would have the least impact on the tree root zones. Can you show the substation and its easement as per Site plan A. 3.3m x 5.3m. The one shown is for URDs only. The substations are orientated so that the HV end faces the on coming traffic.

Kind regards,

Cathy Lean

Senior Electrical Engineer | ASP3 Group Manager

Northrop Consulting Engineers Pty Ltd

T 02 9241 4188 M 0484 684 570

D 02 9156 3004

L11, 345 George Street Sydney NSW 2000

www.northrop.com.au



Follow us on

