

Project Number: 640029.000
Project Name: North Sydney Public School
Date: 19 November 2021
To: Tarini Pathak, Turner & Townsend
From: Alex Krickx, Integral Group



Integral Group
Level 7, 16 Spring Street
Sydney NSW 2000
+ 61 2 9053 6730

ABN 27 618 557 672

Dear Tarini,

www.integralgroup.com

Re: NSPS Roof Layout Update + ESD Targets

Based on the updated roof layouts provided, there are currently 196 PV panels shown on the project roof. We were not provided a panel description, and have conservatively assumed 300 Watts per panel, which equates to a 58.8 kW System.

This system size is substantial and supports the ESD ambitions of the project. We do not see any changes from the initial ESD targets based on this layout.

Yours sincerely

Alex Krickx
GSAP, LEED AP, BEMP
Associate
On behalf of Integral Group

