



## NSW RURAL FIRE SERVICE

Department of Planning and Environment (Sydney Offices)  
GPO Box 39  
Sydney NSW 2001

Your reference: SSI-8609189  
Our reference: DA20211019004516-Original-1

**ATTENTION:** Nathan Heath

Date: Tuesday 2 November 2021

Dear Sir/Madam,

**Development Application**  
**Other - Other Assessment - Industry**  
**Upper South Creek Advanced Water Recycling Centre Kemps Creek NSW 2178, (none)**

I refer to your correspondence regarding the above proposal which was received by the NSW Rural Fire Service on 19/10/2021.

Upon review of the Environmental Impact Statement (EIS), the NSW Rural Fire Services provides the following recommendations:

1. A minimum 10-metre Asset Protection Zone (APZ) is to be provided for structures and associated buildings/infrastructure (including the ground solar panels) according to section 8.3.5 of *Planning for Bush Fire Protection 2019*.
2. The Advanced Water Recycling Centre operational area (except for the onsite detention basins) is to be managed in perpetuity to the standards of an inner protection area (IPA) as outlined in Appendix 4 of *Planning for Bush Fire Protection 2019*.
3. Operational access roads, including the provision for a perimeter access road for the ground solar panels, comply with the standards for property access as outlined in Table 7.4a of *Planning for Bush Fire Protection 2019*.
4. The provision of water, electricity, and gas comply with Table 7.4a of *Planning for Bush Fire Protection 2019*.

For any queries regarding this correspondence, please contact Simon Derevnin on 1300 NSW RFS.

Yours sincerely,

Adam Small  
**Supervisor Development Assessment & Plan**  
**Built & Natural Environment**

### Postal address

NSW Rural Fire Service  
Locked Bag 17  
GRANVILLE NSW 2142

### Street address

NSW Rural Fire Service  
4 Murray Rose Ave  
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555  
F (02) 8741 5550  
[www.rfs.nsw.gov.au](http://www.rfs.nsw.gov.au)