

13 June 2023



ATT: Kevin Kim
Department of Planning and Environment

24-28 Campbell St
Sydney NSW 2000
All mail to
GPO Box 4009
Sydney NSW 2001
T +61 2 13 13 65
ausgrid.com.au

Dear Kevin,

In reference to New Independent School in North Sydney (SSD-46014456).

Ausgrid would like to thank you for seeking input and feedback regarding the Environmental Impact Statement (EIS). Ausgrid has undertaken a review of the EIS and associated information in relation to potential impacts or interfaces with Ausgrid's electricity infrastructure.

Ausgrid requires that due consideration be given to the compatibility of proposed development with existing Ausgrid infrastructure, particularly in relation to risks of electrocution, fire risks, Electric & Magnetic Fields (EMFs), noise, visual amenity and other matters that may impact on Ausgrid or the development.

Ausgrid has 132,000V underground cables positioned adjacent to the site in Faith Bandler PL.

The proponent must check the location of all underground cables by using Before You Dig Australia (BYDA) and comply with the requirements of Ausgrid Network standard 156: Working Near or Around Underground Cables. Ausgrid will need to be contacted prior to any construction works commencing within 2m of these cables.

Ausgrid notes that in Appendix AA "Infrastructure Report" the proponent has already contacted Ausgrid regarding future supply to the development. We encourage the proponent to continue to discuss connections to the site directly with Ausgrid and submit a connection application to Ausgrid as soon as practicable.

Please do not hesitate to contact me for further information.

Regards,

A handwritten signature in black ink, appearing to read "Paul Nakhle", with a long horizontal stroke extending to the right.

Paul Nakhle - Portfolio Manager - Asset Protection | Transmission Services
02 9269 7587 | 0419 631 174

Connecting communities,
empowering lives