



**Veolia Australia & New Zealand**

Spring Farm Resource Recovery Park  
**20 Barrow Road**  
**Spring Farm NSW 2570**  
**Australia**

10 January 2025

DPHI

**Re: Detailed Report in accordance with Condition 5.1 of MP05\_0098.**

Please see below details of the smoldering event at the Spring Farm facility on 6 January 2025.

Event commenced at 9:46am.  
Event completed at 9:52am.  
No release to atmosphere. No notification to the EPA required.  
No emergency services assistance required.  
Actions completed on 6 January 2025.

Record No. 80652

Reported By: Kelly Gee

Area: Veolia Site Spring Farm ARRF

Actual Hazard Location: Dry waste receival loading area

Occurred Date/Time: Monday, 6 January 2025 9:46 AM

Hazard Type: Substances

Hazard Type Sub-Category: Fire / Explosion / smolder

Potential Severity: Moderate

Description: Unidentified incompatible waste ignition source started a smolder in a dry water pile in the transfer station.

Immediate Action Taken: Removed the hazard

Has the immediate action taken eliminated or mitigated the hazard?: Yes

Action Taken / Suggested Action: Fire hoses deployed. Site manager notified. Incoming vehicles suspended. Smolder area removed from larger dry waste stockpile by use of excavator. Smolder extinguished. Material wet down. Approx 300kg involved in incident. Loaded out to landfill on next available walking floor.

Created By: Kelly Gee

Created Date: 06/01/2025 9:54 AM

Actions:

- Retract fire hoses deployed. COMPLETED 06/01/2025
- Waste involved in event disposed to landfill. COMPLETED 06/01/2025

If you have any questions on the above matter, please do not hesitate to contact Kelly Gee on 0429 808 696.

Yours sincerely

**Kelly Gee**

Environmental Manager NSW/ACT  
[kelly.gee@veolia.com](mailto:kelly.gee@veolia.com)

**Veolia Australia & New Zealand**  
20 Barrow Road, Spring Farm NSW 2570  
Phone : 13 13 35  
[www.veolia.com.au](http://www.veolia.com.au)