



AIR QUALITY IMPACT ASSESSMENT  
ORORA BOTANY MILL  
WATER TREATMENT PLANT UPGRADE

30 June 2016

Job Number 16020537

Prepared by

Todoroski Air Sciences Pty Ltd

Suite 2B, 14 Glen Street

Eastwood, NSW 2122

Phone: (02) 9874 2123

Fax: (02) 9874 2125

Email: [info@airsciences.com.au](mailto:info@airsciences.com.au)

# Air Quality Impact Assessment

## Orora Botany Mill

### Water Treatment Plant Upgrade

**Author(s):** Aleks Todoroski      Philip Henschke      Michelle Yu

**Position:** Director      Atmospheric Physicist      Chemical Engineer

**Signature:**

**Date:**

#### DOCUMENT CONTROL

| Report Version | Date       | Prepared by        | Reviewed by |
|----------------|------------|--------------------|-------------|
| DRAFT – 001    | 30/06/2016 | M. Yu & P Henschke | A Todoroski |
| Final - 001    | 30/06/2016 | A Todoroski        |             |
|                |            |                    |             |
|                |            |                    |             |
|                |            |                    |             |
|                |            |                    |             |

This report has been prepared in accordance with the scope of works between Todoroski Air Sciences Pty Ltd (TAS) and the client. TAS relies on and presumes accurate the information (or lack thereof) made available to it to conduct the work. If this is not the case, the findings of the report may change. TAS has applied the usual care and diligence of the profession prevailing at the time of preparing this report and commensurate with the information available. No other warranty or guarantee is implied in regard to the content and findings of the report. The report has been prepared exclusively for the use of the client, for the stated purpose and must be read in full. No responsibility is accepted for the use of the report or part thereof in any other context or by any third party.

## TABLE OF CONTENTS

|       |                                                                                   |    |
|-------|-----------------------------------------------------------------------------------|----|
| 1     | INTRODUCTION.....                                                                 | 1  |
| 2     | LOCAL SETTING.....                                                                | 1  |
| 3     | PROJECT DESCRIPTION .....                                                         | 4  |
| 3.1   | Description of proposed WTP.....                                                  | 4  |
| 3.2   | Proposed WTP layout.....                                                          | 5  |
| 3.3   | Proposed gas treatment and use .....                                              | 7  |
| 4     | AIR QUALITY ASSESSMENT CRITERIA .....                                             | 8  |
| 4.1   | Preamble.....                                                                     | 8  |
| 4.2   | Odour.....                                                                        | 8  |
| 4.2.1 | Introduction .....                                                                | 8  |
| 4.2.2 | Complex Mixtures of Odorous Air Pollutants.....                                   | 9  |
| 4.2.3 | Specific odour criteria for Orora .....                                           | 9  |
| 4.3   | Particulate matter.....                                                           | 9  |
| 4.3.1 | New South Wales Environment Protection Authority impact assessment criteria ..... | 10 |
| 4.3.2 | National Environment Protection (Ambient Air Quality) Measure .....               | 10 |
| 4.4   | Combustion air pollutants.....                                                    | 11 |
| 4.4.1 | Protection of the Environment Operations (Clean Air) Regulation 2010 .....        | 11 |
| 5     | EXISTING ENVIRONMENT.....                                                         | 12 |
| 5.1   | Local climate .....                                                               | 12 |
| 5.2   | Local meteorological conditions.....                                              | 13 |
| 5.3   | Ambient air quality.....                                                          | 15 |
| 5.3.1 | PM <sub>10</sub> monitoring.....                                                  | 15 |
| 5.3.2 | PM <sub>2.5</sub> monitoring .....                                                | 16 |
| 5.3.3 | SO <sub>2</sub> monitoring .....                                                  | 17 |
| 5.3.4 | NO <sub>2</sub> monitoring .....                                                  | 18 |
| 5.3.5 | CO monitoring .....                                                               | 19 |
| 6     | DISPERSION MODELLING APPROACH .....                                               | 21 |
| 6.1   | Introduction.....                                                                 | 21 |
| 6.2   | Modelling methodology .....                                                       | 21 |
| 6.2.1 | Meteorological modelling .....                                                    | 21 |
| 6.2.2 | Dispersion modelling .....                                                        | 25 |
| 7     | DISPERSION MODELLING RESULTS.....                                                 | 30 |
| 7.1   | Odour.....                                                                        | 30 |
| 7.2   | Combustion products.....                                                          | 31 |
| 8     | DISCUSSION .....                                                                  | 32 |
| 9     | SUMMARY AND CONCLUSIONS .....                                                     | 33 |
| 10    | REFERENCES .....                                                                  | 34 |

## LIST OF APPENDICES

APPENDIX A – Peak-to-mean ratios

## LIST OF TABLES

|                                                                                                                                          |    |
|------------------------------------------------------------------------------------------------------------------------------------------|----|
| Table 4-1: Impact assessment criteria for complex mixtures of odorous air pollutants (nose-response-time average, 99th percentile) ..... | 9  |
| Table 4-2: NSW EPA air quality impact assessment criteria .....                                                                          | 10 |
| Table 4-3: Standard for PM <sub>10</sub> and PM <sub>2.5</sub> concentrations.....                                                       | 10 |
| Table 4-4: Goal for PM <sub>2.5</sub> concentrations by 2025.....                                                                        | 11 |
| Table 4-5: Applicable air quality impact assessment criteria for potential combustion air pollutants ....                                | 11 |
| Table 4-6: Standards of concentration for schedule premises.....                                                                         | 11 |
| Table 5-1: Monthly climate statistics summary – Sydney Airport AMO .....                                                                 | 12 |
| Table 5-2: Summary of PM <sub>10</sub> levels from NSW OEH TEOM monitoring (µg/m <sup>3</sup> ).....                                     | 16 |
| Table 5-3: Summary of PM <sub>2.5</sub> levels from NSW EPA BAM monitoring (µg/m <sup>3</sup> ) .....                                    | 17 |
| Table 5-4: Summary of SO <sub>2</sub> levels from NSW EPA monitoring sites (µg/m <sup>3</sup> ).....                                     | 17 |
| Table 5-5: Summary of NO <sub>2</sub> levels from NSW EPA monitoring sites (µg/m <sup>3</sup> ).....                                     | 18 |
| Table 5-6: Summary of CO levels from NSW EPA monitoring sites (mg/m <sup>3</sup> ).....                                                  | 19 |
| Table 6-1: Surface observation stations .....                                                                                            | 22 |
| Table 6-2: Odour emission inventory of the existing scenario.....                                                                        | 26 |
| Table 6-3: Odour emission inventory of the proposed WTP .....                                                                            | 27 |
| Table 6-4: Model parameters for the boiler stacks and gas engine .....                                                                   | 29 |
| Table 7-1: Predicted 99 <sup>th</sup> percentile nose-response odour concentrations at the sensitive receptors (OU).....                 | 30 |
| Table 7-2: Predicted incremental impact at the sensitive receptors.....                                                                  | 31 |

## LIST OF FIGURES

|                                                                                                                                            |    |
|--------------------------------------------------------------------------------------------------------------------------------------------|----|
| Figure 2-1: Project location .....                                                                                                         | 2  |
| Figure 2-2: Representative view of the topography surrounding the Project location.....                                                    | 3  |
| Figure 3-1: Indicative locations of proposed secondary WTP .....                                                                           | 5  |
| Figure 3-2: Indicative layout relative to other services (proposed Option A) .....                                                         | 6  |
| Figure 3-3: Indicative layout relative to other services (proposed Option B).....                                                          | 6  |
| Figure 5-1: Monthly climate statistics summary – Sydney Airport AMO .....                                                                  | 13 |
| Figure 5-2: Annual and seasonal windroses for Sydney Airport AMO.....                                                                      | 14 |
| Figure 5-3: NSW EPA monitoring sites .....                                                                                                 | 15 |
| Figure 5-4: 24-hour average PM <sub>10</sub> concentrations.....                                                                           | 16 |
| Figure 5-5: 24-hour average PM <sub>2.5</sub> concentrations.....                                                                          | 17 |
| Figure 5-6: Maximum daily 1 hour average SO <sub>2</sub> concentrations.....                                                               | 18 |
| Figure 5-7: Maximum daily 1 hour average NO <sub>2</sub> concentrations.....                                                               | 19 |
| Figure 5-8: Maximum daily rolling 8 hour average CO concentrations .....                                                                   | 20 |
| Figure 6-1: Windroses from CALMET extract at 10m height (Cell Ref 5050).....                                                               | 23 |
| Figure 6-2: Meteorological analyses of CALMET extract (Cell Ref 5050) .....                                                                | 24 |
| Figure 6-3: Locations of modelled emission sources.....                                                                                    | 28 |
| Figure 7-1: Predicted 99 <sup>th</sup> percentile nose-response odour concentration (OU) for the existing and the proposed scenarios ..... | 30 |

## 1 INTRODUCTION

Todoroski Air Sciences has prepared this air quality impact assessment report for Orora (hereafter referred to as the Proponent). It provides an assessment of the potential air quality impacts associated with the proposed upgrades to the Orora Botany Mill Water Treatment Plant (WTP) (hereafter referred to as the Project).

To assess the potential air quality impacts associated with the Project, this report incorporates the following aspects:

- ✦ An outline of the local setting, background and description of the Project;
- ✦ A review of the existing meteorological and air quality environment surrounding the Project;
- ✦ A description of the dispersion modelling approach used to assess potential air quality impacts;
- ✦ An outline of the estimated potential air emissions associated with the Project; and,
- ✦ Presentation of the predicted results and discussion of the potential air quality impacts.

## 2 LOCAL SETTING

The Project is located approximately 5 kilometres (km) east-southeast of Sydney Airport and approximately 11km south-southeast of the Sydney Central Business District (CBD) (see **Figure 2-1**).

The land use in the surrounding area is characterised as urban residential areas to the east and northeast of the site. Commercial and industrial areas are identified in all directions with the nearest to the northwest and Port Botany to the south.

**Figure 2-1** presents the location of the Project in relation to the potentially most affected sensitive receptors of relevance to this assessment.

**Figure 2-2** presents a pseudo three-dimensional (3D) visualisation of the topography in the general vicinity of the Project area. The area can be characterised as relatively flat to the west and gently sloping towards higher ground towards the east, nearer the ocean coastline.

The local land use and terrain in this area would have an effect on wind patterns and dispersion of air emissions. The key effects relate to the proximity of the Project to the coastline, and the associated sea-breezes and other such coastal effects which would occur.






Figure 2-1: Project location




Figure 2-2: Representative view of the topography surrounding the Project location

### 3 PROJECT DESCRIPTION

Orora operates a paper mill at Botany Road, Matraville NSW. The paper mill utilises 100% recycled waste paper and requires significant quantities of water to process and manufacture finished paper products.

Process water generated at the site is currently treated at the on-site Primary Dissolved Air Flotation (DAF) Wastewater Treatment Plant WTP before being discharged to the Sydney Water sewerage system.

Orora is proposing to upgrade its WTP which involves the construction and operation of a secondary treatment process

#### 3.1 Description of proposed WTP

The upgraded WTP would consist of the following components:

- ✦ Anaerobic water treatment
  - Anaerobic reactor & associated process equipment
  - Chemical storage & dosing
  - Biogas scrubbing, storage & emergency flare
  - Sulphur capture & removal process
  - Sludge storage & transport
- ✦ Aerobic water treatment
  - Aeration tank & clarifier
  - Various pumps and blowers
  - Associated process equipment
  - Sludge dewatering & storage
- ✦ Gas engine & electricity generation
- ✦ Odour control systems
- ✦ Internal maintenance road, stairways and other access facilities

The upgraded WTP would utilise the existing infrastructure to provide primary treatment of wastewater and also incorporate a two stage secondary treatment process. Anaerobic and aerobic treatment processes would be used to remove substances in the wastewater that generate high Biochemical Oxygen Demand (BOD).

Anaerobic digestion is a process by which specific microorganism bacteria break down biodegradable material in the absence of oxygen. Additional nutrients required by the anaerobic bacteria are




supplied in the form of urea (nitrogen) and phosphate (phosphorus). The by-products of the anaerobic process are methane, hydrogen sulfide, other trace gases and excess microorganisms (known as anaerobic sludge). The volume of anaerobic sludge generated by the process is relatively small and would be either reused for re-seeding the anaerobic reactor, sold for use in another wastewater treatment plant or dewatered for disposal.

Following the anaerobic process, wastewater is then pumped to the aerobic treatment stage where it is mixed in with bacteria and a surplus of oxygen. The process further breaks down any remaining nutrients in the wastewater. The aerobic stage will further reduce the BOD load to domestic sewage levels. This stage occurs in a surplus of oxygen and generally would not generate excessive odour.

### 3.2 Proposed WTP layout

The WTP upgrades are proposed to be located in a central area of the site, adjacent to the existing WTP and the boiler house. Two indicative locations are available for the upgrade, as shown in **Figure 3-1**.

In this assessment it has been assumed that the Project would be positioned in the location closest to the nearest sensitive receptors. This would represent a potential worst-case for air quality impact and has been considered in this assessment to ensure conservatism (i.e. overestimation of potential impacts).



**Figure 3-1: Indicative locations of proposed secondary WTP**

Specific details for the upgraded WTP have not been finalised and the Proponent is currently choosing between two similar process designs. These are referred to as Option A and Option B.

An indicative layout of the process Option A is shown in **Figure 3-2**.




Figure 3-2: Indicative layout relative to other services (proposed Option A)

An indicative layout of the process Option B is shown in **Figure 3-3**.




Figure 3-3: Indicative layout relative to other services (proposed Option B)

The key differences between the two process designs include:

- ✦ The positions of the aerobic and anaerobic processes are swapped between the options;
- ✦ The anaerobic tank of the Option B process would be fully sealed, while the some of the gas from the anaerobic tank of the Option A process would bleed through a biological odour control unit together with the gas from the granular sludge tank; and,
- ✦ Some differences in the different types of equipment including the clarifier and sludge dewatering equipment.

An important observation is that the proposed WTP would be sited as far as is practicable from receptors. The nearest element of the upgraded WTP (aeration tank and clarifier) would be approximately 160m from the nearest residence located on Partanna Avenue (Receptor R5 in **Figure 2-1**).

### 3.3 Proposed gas treatment and use

Wastewater from the paper making process generally contains sulphur compounds and during the anaerobic treatment process, some amount of this sulphur is converted to hydrogen sulphide ( $H_2S$ ).

Gas generated from the anaerobic process will be scrubbed to remove  $H_2S$ , and then stored in a large bladder. This scrubbing process produces elemental sulphur which can be sold, and essentially eliminates  $H_2S$  odours (due to a removal efficiency of 99.9% of  $H_2S$ ) and significantly reduces  $SO_x$  emissions by burning the remainder of the gases in an engine.

From the gas storage bladder, the captured biogas will be consumed in a gas engine to produce electricity for use by the site. When the generator isn't available, excess gas would be burnt in the emergency flare. The emergency flare would be operational infrequently and as a last resort measure. This would be a rare and exceptional circumstance as the electricity produced would be less than is needed for normal operations.

The gas from the headspace of the granular sludge tank and a portion of the gas from the anaerobic tank of the Option A process would pass through a biological packed bed odour control unit to ensure potential odours are managed.

---

## 4 AIR QUALITY ASSESSMENT CRITERIA

### 4.1 Preamble

Air quality criteria are benchmarks set to protect the general health and amenity of the community in relation to air quality. The sections below identify the potential air emissions generated by the Project and the applicable air quality criteria.

### 4.2 Odour

#### 4.2.1 Introduction

Odour in a regulatory context needs to be considered in two similar, but different ways depending on the situation.

NSW legislation prohibits emissions that cause offensive odour to occur at any off-site receptor. Offensive odour is evaluated in the field by authorised officers, who are obliged to consider the odour in the context of its receiving environment, frequency, duration, character and so on and to determine whether the odour would interfere with the comfort and repose of the normal person unreasonably. In this context, the concept of offensive odour is applied to operational facilities and relates to actual emissions in the air.

However, in the approval and planning process for proposed new operations or modifications to existing projects, no actual odour exists and it is necessary to consider hypothetical odour. In this context, odour concentrations are used and are defined in odour units. The number of odour units represents the number of times that the odour would need to be diluted to reach a level that is just detectable to the human nose. Thus by definition, odour less than one odour unit (1 OU), would not be detectable to most people.

The range of a person's ability to detect odour varies greatly in the population, as does their sensitivity to the type of odour. The wide ranging response in how any particular odour is perceived by any individual poses specific challenges in the assessment of odour impacts and the application of specific air quality goals related to odour. The NSW Odour Policy (**NSW DEC, 2006**) sets out a framework specifically to deal with such issues.

It needs to be noted that the term odour refers to complex mixtures of odours, and not "pure" odour arising from a single chemical. Odour from a single, known chemical very rarely occurs (when it does, it is best to consider that specific chemical in terms of its concentration in the air). In most situations odour will be comprised of a cocktail of many substances that is referred to as a complex mixture of odour, or more simply odour.

For activities with potential to release significant odour it may be necessary to predict the likely odour impact that may arise. This is done by using air dispersion modelling which can calculate the level of dilution of odours emitted from the source at the point that such odour reaches surrounding receptors. This approach allows the air dispersion model to produce results in terms of odour units.

The NSW criteria for acceptable levels of odour range from 2 to 7 OU, with the more stringent 2 OU criteria applicable to densely populated urban areas and the 7 OU criteria applicable to sparsely populated rural areas, as outlined below.



#### 4.2.2 Complex Mixtures of Odorous Air Pollutants

**Table 4-1** presents the assessment criteria as outlined in the NSW EPA document *Approved Methods for the Modelling and Assessment of Air Pollutants in NSW* (NSW DEC, 2005). This criterion has been refined to take into account the population densities of specific areas and is based on a 99th percentile of dispersion model predictions calculated as 1-second averages (nose-response time).

**Table 4-1: Impact assessment criteria for complex mixtures of odorous air pollutants  
(nose-response-time average, 99th percentile)**

| Population of affected community                   | Impact assessment criteria for complex mixtures of odorous air pollutants (OU) |
|----------------------------------------------------|--------------------------------------------------------------------------------|
| Urban ( $\geq 2000$ ) and/or schools and hospitals | 2.0                                                                            |
| ~500                                               | 3.0                                                                            |
| ~125                                               | 4.0                                                                            |
| ~30                                                | 5.0                                                                            |
| ~10                                                | 6.0                                                                            |
| Single rural residence ( $\leq 2$ )                | 7.0                                                                            |

Source: NSW DEC, 2005

The NSW odour goals are based on the risk of odour impact within the general population of a given area. In sparsely populated areas the criteria assume there is a lower risk that some individuals within the community would find the odour unacceptable, hence higher criteria apply.

Peak-to-mean factors are applied to account for any odour fluctuation above and below the mean odour level of the 1-hour averaging time. The criteria in **Table 4-1** are compared with modelled results that include peaking factors to account for the time-averaging limitations of air dispersion models. The peak-to-mean factors developed by **Katestone Scientific Pty Ltd (1995, 1998)** for NSW EPA are applied to convert the modelled (1-hour) averaging time to 1-second peak concentrations which are appropriate.

A summary of the peak-to-mean values is provided in **Appendix A**.

#### 4.2.3 Specific odour criteria for Orora

While 2OU may be the appropriate criterion to be applied for the Project based on **Table 4-1**, as the Project is located close to a densely populated residential area, the Technical Framework for the *Assessment and management of odour from stationary sources in NSW* (DEC, 2006) allows for a development of an acceptable odour performance of a facility. This would be agreed with the neighbours if appropriate mitigation strategies would not reduce the odour impacts at sensitive receptors to levels below the appropriate criteria. A site specific odour criterion was determined to be 6OU as analysed by **SKM (2006)** based on odour complaints data. Thus, a criterion of 6OU was applied in previous odour assessments for the site (**SKM, 2006** and **Benbow Environmental, 2010**) and is also applied in this assessment.

### 4.3 Particulate matter

Particulate matter consists of dust particles of varying size and composition. Air quality goals refer to measures of the total mass of all particles suspended in air defined as the Total Suspended Particulate matter (TSP). The upper size range for TSP is nominally taken to be 30 micrometres ( $\mu\text{m}$ ) as in practice



particles larger than 30 to 50µm will settle out of the atmosphere too quickly to be regarded as air pollutants.

Two sub-classes of TSP are also included in the air quality goals, namely PM<sub>10</sub>, particulate matter with equivalent aerodynamic diameters of 10µm or less, and PM<sub>2.5</sub>, particulate matter with equivalent aerodynamic diameters of 2.5µm or less.

Particulate matter, typically in the upper size range, that settles from the atmosphere and deposit on surfaces is characterised as deposited dust. The deposition of dust on surfaces is considered a nuisance and can adversely affect the amenity of an area by soiling property in the vicinity.

#### 4.3.1 New South Wales Environment Protection Authority impact assessment criteria

**Table 4-2** summarises the air quality goals that are relevant to this study as outlined in the NSW EPA document *Approved Methods for the Modelling and Assessment of Air Pollutants in NSW* (NSW DEC, 2005).

The air quality goals for total impacts relate to the total dust burden in the air and not just the dust from the Project. Consideration of background dust levels needs to be made when using these goals to assess potential impacts.

**Table 4-2: NSW EPA air quality impact assessment criteria**

| Pollutant        | Averaging period | Impact      | Criteria                 |
|------------------|------------------|-------------|--------------------------|
| TSP              | Annual           | Total       | 90µg/m <sup>3</sup>      |
| PM <sub>10</sub> | Annual           | Total       | 30µg/m <sup>3</sup>      |
|                  | 24 hour          | Total       | 50µg/m <sup>3</sup>      |
| Deposited dust   | Annual           | Incremental | 2g/m <sup>2</sup> /month |
|                  |                  | Total       | 4g/m <sup>2</sup> /month |

Source: NSW DEC, 2005

µg/m<sup>3</sup> = micrograms per cubic metre

g/m<sup>2</sup>/month = grams per square metre per month

#### 4.3.2 National Environment Protection (Ambient Air Quality) Measure

The National Environment Protection Council (NEPC) Act 1994 and subsequent amendments define the National Environment Protection Measures (NEPMs) as instruments for setting environmental objectives in Australia.

The Ambient Air Quality NEPM specifies national ambient air quality standards and goals for air pollutants including PM<sub>10</sub> and PM<sub>2.5</sub>. The standard for PM<sub>10</sub> and PM<sub>2.5</sub> is outlined in **Table 4-3**. The Ambient Air Quality NEPM allows for exceedance above the 24-hour average criterion in exceptional events such as bush fires and regional dust storms, and included goals for PM<sub>2.5</sub> concentrations (see **Table 4-4**).

**Table 4-3: Standard for PM<sub>10</sub> and PM<sub>2.5</sub> concentrations**

| Pollutant         | Averaging period | Maximum concentration |
|-------------------|------------------|-----------------------|
| PM <sub>10</sub>  | 24 hour          | 50µg/m <sup>3</sup>   |
|                   | Annual           | 25µg/m <sup>3</sup>   |
| PM <sub>2.5</sub> | 24 hour          | 25µg/m <sup>3</sup>   |
|                   | Annual           | 8µg/m <sup>3</sup>    |

Source: NEPC, 2016



Table 4-4: Goal for PM<sub>2.5</sub> concentrations by 2025

| Pollutant         | Averaging period | Maximum concentration |
|-------------------|------------------|-----------------------|
| PM <sub>2.5</sub> | 24 hour          | 20µg/m <sup>3</sup>   |
|                   | Annual           | 7µg/m <sup>3</sup>    |

Source: NEPC, 2016

As with each of the NEPM goals, these apply to the average, or general exposure of a population, rather than to "hot spot" locations or to individual industry projects.

#### 4.4 Combustion air pollutants

Emissions of air pollutants that arise from the operation of the natural gas fired equipment which may be relevant include sulfur dioxide (SO<sub>2</sub>), nitrogen dioxide (NO<sub>2</sub>) and carbon monoxide (CO). Other combustion air pollutants are too low to be of any tangible risk to the environment, and are not considered further.

**Table 4-5** outlines the applicable air quality assessment criteria, as outlined in the document *Approved Methods for the Modelling and Assessment of Air Pollutants in NSW* (NSW DEC, 2005), for potential combustion air pollutants that are considered in this assessment.

Table 4-5: Applicable air quality impact assessment criteria for potential combustion air pollutants

| Pollutant       | Averaging period | Criterion            |
|-----------------|------------------|----------------------|
| SO <sub>2</sub> | 10-minute        | 712µg/m <sup>3</sup> |
|                 | 1-hour           | 570µg/m <sup>3</sup> |
|                 | 24-hour          | 228µg/m <sup>3</sup> |
|                 | Annual           | 60µg/m <sup>3</sup>  |
| NO <sub>2</sub> | 1-hour           | 246µg/m <sup>3</sup> |
|                 | Annual           | 62µg/m <sup>3</sup>  |
| CO              | 15-minute        | 100mg/m <sup>3</sup> |
|                 | 1-hour           | 30mg/m <sup>3</sup>  |
|                 | 8-hour           | 10mg/m <sup>3</sup>  |

Source: NSW DEC, 2005

##### 4.4.1 Protection of the Environment Operations (Clean Air) Regulation 2010

The Protection of the Environment Operations (Clean Air) Regulation 2010 (POEO, 2010) outlines standards of concentrations for air emissions emitted from various plant. The emission limits applicable to the Project are summarised in **Table 4-6**.

Table 4-6: Standards of concentration for schedule premises

| Pollutant                                       | Applicable plant      | Standard of concentration |
|-------------------------------------------------|-----------------------|---------------------------|
| TSP                                             | Boiler                | 50mg/m <sup>3</sup>       |
|                                                 | Gas engine            | 50mg/m <sup>3</sup>       |
| NO <sub>x</sub> , as NO <sub>2</sub> equivalent | Boiler                | 300mg/m <sup>3</sup>      |
|                                                 | Gas engine            | 450mg/m <sup>3</sup>      |
| H <sub>2</sub> S                                | Any activity or plant | 5mg/m <sup>3</sup>        |
| CO                                              | Boiler                | 125mg/m <sup>3</sup>      |
|                                                 | Gas engine            | 125mg/m <sup>3</sup>      |

Source: POEO, 2010



## 5 EXISTING ENVIRONMENT

This section describes the existing environment including the climate and ambient air quality in the general area surrounding the Project.

### 5.1 Local climate

Long-term climatic data from the closest Bureau of Meteorology (BoM) weather station at Sydney Airport Aeronautical Meteorological Office (AMO) (Site No. 066037) were analysed to characterise the local climate in the proximity of the Project. The Sydney Airport AMO weather station is located approximately 5km west-northwest of the Project.

**Table 5-1** and **Figure 5-1** present a summary of data from the Sydney Airport AMO weather station collected over a 71 to 87-year period for the various meteorological parameters.

The data indicate that January is the hottest month with a mean maximum temperature of 26.5 degrees Celsius (°C) and July is the coldest month with a mean minimum temperature of 7.2°C.

Rainfall peaks during the first half of the year declines during the latter, with an annual average rainfall of 1083.7 millimetres (mm) over 96.0 days. The data indicate that June is the wettest month with an average rainfall of 122.5mm over 8.8 days and September is the driest month with an average rainfall of 60.3mm over 6.8 days.

Relative humidity exhibits little variability across the year. Mean 9am relative humidity ranges from 61% in October to 74% in June. Mean 3pm relative humidity levels range from 49% in August to 63% in February.

Wind speeds during the warmer months have a greater spread between the 9am and 3pm conditions compared to the cooler months. Mean 9am wind speeds range from 12.6 kilometres per hour (km/h) in May to 16.3km/h in October. Mean 3pm wind speeds range from 17.1km/h in May to 25.3km/h in November.

**Table 5-1: Monthly climate statistics summary – Sydney Airport AMO**

| Parameter                    | Jan  | Feb   | Mar   | Apr   | May  | Jun   | Jul  | Aug  | Sep  | Oct  | Nov  | Dec  | Ann.   |
|------------------------------|------|-------|-------|-------|------|-------|------|------|------|------|------|------|--------|
| <b>Temperature</b>           |      |       |       |       |      |       |      |      |      |      |      |      |        |
| Mean max. temperature (°C)   | 26.5 | 26.4  | 25.3  | 22.9  | 20.0 | 17.6  | 17.0 | 18.4 | 20.6 | 22.6 | 24.1 | 25.8 | 22.3   |
| Mean min. temperature (°C)   | 18.9 | 19.1  | 17.6  | 14.2  | 11.0 | 8.7   | 7.2  | 8.2  | 10.5 | 13.3 | 15.5 | 17.5 | 13.5   |
| <b>Rainfall</b>              |      |       |       |       |      |       |      |      |      |      |      |      |        |
| Rainfall (mm)                | 95.9 | 111.1 | 115.7 | 109.3 | 98.6 | 122.5 | 69.6 | 76.8 | 60.3 | 70.3 | 81.5 | 74.0 | 1083.7 |
| Mean No. of rain days (≥1mm) | 8.1  | 8.5   | 9.2   | 8.6   | 8.5  | 8.8   | 6.7  | 6.8  | 6.8  | 7.8  | 8.4  | 7.8  | 96.0   |
| <b>9am conditions</b>        |      |       |       |       |      |       |      |      |      |      |      |      |        |
| Mean temperature (°C)        | 22.4 | 22.3  | 21.1  | 18.2  | 14.6 | 11.9  | 10.8 | 12.5 | 15.7 | 18.4 | 19.9 | 21.6 | 17.4   |
| Mean relative humidity (%)   | 70   | 73    | 73    | 71    | 73   | 74    | 71   | 65   | 62   | 61   | 64   | 66   | 69     |
| Mean wind speed (km/h)       | 14.4 | 13.8  | 12.9  | 12.9  | 12.6 | 13.4  | 13.3 | 14.4 | 15.5 | 16.3 | 16.0 | 14.8 | 14.2   |
| <b>3pm conditions</b>        |      |       |       |       |      |       |      |      |      |      |      |      |        |
| Mean temperature (°C)        | 24.8 | 24.8  | 23.9  | 21.7  | 19.0 | 16.6  | 16.1 | 17.2 | 19.0 | 20.7 | 22.1 | 23.9 | 20.8   |
| Mean relative humidity (%)   | 60   | 63    | 61    | 59    | 58   | 57    | 52   | 49   | 51   | 54   | 56   | 58   | 57     |
| Mean wind speed (km/h)       | 24.1 | 23.0  | 21.0  | 19.3  | 17.1 | 17.8  | 18.2 | 20.8 | 23.1 | 24.6 | 25.3 | 25.2 | 21.6   |

Source: Bureau of Meteorology, 2016a (6 April 2016)






Figure 5-1: Monthly climate statistics summary – Sydney Airport AMO

## 5.2 Local meteorological conditions

Annual and seasonal windroses for the Sydney Airport AMO during the 2012 calendar period are presented in **Figure 5-2**.

Strong winds are generally experienced in the area due to its proximity to the coast. Winds from the northwest quadrant are typically weaker than winds from other directions. On an annual basis, the winds are varied with the highest portion originating from the northwest.

In summer, winds are typically from the northeast and southeast quadrants, with dominant winds from the northeast and south. The autumn distribution is similar to the annual distribution with a high portion of winds from the northwest. During winter, winds are typically from the southwest and northwest quadrants, with winds from the northeast most frequent. Spring has similar distribution to the annual distribution, however indicates a slightly higher portion of northeast winds.




Figure 5-2: Annual and seasonal windroses for Sydney Airport AMO

### 5.3 Ambient air quality

The main sources of air pollutants in the area surrounding the Project include emissions from local anthropogenic activities such as various commercial or industrial activities, motor vehicle exhaust and domestic wood heaters.

Ambient air quality monitoring data from the Project site are not available. Therefore the available data from the nearest air quality monitors operated by the NSW Office of Environment and Heritage (OEH) were used to quantify the existing background level for assessed pollutants at the Project site.

The NSW OEH air quality monitors at Randwick, Earlwood and Rozelle (see **Figure 5-3**) are approximately 4 to 12km from the site and are considered to be generally representative of the background levels in the vicinity of the Project site. The data from these monitors have therefore been used to quantify the existing ambient levels of air pollutants in this study.




Figure 5-3: NSW EPA monitoring sites

#### 5.3.1 PM<sub>10</sub> monitoring

A summary of the available data from the NSW OEH monitoring stations is presented in **Table 5-2**. Recorded 24-hour average PM<sub>10</sub> concentrations are presented in **Figure 5-4**.

A review of **Table 5-2** indicates that the annual average PM<sub>10</sub> concentrations for each monitoring station were below the relevant criterion of 30µg/m<sup>3</sup>. The maximum 24-hour average PM<sub>10</sub>


concentrations recorded at these stations were found to exceed the relevant criterion of  $50\mu\text{g}/\text{m}^3$  at times during the review period (see **Figure 5-4**).

**Table 5-2: Summary of PM<sub>10</sub> levels from NSW OEH TEOM monitoring ( $\mu\text{g}/\text{m}^3$ )**

| Station ID | Annual average |      |      |      |      | Maximum 24-hour average |      |      |      |      |
|------------|----------------|------|------|------|------|-------------------------|------|------|------|------|
|            | 2011           | 2012 | 2013 | 2014 | 2015 | 2011                    | 2012 | 2013 | 2014 | 2015 |
| Randwick   | 15.9           | 18.0 | 18.8 | 18.2 | 18.6 | 40.1                    | 43.7 | 55.3 | 46.1 | 77.4 |
| Earlwood   | 18.1           | 19.6 | 19.9 | 18.3 | 17.2 | 124.9                   | 44.2 | 63.1 | 45.2 | 66.5 |
| Rozelle    | 16.6           | 16.9 | 18.3 | 17.8 | 16.7 | 39.4                    | 40.7 | 58.5 | 43.8 | 60.3 |

The Ambient Air Quality NEPM standard for 24 hour average PM<sub>10</sub> is a level of  $50\mu\text{g}/\text{m}^3$  with an allowance for extraordinary events such as bushfires and dust storms that may produce dust levels above the standard (refer to **Table 4-3**).

It can be seen from **Figure 5-4** that PM<sub>10</sub> concentrations are nominally highest in the spring and summer months with the warmer weather raising the potential for drier ground elevating the occurrence of windblown dust, bushfires and increased pollen levels.



**Figure 5-4: 24-hour average PM<sub>10</sub> concentrations**

### 5.3.2 PM<sub>2.5</sub> monitoring

A summary of the PM<sub>2.5</sub> readings from the NSW EPA monitoring stations is presented in **Table 5-3**. The recorded 24-hour average PM<sub>2.5</sub> concentrations are presented in **Figure 5-5**.


**Table 5-3** indicates that the annual average PM<sub>2.5</sub> concentration for the Earlwood monitoring station was  $0.7\mu\text{g}/\text{m}^3$  above the NEPM standard of  $8\mu\text{g}/\text{m}^3$  in 2015. For all other periods the annual average PM<sub>2.5</sub> concentrations were below standard. The Rozelle monitoring station indicated levels below the standard in 2015.

The lower PM<sub>2.5</sub> levels recorded in 2011 and 2012 may be due to La Niña experienced in Australia which brought heavy rainfalls (**BOM, 2016b**).

**Table 5-3: Summary of PM<sub>2.5</sub> levels from NSW EPA BAM monitoring (µg/m<sup>3</sup>)**

| Station ID             | Annual average |      |      |      |      | Maximum 24-hour average |      |      |      |      |
|------------------------|----------------|------|------|------|------|-------------------------|------|------|------|------|
|                        | 2011           | 2012 | 2013 | 2014 | 2015 | 2011                    | 2012 | 2013 | 2014 | 2015 |
| Earlwood               | 5.4            | 5.6  | 7.9  | 7.8  | 8.7  | 23.6                    | 20.7 | 37.3 | 22.7 | 28.0 |
| Rozelle <sup>(1)</sup> | -              | -    | -    | -    | 7.2  | -                       | -    | -    | -    | 33.4 |

<sup>(1)</sup>Data available from March 2015



**Figure 5-5: 24-hour average PM<sub>2.5</sub> concentrations**

### 5.3.3 SO<sub>2</sub> monitoring


**Table 5-5** presents a summary of the SO<sub>2</sub> monitoring data and shows that the maximum 1-hour average SO<sub>2</sub> level during the 2011 to 2015 period at these monitors was 88.66µg/m<sup>3</sup> recorded at Randwick. The annual average levels recorded at both Randwick and Rozelle during the period were a uniform level of 2.86µg/m<sup>3</sup> which is the equivalent to the resolution of the recorded SO<sub>2</sub> levels of 0.1 parts per hundred million (pphm).

**Table 5-4: Summary of SO<sub>2</sub> levels from NSW EPA monitoring sites (µg/m<sup>3</sup>)**

| Station ID             | 2011                   | 2012 | 2013 | 2014 | 2015 |
|------------------------|------------------------|------|------|------|------|
|                        | Annual Average         |      |      |      |      |
| Randwick               | 2.86                   | 2.86 | 2.86 | 2.86 | 2.86 |
| Rozelle <sup>(1)</sup> | -                      | -    | -    | -    | 2.86 |
| Station ID             | Maximum 1-hour average |      |      |      |      |
|                        | 2011                   | 2012 | 2013 | 2014 | 2015 |
| Randwick               | 65.8                   | 65.8 | 77.2 | 74.4 | 88.7 |
| Rozelle <sup>(1)</sup> | -                      | -    | -    | -    | 80.1 |

<sup>(1)</sup>Data available from February 2015

**Figure 5-7** presents the maximum daily 1-hour average SO<sub>2</sub> concentrations recorded at the NSW EPA monitoring sites from 2011 to 2015. The monitoring data reviewed indicate that there were no exceedances of the NSW EPA 1-hour average goal of 570 µg/m<sup>3</sup> during this period at the monitors. The data in **Figure 5-6** indicate that levels of SO<sub>2</sub> are relatively low compared to the criterion level and show no clear seasonal variation.



**Figure 5-6: Maximum daily 1 hour average SO<sub>2</sub> concentrations**

#### 5.3.4 NO<sub>2</sub> monitoring

**Table 5-5** presents a summary of the NO<sub>2</sub> monitoring data and shows that the maximum 1-hour average NO<sub>2</sub> level during the 2011 to 2015 period at these monitors was 143.5 µg/m<sup>3</sup> recorded at Rozelle. The maximum annual average level during the period was also recorded at Rozelle with a level of 24.6 µg/m<sup>3</sup>.

**Table 5-5: Summary of NO<sub>2</sub> levels from NSW EPA monitoring sites (µg/m<sup>3</sup>)**


| Station ID | 2011                   | 2012  | 2013  | 2014  | 2015  |
|------------|------------------------|-------|-------|-------|-------|
|            | Annual Average         |       |       |       |       |
| Randwick   | 14.4                   | 12.3  | 14.4  | 12.3  | 16.4  |
| Earlwood   | 18.5                   | 18.5  | 20.5  | 16.4  | 16.4  |
| Rozelle    | 22.6                   | 24.6  | 22.6  | 22.6  | 22.6  |
| Station ID | Maximum 1-hour average |       |       |       |       |
|            | 2011                   | 2012  | 2013  | 2014  | 2015  |
| Randwick   | 108.7                  | 84.1  | 94.3  | 96.4  | 88.2  |
| Earlwood   | 94.3                   | 104.6 | 98.4  | 82.0  | 108.7 |
| Rozelle    | 102.5                  | 127.1 | 143.5 | 112.8 | 123.0 |

**Figure 5-7** presents the maximum daily 1-hour average NO<sub>2</sub> concentrations recorded at the NSW EPA monitoring sites from 2011 to 2015. The monitoring data reviewed indicate that there were no exceedances of the NSW EPA 1-hour average goal of 246 µg/m<sup>3</sup> during this period at the monitors.

16020537\_OroraWTP\_AQIA\_160630.docx



The data in **Figure 5-7** indicate that levels of NO<sub>2</sub> are relatively low compared to the criterion level and show a clear trend of seasonal fluctuation. Higher NO<sub>2</sub> concentrations occur during the cooler months with the low temperatures and less sunlight which makes the NO<sub>2</sub> less readily consumed in the formation of ozone (**DECCW, 2010**).



**Figure 5-7: Maximum daily 1 hour average NO<sub>2</sub> concentrations**

### 5.3.5 CO monitoring

**Table 5-6** presents a summary of the CO monitoring data and shows that the maximum 8-hour rolling average CO level during the 2011 to 2015 period recorded at Rozelle was 2.8mg/m<sup>3</sup>. Based on the 8-hour rolling average CO monitoring data which are low compared to the goal, it is likely that the CO levels of other averaging times would also be below the applicable air quality goals.

**Table 5-6: Summary of CO levels from NSW EPA monitoring sites (mg/m<sup>3</sup>)**

| Station ID | 2011                           | 2012 | 2013 | 2014 | 2015 |
|------------|--------------------------------|------|------|------|------|
|            | Maximum 8-hour rolling average |      |      |      |      |
| Rozelle    | 1.8                            | 2.8  | 2.3  | 1.4  | 1.4  |

**Figure 5-8** presents the maximum daily rolling 8-hour average CO concentrations recorded at the NSW EPA monitoring sites from 2011 to 2015. The monitoring data reviewed indicate that there were no exceedances of the NSW EPA 8-hour average goal of 10mg/m<sup>3</sup> during this period at the monitors.

The data in **Figure 5-8** indicate that measured levels of CO are low compared to the criterion level and show a similar but less pronounced seasonal fluctuation trend relative to the trends in NO<sub>2</sub> concentrations. Similar to the NO<sub>2</sub>, the CO is a precursor to the formation of ozone (**Saini et al, 2008**)

and with less available sunlight in the cooler months, it is less readily consumed in the formation of ozone.




Figure 5-8: Maximum daily rolling 8 hour average CO concentrations

## 6 DISPERSION MODELLING APPROACH

### 6.1 Introduction

The following sections are included to provide the reader with an understanding of the model and modelling approach.

For this assessment the CALPUFF modelling suite is applied to dispersion modelling. The CALPUFF model is an advanced "puff" model that can deal with the effects of complex local terrain on the dispersion meteorology over the entire modelling domain in a three dimensional, sub-hourly varying time step. CALPUFF is an air dispersion model approved by NSW EPA for use in air quality impact assessments. The model setup used is in general accordance with methods provided in the NSW EPA document *Generic Guidance and Optimum Model Setting for the CALPUFF Modeling System for Inclusion into the 'Approved Methods for the Modeling and Assessments of Air Pollutants in NSW, Australia'* (TRC Environmental Corporation, 2011).

### 6.2 Modelling methodology

Modelling was undertaken using a combination of The Air Pollution Model (TAPM) and the CALPUFF Modelling System. The CALPUFF Modelling System includes three main components: CALMET, CALPUFF and CALPOST and a large set of pre-processing programs designed to interface the model to standard, routinely available meteorological and geophysical datasets.

TAPM is a prognostic air model used to simulate the upper air data for CALMET input. The meteorological component of TAPM is an incompressible, non-hydrostatic, primitive equation model with a terrain-following vertical coordinate for 3D simulations. The model predicts the flows important to local scale air pollution, such as sea breezes and terrain induced flows, against a background of larger scale meteorology provided by synoptic analysis.

CALMET is a meteorological model that uses the geophysical information and observed/simulated surface and upper air data as inputs and develops wind and temperature fields on a 3D gridded modelling domain.

CALPUFF is a transport and dispersion model that advects "puffs" of material emitted from modelled sources, simulating dispersion processes along the way. It typically uses the 3D meteorological field generated by CALMET.

CALPOST is a post processor used to process the output of the CALPUFF model and produce tabulations that summarise the results of the simulation.

#### 6.2.1 Meteorological modelling

TAPM was applied to the available data to generate a 3D upper air data file for use in CALMET. The centre of analysis for TAPM was 33.84deg south and 151.11deg east (325100mE, 6254000mN). The simulation involved an outer grid of 30km, with three nested grids of 10km, 3km and 1km with 35 vertical grid levels.

CALMET modelling used a nested approach where the 3D wind field from the coarser grid outer domain is used as the initial guess (or starting) field for the finer grid inner domain. This approach has several advantages over modelling a single domain. Observed surface wind field data from the near



field as well as from far field monitoring sites can be included in the model to generate a more representative 3D wind field for the modelled area. Off domain terrain features for the finer grid domain can be allowed to take effect within the finer domain, as would occur in reality. Also, the coarse scale wind flow fields give a better set of starting conditions with which to operate the finer grid run.

The CALMET initial domain was run on a 50 x 50km area with a 1km grid resolution and refined for a second domain on a 10 x 10km area with a 0.1km grid resolution.

The 2012 calendar year was selected as the meteorological year for the dispersion modelling based on analysis of long-term data trends in meteorological data recorded for the area. **Table 6-1** outlines the parameters used from each station.

**Table 6-1: Surface observation stations**

| Weather stations                                             | Parameters |    |    |    |   |    |     |
|--------------------------------------------------------------|------------|----|----|----|---|----|-----|
|                                                              | WS         | WD | CH | CC | T | RH | SLP |
| Sydney Olympic Park (BoM) (Station No. 66195)                | ✓          | ✓  |    |    | ✓ | ✓  |     |
| Canterbury Racecourse AWS (BoM) (Station No. 66194)          | ✓          | ✓  |    |    | ✓ | ✓  |     |
| Bankstown Airport AWS (BoM) (Station No. 66137)              | ✓          | ✓  | ✓  | ✓  | ✓ | ✓  | ✓   |
| Sydney Airport AMO (BoM) (Station No. 66037)                 | ✓          | ✓  | ✓  | ✓  | ✓ | ✓  | ✓   |
| Sydney Harbour (Wedding Cake West) (BoM) (Station No. 66196) | ✓          | ✓  |    |    | ✓ |    |     |
| Fort Denison (BoM) (Station No. 66022)                       | ✓          | ✓  |    |    |   |    |     |
| Terrey Hills AWS (BoM) (Station No. 66059)                   | ✓          | ✓  |    |    | ✓ | ✓  |     |
| Horsley Park Equestrian Centre AWS (BoM) (Station No. 67119) | ✓          | ✓  |    |    | ✓ | ✓  |     |
| Kurnell AWS (BoM) (Station No. 66043)                        | ✓          | ✓  |    |    |   |    |     |
| Little Bay (The Coast Golf Club) (BoM) (Station No. 66051)   | ✓          | ✓  |    |    |   |    |     |
| Port Botany (Molineux Point AWS) (BoM) (Station No. 66100)   | ✓          | ✓  |    |    |   |    |     |

WS = wind speed, WD = wind direction, CH = cloud height, CC = cloud cover, T = temperature, RH = relative humidity, SLP = station level pressure

Local land use and detailed topographical information was included in the simulation to produce realistic fine scale flow fields (such as terrain forced flows) in surrounding areas.

CALMET generated meteorological data were extracted from a point within the CALMET domain and are graphically represented in **Figure 6-1** and **Figure 6-2**.

**Figure 6-1** presents the annual and seasonal windroses from the CALMET data. The figure shows similar annual and seasonal windroses for the Sydney Airport AMO during the 2012 calendar period presented in **Figure 5-2**.

Overall, the windroses generated in the CALMET modelling reflect the expected wind distribution patterns of the area as determined based on the available measured data and the expected terrain effects on the prevailing winds. **Figure 6-2** includes graphs of the temperature, wind speed, mixing height and stability classification over the modelling period and show sensible trends considered to be representative of the area.



Figure 6-1: Windroses from CALMET extract at 10m height (Cell Ref 5050)




Figure 6-2: Meteorological analyses of CALMET extract (Cell Ref 5050)

## 6.2.2 Dispersion modelling

### 6.2.2.1 Odour modelling

For this assessment two scenarios were modelled, representing the existing situation and the proposed situation including the upgraded WTP.

The emission parameters for the existing scenario were approximated in consideration of the data in the latest odour assessment report prepared for the site (**Benbow Environmental, 2010**). The odour emission inventory for the existing scenario is presented in **Table 6-2**. The locations of the odour sources are presented in **Figure 6-3**.

Due to the large similarities and minor differences between the two potential designs for the upgraded WTP (Option A or B), it is anticipated that there would be minor differences between the odour impacts of the two designs at the sensitive receptors.

To be conservative, the worst-case design was modelled. This was considered to be Option A as there would be more odour sources and the significant sources would be slightly closer to the sensitive receptors compared with the Option B layout.

With the Option B design, the anaerobic tank would be closest to the sensitive receptors but would be fully sealed and thus would not have any significant emissions. With the Option A design, the aerobic tank, clarifier and sludge dewatering would be closest to the sensitive receptors. Although the emissions from the anaerobic tank would be captured and used as fuel to produce electricity, some odour emissions would pass through a biological packed bed odour control unit together with the emissions from the granular sludge tank, before they are emitted to the atmosphere.

**Table 6-3** presents the odour emission inventory of the proposed WTP. The locations of the modelled sources are shown in **Figure 6-3**. The emission parameters are either assumed or based on the indicative site plan, unless otherwise stated. The location of the sludge storage area was assumed to be next to the sludge dewatering area.

For conservatism in the assessment, all sources were assumed to emit odours continuously for 24 hours including those from the sludge dewatering and sludge storage which are planned to occur only during daytime.

Table 6-2: Odour emission inventory of the existing scenario

| Source ID            | Description                    | Easting (m) | Northing (m) | Stack height (m) | Discharge Temperature (°C) | Stack Diameter (m) | Exit Velocity (m/s) | Odour Strength at STP (OU/m³) | Odour Emission Rate (OU/s) |
|----------------------|--------------------------------|-------------|--------------|------------------|----------------------------|--------------------|---------------------|-------------------------------|----------------------------|
| Building Ventilation |                                |             |              |                  |                            |                    |                     |                               |                            |
| BV01                 | Roof Exhaust Fan No. 1         | 335834      | 6240404      | 19.5             | 30                         | 1.60               | 14.10               | 300                           | 8,109                      |
| BV02                 | Roof Exhaust Fan No. 2         | 335885      | 6240345      | 21.5             | 30                         | 1.60               | 14.10               | 300                           | 8,109                      |
| BV03                 | Roof Exhaust Fan No. 3         | 335893      | 6240337      | 21.5             | 30                         | 1.60               | 14.10               | 300                           | 8,109                      |
| BV04                 | Roof Exhaust Fan No. 4         | 335898      | 6240334      | 21.5             | 30                         | 1.60               | 14.10               | 300                           | 8,109                      |
| BV05                 | Roof Exhaust Fan No. 5         | 335957      | 6240283      | 19.5             | 30                         | 1.60               | 14.10               | 300                           | 8,109                      |
| Process Ventilation  |                                |             |              |                  |                            |                    |                     |                               |                            |
| PV01                 | Optiformer Exhaust Fan No.1    | 335915      | 6240319      | 30.5             | 40                         | 1.62               | 14.10               | 500                           | 13,520                     |
| PV02                 | Mist Collector and Vac. Fabric | 335904      | 6240329      | 30.5             | 40                         | 1.15               | 14.10               | 500                           | 6,804                      |
| PV03                 | Optiformer Exhaust Fan No.2    | 335907      | 6240336      | 30.5             | 40                         | 1.62               | 14.10               | 500                           | 13,520                     |
| PV04                 | Vacuum Blower No.1+ No. 2      | 335881      | 6240358      | 19.5             | 105.6                      | 1.50               | 14.10               | 700                           | 13,328                     |
| PV05                 | Vacuum System Fan No.1         | 335931      | 6240312      | 30.5             | 86                         | 0.57               | 14.10               | 700                           | 2,071                      |
| PV06                 | Vacuum System Fan No.2         | 335925      | 6240318      | 30.5             | 99                         | 0.38               | 14.10               | 700                           | 884                        |
| PV07                 | Vac Roll Exhaust Air No.1 Fan  | 335874      | 6240366      | 19.5             | 47.7                       | 1.34               | 14.10               | 350                           | 6,287                      |
| PV08                 | Hood Exhaust Air No.1 Fan      | 335858      | 6240381      | 19.5             | 51.4                       | 1.92               | 14.10               | 350                           | 12,843                     |
| PV09                 | Vac Roll Exhaust Air No.2 Fan  | 335843      | 6240395      | 19.5             | 51.6                       | 1.32               | 14.10               | 350                           | 6,006                      |
| PV10                 | Vac Roll Exhaust Air No.3 Fan  | 335822      | 6240415      | 19.5             | 47.7                       | 2.06               | 14.10               | 300                           | 12,770                     |
| PV11                 | Winder Pulper Exhaust Fan      | 335769      | 6240464      | 16.5             | 30                         | 0.90               | 14.10               | 500                           | 4,280                      |
| PV13                 | Vent                           | 335851      | 6240430      | 15               | 30                         | 0.11               | 2.07                | 5250                          | 77                         |
| PV14                 | Pulper Exhaust Fan             | 335986      | 6240295      | 28.5             | 30                         | 0.46               | 14.10               | 500                           | 1,126                      |

Source: Benbow Environmental (2010)



Table 6-3: Odour emission inventory of the proposed WTP

| Point source  |                      |                    |              |                      |                            |                      |                     |                               |                            |
|---------------|----------------------|--------------------|--------------|----------------------|----------------------------|----------------------|---------------------|-------------------------------|----------------------------|
| Source ID     | Description          | Easting (m)        | Northing (m) | Stack height (m)     | Discharge temperature (°C) | Stack diameter (m)   | Exit velocity (m/s) | Odour strength at STP (OU/m³) | Odour emission rate (OU/s) |
| OC            | Bioair odour control | 335928             | 6240408      | 5                    | 25                         | 0.1                  | 15 <sup>a</sup>     | 500 <sup>a</sup>              | 67 <sup>a</sup>            |
| Area source   |                      |                    |              |                      |                            |                      |                     |                               |                            |
| Source ID     | Description          | Corner easting (m) |              | Corner northing (m)  |                            | Effective height (m) | Initial sigma z (m) | Odour emission rate (OU/m²/s) |                            |
| AT            | Aeration tank        | 335985             |              | 6240466              |                            | 10                   | 2                   | 0.3 <sup>b</sup>              |                            |
|               |                      | 336001             |              | 6240451              |                            |                      |                     |                               |                            |
|               |                      | 335987             |              | 6240435              |                            |                      |                     |                               |                            |
|               |                      | 335971             |              | 6240450              |                            |                      |                     |                               |                            |
| C             | Clarifier            | 336002             |              | 6240485              |                            | 7                    | 2                   | 0.1 <sup>b</sup>              |                            |
|               |                      | 336018             |              | 6240472              |                            |                      |                     |                               |                            |
|               |                      | 336004             |              | 6240455              |                            |                      |                     |                               |                            |
|               |                      | 335988             |              | 6240469              |                            |                      |                     |                               |                            |
| Volume source |                      |                    |              |                      |                            |                      |                     |                               |                            |
| Source ID     | Description          | Easting (m)        | Northing (m) | Effective height (m) |                            | Initial sigma y (m)  | Initial sigma z (m) | Odour emission rate (OU/s)    |                            |
| SD            | Sludge dewatering    | 336003             | 6240489      | 1                    |                            | 1                    | 1                   | 500 <sup>c</sup>              |                            |
| SS            | Sludge storage       | 335998             | 6240495      | 1                    |                            | 1                    | 1                   | 200 <sup>d</sup>              |                            |

STP – standard temperature and pressure (at 0°C and 1 atm)

<sup>a</sup> The dimension of the odour control unit would be 2m x 2m x 3m. Based on a lower removal efficiency of 80% (Salmon, 2016), a minimum residence of 90 seconds (Salmon, 2016) of a biological odour control, and assuming 10% of emission from the anaerobic tank with an odour emission rate 1.5OU/m<sup>2</sup>/s (SKM, 2013), and the odour emission from the granular sludge tank at the rate of 8.41OU/m<sup>2</sup>/s (Naddeo et al, 2012), the calculated odour emission rate is 36OU/s. The maximum limit of 500OU based from the standard specification of the odour control unit of Sydney Water (2011), the odour emission rate would be 67OU/s. To be conservative, the higher odour emission rate was used in this assessment. Assuming a stack diameter of 0.1m, the calculated velocity is 17m/s. To be conservative, the minimum velocity of 15m/s as specified in Sydney Water (2011) was used.

<sup>b</sup> Source: Naddeo et al (2012)

<sup>c</sup> Source: SKM (2013)

<sup>d</sup> Based from the sludge dewatering odour emission rate (500OU/s) (SKM (2013) scaled down to emission rate for sludge storage based from Naddeo et al (2012)





**Figure 6-3: Locations of modelled emission sources**

#### 6.2.2.2 Combustion pollutant modelling

Air pollutants from the existing boiler stacks and a proposed gas engine for electricity generation were also modelled. **Figure 6-3** shows the location of these sources. There are two existing boiler stacks located next to each other. For conservatism, the proposed gas engine was assumed to be located on the eastern portion of the site closer to the sensitive receptor locations.

**Table 6-4** shows the model parameters for the existing boiler stacks and proposed gas engine. The parameters for the boiler stacks were based from the results of the stack emissions testing from 2010 to 2015. Conservative parameters were used in the model such as the lowest discharge temperature, lowest exit velocity, and highest available pollutant emission rates measured via the stack testing.

The proposed gas engine would produce approximately 1.5 megawatt (MW) of power. For conservatism, exhaust gas heat recovery was assumed which would result in a lower exhaust gas exit temperature of approximately 180°C. Although the Proponent has not decided whether to include

exhaust gas heat recovery, this assumption would represent a worst-case scenario for air quality impacts as it means the exhaust temperature is significantly lower and air dispersion is reduced.

The CO emission rate from the gas engine was assumed to be at the **POEO (Clean Air) Regulation (2010)** emission limit of 125 milligram per normal cubic metre (mg/Nm<sup>3</sup>).

The NSW EPA has a policy to minimise NO<sub>x</sub> emissions for new NO<sub>x</sub> sources (**NSW DECC, 2009**). This would require a low NO<sub>x</sub> engine with an emission limit of 250mg/Nm<sup>3</sup> for NO<sub>x</sub> commensurate with best available techniques (BAT) for the combustion of biogasses (containing some residual levels of sulfur). Therefore, in this assessment, the NO<sub>x</sub> and CO emission rates were calculated based on emission limit concentrations of 250 mg/Nm<sup>3</sup>, respectively.

The emission flowrate from the gas engine was calculated assuming;

- ✦ The biogas contains 70% methane and 30% carbon dioxide (**NPI, 2008**);
- ✦ Methane energy content of approximately 35.9 megajoule per normal cubic metre (MJ/Nm<sup>3</sup>) (**NPI, 2008**);
- ✦ Fuel energy to power rate of 10,000 kilojoule per kilowatt-hour (kJ/kWh) (**NPI, 2008**); and,
- ✦ 10% excess air, consistent with low NO<sub>x</sub> engines.

The SO<sub>2</sub> emission rate was calculated on the basis of the assumed post-scrubber H<sub>2</sub>S gas concentration of 10ppm (from the manufacturer's specification) and 100% conversion of H<sub>2</sub>S to SO<sub>2</sub>.

**Table 6-4: Model parameters for the boiler stacks and gas engine**

| Sources        | Easting (m) | Northing (m) | Stack height (m) | Discharge temperature (°C) | Stack diameter (m) | Exit velocity (m/s) | TSP (g/s) | PM <sub>10</sub> (g/s) | SO <sub>2</sub> (g/s) | NO <sub>x</sub> (g/s) | CO (g/s) |
|----------------|-------------|--------------|------------------|----------------------------|--------------------|---------------------|-----------|------------------------|-----------------------|-----------------------|----------|
| Boiler Stack 1 | 335956      | 6240417      | 43               | 120.6                      | 1.69               | 6.2                 | 0.021     | 0.015                  | -                     | 0.5                   | 1.1      |
| Boiler Stack 2 | 335969      | 6240431      | 43               | 120.6                      | 1.69               | 6.2                 |           |                        |                       |                       |          |
| Gas Engine     | 335992      | 6240514      | 6                | 180.0                      | 0.3                | 32.4                | -         | -                      | 0.039                 | 0.35                  | 0.17     |


- Not available and/or too low and was not considered in this assessment

## 7 DISPERSION MODELLING RESULTS

### 7.1 Odour

The spatial distribution of the dispersion modelling predictions for the existing and proposed scenarios is presented as isopleth diagrams showing the 99<sup>th</sup> percentile nose-response ground level odour concentrations in **Figure 7-1**.

As shown, the predicted odour impacts for the two scenarios are similar and the odour impacts from the proposed scenario would be insignificantly higher than those of the existing scenario.



**Figure 7-1: Predicted 99<sup>th</sup> percentile nose-response odour concentration (OU) for the existing and the proposed scenarios**

**Table 7-1** presents the predicted odour concentrations at each of the sensitive receptors for the existing and proposed scenarios, and the incremental change.

**Table 7-1: Predicted 99<sup>th</sup> percentile nose-response odour concentrations at the sensitive receptors (OU)**

|                    | R1   | R2   | R3   | R4   | R5   | R6   | R7   | R8   | R9   |
|--------------------|------|------|------|------|------|------|------|------|------|
| Existing scenario  | 2.91 | 2.70 | 2.40 | 3.27 | 4.32 | 3.94 | 2.86 | 3.38 | 2.77 |
| Proposed scenario  | 2.98 | 2.79 | 2.46 | 3.36 | 4.34 | 3.95 | 2.90 | 3.42 | 2.78 |
| Incremental change | 0.07 | 0.10 | 0.07 | 0.09 | 0.02 | 0.01 | 0.04 | 0.03 | 0.02 |

16020537\_OroraWTP\_AQIA\_160630.docx

The highest predicted odour concentration is 4.3OU at receptor R5 for both the existing and the proposed scenarios.

The highest change of odour levels at the sensitive receptors would up to 0.1 OU. This would not be detectable or measurable in actual practice.

## 7.2 Combustion products

The predicted maximum incremental impact (i.e. due to the operation in isolation) and cumulative impact (i.e. due to the operation and background level) at the sensitive receptors arising from the Project is presented in **Table 7-2**.

With the exception of NO<sub>2</sub>, the incremental impacts are low in comparison to the background concentrations. A total (100%) instantaneous conversion of the predicted NO<sub>x</sub> levels to NO<sub>2</sub> was assumed in the estimation of the NO<sub>2</sub> incremental impacts. Even with this conservative assumption, the predicted maximum cumulative NO<sub>2</sub> impacts, as with the other pollutant impacts, would remain below the criteria. In actual practice the impacts would be significantly less than presented.

In the absence of background or source data for some of the assessable pollutants, several conservative assumptions were necessary as follows;

- ✦ All of the PM<sub>10</sub> is comprised of PM<sub>2.5</sub>, and hence the maximum PM<sub>2.5</sub> impacts are assessed based on the maximum PM<sub>10</sub> impacts; and,
- ✦ Without background data and predictions for specific averaging periods, the required values are estimated based on the available shorter-term averaging period for SO<sub>2</sub> and CO.

Using these assumptions, the maximum cumulative impacts of all the assessed pollutants are below their relevant criteria at the sensitive receptors.

**Table 7-2: Predicted incremental impact at the sensitive receptors**

| Pollutant         | Averaging period | Unit              | Background | Maximum incremental impact at the receptors | Maximum cumulative impact at the receptors | Criterion |
|-------------------|------------------|-------------------|------------|---------------------------------------------|--------------------------------------------|-----------|
| TSP               | Annual           | µg/m <sup>3</sup> | -          | 0.02                                        | -                                          | 90        |
| PM <sub>10</sub>  | 24-hour          | µg/m <sup>3</sup> | 43.7       | 0.12                                        | 43.82                                      | 50        |
|                   | Annual           | µg/m <sup>3</sup> | 18.0       | 0.02                                        | 18.02                                      | 25        |
| PM <sub>2.5</sub> | 24-hour          | µg/m <sup>3</sup> | 20.7       | ≤0.12 <sup>a</sup>                          | ≤20.82 <sup>a</sup>                        | 25        |
|                   | Annual           | µg/m <sup>3</sup> | 5.6        | ≤0.02 <sup>a</sup>                          | ≤5.62 <sup>a</sup>                         | 8         |
| SO <sub>2</sub>   | 10-minute        | µg/m <sup>3</sup> | -          | 7.47                                        | -                                          | 712       |
|                   | 1-hour           | µg/m <sup>3</sup> | 65.8       | 5.52                                        | 71.3                                       | 570       |
|                   | 24-hour          | µg/m <sup>3</sup> | -          | 1.38                                        | <71.3 <sup>b</sup>                         | 228       |
|                   | Annual           | µg/m <sup>3</sup> | 2.86       | 0.27                                        | 3.13                                       | 60        |
| NO <sub>2</sub>   | 1-hour           | µg/m <sup>3</sup> | 84.1       | 48.5                                        | 132.6                                      | 246       |
|                   | Annual           | µg/m <sup>3</sup> | 12.3       | 2.9                                         | 15.2                                       | 62        |
| CO                | 10-minute        | mg/m <sup>3</sup> | -          | 0.044                                       | -                                          | -         |
|                   | 15-minute        | mg/m <sup>3</sup> | -          | <0.044 <sup>b</sup>                         | -                                          | 100       |
|                   | 1-hour           | mg/m <sup>3</sup> | -          | 0.032                                       | -                                          | 30        |
|                   | 8-hour           | mg/m <sup>3</sup> | 2.8        | <0.032 <sup>b</sup>                         | <2.83 <sup>b</sup>                         | 10        |

- Not available

<sup>a</sup> Estimated based from PM<sub>10</sub> results

<sup>b</sup> Estimated based from the results of a lower-averaging time of the same pollutant



## 8 DISCUSSION

It is observed that without the proposed wastewater treatment processes, the wastewater would still undergo similar processes at Sydney Water's sewage treatment facility; and without the proposed engine, electricity would still need to be purchased and thus generated by a power plant elsewhere. However there would be some energy lost through transmission, and thus more greenhouse gas and air pollution impacts due to this and also the likely production of coal-fired electricity instead of gas fired electricity.

The combination of the upgraded wastewater treatment and the treatment, recovery and combustion of the emissions, the Project would thus have a net positive air quality outcome from a total emissions perspective. The improvements would arise from:

- ✦ Reduction of methane emissions;
- ✦ Reduction of sulfur emissions in the form of H<sub>2</sub>S and SO<sub>2</sub>;
- ✦ Reduction of greenhouse gas emissions; and,
- ✦ The generation of electricity locally from biogas.

It is also noted that a low emissions engine is proposed, commensurate with best practice for the combustion of biogas. It is noted that the presence of residual levels of sulfur in the biogas poses a limit on how low the engine NO<sub>x</sub> emissions can be, in this case not above 250mg/Nm<sup>3</sup>. The presence of sulfur in the gas stream must necessarily be kept low otherwise it is costly to the operator in terms of maintenance and shortened life for an expensive asset. Thus the proponent has an inherent incentive to maintain the gas scrubbing equipment operating efficiently.

As shown in **Section 7.2**, even the highest levels of emissions from the engine would not cause any impact at the surrounding residences. As shown in **Section 7.1**, the effect of the Project on odour is unlikely to be discernible to any person off-site, and the Project has a positive effect on greenhouse gas emissions and some air emissions.

Overall, the study finds that the Project would not lead to any unacceptable level of air pollutants.



---

## 9 SUMMARY AND CONCLUSIONS

This study has examined the potential air quality impacts that may arise from the Project.

The study applies conservative calculations and assumptions which would overestimate the likely impacts for example, higher pollutant emission rates, lower stack temperature and velocity, total conversion of NO<sub>x</sub> to NO<sub>2</sub>, (amongst others).

The results indicate that the Project would lead to an insignificant change in odour concentrations and relative to the current situation, no discernible change in the levels of odour at the sensitive receptors are predicted due to the Project.

The results also show that the Project would not cause any exceedance of the air quality criteria at the sensitive receptors for all of the relevant air pollutants.

Overall, the Project would have a net positive effect on greenhouse gas emissions, and some air pollutants.

The study shows that the Project could operate either Option A or Option B without any unacceptable level of impact in the locality in regard to the applicable air quality and odour criteria.



---

## 10 REFERENCES

Benbow Environmental (2010)

"Final Odour Assessment Report for Amcor Paper Pty Ltd Matraville, NSW", Benbow Environmental for Amcor Paper, January 2010.

Bureau of Meteorology (2016a)

Climate Averages Australia, Bureau of Meteorology website, accessed 12 April 2016.  
<<http://www.bom.gov.au/climate/averages>>

Bureau of Meteorology (2016b)

La Niña – Detailed Analysis, Bureau of Meteorology website, accessed 1 May 2016.  
< <http://www.bom.gov.au/climate/enso/lnlist/>>

Department of Environment and Conservation (2005)

"Approved Methods for the Modelling and Assessment of Air Pollutants in New South Wales", Department of Environment and Conservation (NSW), August 2005

Department of Environment and Conservation (2006)

"Technical Framework – Assessment and management of odour from stationary sources in NSW", Department of Environment and Conservation (NSW), November 2006.

Katestone Scientific Pty Ltd (1995)

"The evaluation of peak-to-mean ratios for odour assessments" Volume 1 - Main Report, May 1995.

Katestone Scientific Pty Ltd (1998)

"Peak-to-Mean Concentration Ratios for Odour Assessments".

Naddeo V, Zarra T, Giuliani S & Belgiomo V (2012)

"Odour Impact Assessment in Industrial Areas", Chemical Engineering Transactions, 30, 85-90, DOI: 10.3303/CET1230015 2012.

National Environment Protection Council (2016)

"National Environment Protection (Ambient Quality) Measure", National Environment Protection Council, Canberra, February 2016.

NPI (2008)

"Emission Estimation Technique Manual for Combustion Engines", Version 3.0, National Pollutant Inventory, January 2008.

NSW DECC (2009)

"Interim DECC Nitrogen Oxide Policy for Cogeneration in Sydney and the Illawarra", Department of Environment and Climate Change NSW, February 2009

POEO (Clean Air) Regulation (2010)

Protection of the Environment Operations (Clean Air) Regulation 2010.



---

Salmon Graeme (2016)

"Odour Control Devices – Selection, Design and Application", accessed 31 May 2016  
<<http://www.ghd.com/pdf/Graeme%20Salmon%20-%20Odour%20Control%20Devices%20-%20Paper.pdf> >

Saini R, Satsangi GS & Tanjea A (2008)

"Concentrations of surface O<sub>3</sub>, NO<sub>2</sub> and CO during winter seasons at a semi-arid region – Agra, India", Indian Journal of Radio & Space Physics, Vol. 37, pp. 121-130, April 2008.

SKM (2006)

"AMCOR Botany New Paper Mill EA Air Quality Assessment", Sinclair Knight Merz, December 2006.

SKM (2013)

"Odour Impact Assessment – Rubyanna WWTP", prepared for Hunter Water Australia / Bundaberg Regional Council by Sinclair Knight Merz, March 2013.

Sydney Water (2011)

"Odour Control Unit Standard Specification", ACP0004, Sydney Water, 18 January 2011, accessed 31 May 2016.  
<[https://www.sydneywater.com.au/web/groups/publicwebcontent/documents/document/zgrf/mdq2/~edisp/dd\\_046423.pdf](https://www.sydneywater.com.au/web/groups/publicwebcontent/documents/document/zgrf/mdq2/~edisp/dd_046423.pdf) >

TRC Environmental Corporation (2011)

"Generic Guidance and Optimum Model Setting for the CALPUFF Modelling System", prepared for NSW OEH, March 2011.

---

## **Appendix A**

### ***Peak-to-mean ratios***



### **Peak-to-mean ratios**

The following table shows the recommended factors to be applied for estimating peak concentrations from different source types, stabilities and distances.

| Source Type          | Pasquill-Gifford stability class | Near field P/M 60* | Far field P/M 60* |
|----------------------|----------------------------------|--------------------|-------------------|
| Area                 | A, B, C, D                       | 2.5                | 2.5               |
|                      | E, F                             | 2.3                | 1.9               |
| Line                 | A-F                              | 6                  | 6                 |
| Surface point        | A, B, C                          | 12                 | 4                 |
|                      | D, E, F                          | 25                 | 7                 |
| Tall wake-free point | A, B, C                          | 17                 | 3                 |
|                      | D, E, F                          | 35                 | 6                 |
| Wake-affected point  | A-F                              | 2.3                | 2.3               |
| Volume               | A-F                              | 2.3                | 2.3               |

\*Ratio of peak 1-second average concentrations

