

ANNEXURE B(i)

Shoalhaven Ethanol Plant Upgrade PHA

**Response to Department of Planning Comments
Concerning Hazards**

prepared by

**GHD Pty Ltd
October 2008**



CLIENTS | PEOPLE | PERFORMANCE

9 October 2008

Cowman Stoddart Pty Ltd

Our ref: 31/21661/155044
Your ref:

Dear Steve

**Shoalhaven Ethanol Plant Upgrade PHA
Response to DoP Comments**

Please find attached the response to Sohan Fernando's comments on the QRA for the proposed Shoalhaven ethanol plant upgrade. Process description and P&ID of the mol sieve plant relevant to this project are included.

Yours Sincerely
Raj Chatiar

Senior Risk Consultant
0386878450



- 1. The Preliminary Hazard Analysis (PHA) does not appear to have considered propagation or domino effects. e.g. event E3 in table C1 is for a one hour release of vapour or jet fire. Why has the likelihood of escalation due to impacts on the nearby distillation plant items not been addressed? Please refer to clause 3.2 in the Department's Hazardous Industry Planning Advisory Paper No.6,(HIPAP6) Guidelines for Hazard Analysis.**

Incident in the distillation plant, which includes the mol sieves could affect the ethanol storage tanks and the loading area causing the escalation of event. However, the mitigation controls such as the deluge system and fire monitors/hydrants around the ethanol storage tank farm and the loading bay should minimise the impact. There is sufficient separation distance between the ethanol storage tank farm and the distillation plant. These controls are listed in Table 6-1 for the various events.

Escalation is generally not included as an initiating event in risk calculations. When compared to other initiating events (eg leaks), the probability of an event being initiated because of escalation from another event is very low. Therefore the likelihood of escalation is not likely to affect the off site risk profile, and is not included in the analysis.

A detail study titled 'PML Events Damage Contours' was completed in 2005 to assess the impact of explosion and thermal radiation from the distillation plant and ethanol storage tank farm on to the adjacent plant and equipment.

- 2. Clause 3.3.1(PHA) refers to the addition of one set(2 sieve units per set) of molecular sieves and superheater to bring the total to 4 sets. Process/plant description is required to identify the 6 vessels, 6 heat exchangers and 1 pump used under E3 in table D1. A process/plant description with P&IDs or process flow diagram should be provided to support the numbers used in table D1 for all equipment items. Please state the total sets of sieves that will be operational after this upgrade.**

- » Typically 3 mol sieves will be used but possible to use all 4 mol sieves. The QRA was completed for 4 mol sieves in operation.
- » Process description of mol sieve attached.
- » P&ID of a typical mol sieve is attached.

- 3. Does event E5 (distillation unit) in table D1 (3 vessels and 1 pump) refer to the whole distillation plant or only a part. If so explanation should be provided for the decision. The hazard ID table 6-1 refers to three distillation columns T680, T540 & T660. What will be the total number of columns after this upgrade? How many other vessels are there in the distillation plant and give reasons for only including 3 vessels in the analysis.**

Event E5 represents the equipment in the distillation section where the ethanol strength is greater than 80%, reason being that probability of ignition will be lower for dilute ethanol. The reason for including only the major equipment from the distillation section in the QRA was based on the assumption that the smaller equipment and pipes would only result in on site impact and won't be the major contributors to the off site risk due to smaller inventory involved.

There are no planned changes to the existing distillation section from this proposal.



4. **Table C2 gives the explosion consequence of 21 kPa overpressure at a distance of 53 m for the molecular sieve failure scenario. Given that 21 kPa is considered to cause failure of storage tanks, please give. Why has the distillation plant release scenario (also 10240 kg release) not been included for explosion consequences?**

Both mol sieve and distillation section are expected to generate similar overpressure consequences, due to similar inventories involved, with respect to distance to overpressure. The 21 kPa overpressure contour given in Fig C2 in Appendix C does not impact the ethanol storage tank farm or the loading bay.

5. **Table C1 does not give distances to thermal radiation levels of 23 kW/m², at which steel is considered to fail and pressure vessels need to be relieved. Please give reasons to justify why the the escalation potential was not considered, in particular for the jet fire and pool fire scenarios, eg, E1,E3,E5 etc.**

The pool fire scenario for the storage tank for 23 kW/m² thermal radiation extends 26m and does not impact on any adjacent plant that are considered hazardous. The jet fire scenario for the mol sieve and distillation section for 23 kW/m² thermal radiation does not impact the adjacent plants or extend beyond the site boundary. The 23 kW/m² thermal radiation approximately extends 45m from the source.

Table C1 in Appendix C will be updated with 23 kW/m² thermal radiation and re-issued.

Regarding not including escalation scenarios, this has been covered in the response to Question 1.

6. **Table C2 shows a confined strength of 5 for the cogen plant. The cogen plant will be inside a building (mostly for noise reduction purposes). Any mitigating measures such as blast panels etc should be discussed to justify using a confined strength of 5.**

A higher confined strength (for example using 8) still does not increase the nominated risk beyond the site boundary.

Protection measures against fire and explosion, such as blast panels etc , in the co-generation plant to be considered by Manildra in the detail design phase of the project and other safety studies (e.g. HAZOP study).



Additional Questions (e-mail 2/9/08)

- 1. Clause 3.3.3 of the PHA refers to a Cogen plant of 15 MW. However, Page 29 of the EA document refers to 40 MW. PI clarify.**

It should be 40 MW.

- 2. Hazard ID table item No.E 1 states that the actual ethanol storage is normally 50% of capacity. Please clarify if the hazard analyses for the existing plant assumed that ethanol quantity was 50% of capacity. Given the proposed increase in throughput by 2.3 times, justification is required for 50% statement.**

The hazard scenario E1 in Table 6-1 refers to current operation where the ethanol tanks are normally at 50% of capacity.

For E1 in the QRA the largest tank (capacity: 434,500 kg) is assumed to catastrophically fail and spill the content into the bund. It is assumed that 50% of the spill will flow into the underground storage tank and the remaining 50% (217,000 kg) will be involved in the fire.

- 3. Hazard ID table item E2 states that only one ethanol load pump is used at any one time. Will the one pump loadout practice be followed after the increase in throughput?**

In the modeling it is conservatively assumed that the loading pump is continuously running where as in reality it is only operating during loading. After the uprate, it will still be single pump operation but running more often compared to current operation.

- 4. Hazard ID table item E 5 refers to distillation columns T680, T 540 and T660. Please give the identifications for the existing columns and the additional column/s to be installed.**

T680, T540 and T660 are the existing vessels. There are no changes to the distillation section as part of this uprate.

- 5. The PHA shows the risk contours. Please provide an assessment to demonstrate that the impact of the proposed activity on the existing site risk levels will not significantly increase the risks from the site and that the NSW published criteria are not exceeded.**

Figure 8-1 on page 29 shows the risk profile of the existing operation and the proposed changes with respect to ethanol production, ethanol storage and gas plants. The hazardous scenario not included in the model is the explosion overpressure from the dust (flour) cloud explosion. A PHA was completed for the flour mill and the storage facility in 2007 and was assessed as unlikely to cause an off site impact from dust cloud explosion.

There is potential for escalation from the dust cloud explosion but the flour storage and other solids handling are sufficiently separated from the ethanol plant and ethanol storage area. The dust cloud explosion is not expected to increase the risk profile (specifically the individual fatality risk of 50×10^{-6} pa) beyond the site boundary.



6. Please state the surface emissive power used in the calculations for heat radiation from an ethanol fire, and the justification for using the particular value

The surface emissive power used is 170 kW/m^2 , this is the default value in SAFETI. For pool fire SAFETI uses surface emissive power specific to the material in this case this would imply that 170 kW/m^2 is specific to ethanol.

Process Description for Mol Sieve Operation

Figure 5.1 gives an overview of the existing process of dehydration of industrial grade ethanol to fuel grade ethanol. The existing molecular system is located within the distillation plant which produces industrial grade ethanol of 95%, which is sent to storage tanks for delivery. When required, 95% ethanol is taken from storage tanks back into the distillation plant for further dehydration and returned to separate storage tanks. Dehydration is achieved by passing the 95% ethanol through molecular sieves, which absorb most of the remaining water content to give 99.5% ethanol.




FIGURE 5.1
OVERVIEW OF ETHANOL DEHYDRATION PROCESS

In essence, the molecular sieve process train consists of three parts as shown in Figure 5.2: The 95% ethanol is first heated and evaporated, using steam as the heat source. It then passes through one of the two molecular sieves on line, which absorbs the water content and allows the dehydrated ethanol in vapour form to pass through. In the final part, the dehydrated ethanol vapour is condensed, cooled and pumped back to storage. Two molecular sieves work in parallel with one on line for some ten minutes while water absorbing beads in the other are being regenerated. An automatic valve change-over system cycles the two sieves. A vacuum pump system is used to extract the absorbed water from the beads in the sieves.





FIGURE 5.2
OVERVIEW OF MOLECULAR SIEVE PROCESS

Attach

Molecular Sieve Stage V Area

Stream	1	2	3	4	5	6	7	8	9	10	11	12
	Feed to Superheater	Feed to Superheater	Feed to Superheater	Feed to Superheater	Feed to Superheater	Feed to Superheater	Feed to Superheater	Feed to Superheater	Feed to Superheater	Feed to Superheater	Feed to Superheater	Feed to Superheater
Ethanol	92.0	92.0	92.0	92.0	92.0	92.0	92.0	92.0	92.0	92.0	92.0	92.0
Water	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
Flow (lb/hr) (max)	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000
Flow (lb/hr) (avg)	12,800	12,800	12,800	12,800	12,800	12,800	12,800	12,800	12,800	12,800	12,800	12,800
Flow (kg/hr) (max)	12,800	12,800	12,800	12,800	12,800	12,800	12,800	12,800	12,800	12,800	12,800	12,800
Flow (kg/hr) (avg)	10,240	10,240	10,240	10,240	10,240	10,240	10,240	10,240	10,240	10,240	10,240	10,240
Temperature (°C)	20.0	70.0	110	155	155	130	120	120	120	120	120	120
Pressure (kPa)	800	800	320	300	300	100	100	300	200	700	700	700
S.G.	0.80	0.80	0.80	0.80	0.80	0.78	0.84	N/A	N/A	N/A	N/A	N/A

- Notes:
1. All flows above are preliminary estimates
2.
3.



Tag	Description	Duty	S.G.	Make	Model	Speed	KW	Status
P703	Ethanol Feed to Stage V	20m3/hr vs 120m	0.8	Grundfos	CRN15-12	2900	11.0	New

Motor List

REV.	DESCRIPTION	DATE	BY	CHKD.	APPD.	REV.	DESCRIPTION	DATE	BY	CHKD.	APPD.
0	Preliminary	Feb/07				5	Steam bypasses added	May/07			
1	General updates	Feb/07									
2	Updated - Pre-Heater Preheater	Mar/07									
3	Updated - Line and valve numbers added	Mar/07									
4	Updated - Line and valve numbers added	Mar/07									

CLIENT: MANILDRA


TITLE: Stage V Molecular Sieve Sheet 1

DWG. NO. REF. NO. C323 REV. NO.

Molecular Sieve Stage VII Area

Stream	1	2	3	4	5	6	7	8	9	10	11	12
Ethanol	92.0	92.0	92.0	92.0	92.0	92.0	92.0	92.0	92.0	92.0	92.0	92.0
Water	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0
Flow lph (max) (as liquid)	28,000	28,000	28,000	28,000	28,000	28,000	28,000	28,000	28,000	28,000	28,000	28,000
Flow lph (ave) (as liquid)	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500
Flow kg/hr (max)	22,500	22,500	22,500	22,500	22,500	22,500	22,500	22,500	22,500	22,500	22,500	22,500
Flow kg/hr (ave)	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000
Temperature °C	20-35	100	115	155	130	120	120	120	120	120	120	120
Pressure kPa	800	800	320	300	100	100	300	200	700	700	700	700
S.G. (as liquid)	0.81	0.81	0.80	0.80	0.84	0.84	N/A	N/A	N/A	N/A	N/A	N/A

Notes:
1. All flows above are preliminary estimates
2.
3.



Tag	Description	Duty	S.G.	Make	Model	Speed	kW	Status
P404	Ethanol Feed to Stage VII	10m3/hr vs 100m	0.8	Gundlach	CRV15-12	2500	7.5	OK
P703a	Ethanol Feed to Stage VII	20m3/hr vs 120m	0.8	Gundlach	CRV15-12	2500	11.0	OK
P703b	Ethanol Feed to Stage VII	20m3/hr vs 120m	0.8	Gundlach	CRV15-12	2500	11.0	New

REV.	DESCRIPTION	REV.	DESCRIPTION
0	Preliminary		
1	Updated		
2	Updated line and valve numbers		

0 Preliminary

1 Updated

2 Updated line and valve numbers

REV.

DESCRIPTION

0 Preliminary

1 Updated

2 Updated line and valve numbers

REV.

DESCRIPTION

THIS DRAWING IS OWNED BY SCIENTIFIC DESIGN PTY. LTD. AND IS ISSUED ON THE UNDERSTANDING THAT IT WILL NOT BE REPRODUCED OR COPIED IN WHOLE OR IN PART WITHOUT THE WRITTEN PERMISSION OF SCIENTIFIC DESIGN PTY. LTD. FROM IT WHICH WILL BE INADVISABLE TO THE ABOVE COMPANY

CLIENT: MANILDRA

TITLE: Ethanol Stages VII/II
Molecular Sieve Area

DWG. NO. C423
REV. NO.

28-Jun-08

Sheet 3 of 5



CLIENTS | PEOPLE | PERFORMANCE

9 October 2008

Cowman Stoddart Pty Ltd

Our ref: 31/21661/155044
Your ref:

Dear Steve

**Shoalhaven Ethanol Plant Upgrade PHA
Response to DoP Comments**

Please find attached the response to Sohan Fernando's comments on the QRA for the proposed Shoalhaven ethanol plant upgrade. Process description and P&ID of the mol sieve plant relevant to this project are included.

Yours Sincerely
Raj Chatiar

Senior Risk Consultant
0386878450



- 1. The Preliminary Hazard Analysis (PHA) does not appear to have considered propagation or domino effects. e.g. event E3 in table C1 is for a one hour release of vapour or jet fire. Why has the likelihood of escalation due to impacts on the nearby distillation plant items not been addressed? Please refer to clause 3.2 in the Department's Hazardous Industry Planning Advisory Paper No.6,(HIPAP6) Guidelines for Hazard Analysis.**

Incident in the distillation plant, which includes the mol sieves could affect the ethanol storage tanks and the loading area causing the escalation of event. However, the mitigation controls such as the deluge system and fire monitors/hydrants around the ethanol storage tank farm and the loading bay should minimise the impact. There is sufficient separation distance between the ethanol storage tank farm and the distillation plant. These controls are listed in Table 6-1 for the various events.

Escalation is generally not included as an initiating event in risk calculations. When compared to other initiating events (eg leaks), the probability of an event being initiated because of escalation from another event is very low. Therefore the likelihood of escalation is not likely to affect the off site risk profile, and is not included in the analysis.

A detail study titled 'PML Events Damage Contours' was completed in 2005 to assess the impact of explosion and thermal radiation from the distillation plant and ethanol storage tank farm on to the adjacent plant and equipment.

- 2. Clause 3.3.1(PHA) refers to the addition of one set(2 sieve units per set) of molecular sieves and superheater to bring the total to 4 sets. Process/plant description is required to identify the 6 vessels, 6 heat exchangers and 1 pump used under E3 in table D1. A process/plant description with P&IDs or process flow diagram should be provided to support the numbers used in table D1 for all equipment items. Please state the total sets of sieves that will be operational after this upgrade.**

- » Typically 3 mol sieves will be used but possible to use all 4 mol sieves. The QRA was completed for 4 mol sieves in operation.
- » Process description of mol sieve attached.
- » P&ID of a typical mol sieve is attached.

- 3. Does event E5 (distillation unit) in table D1 (3 vessels and 1 pump) refer to the whole distillation plant or only a part. If so explanation should be provided for the decision. The hazard ID table 6-1 refers to three distillation columns T680, T540 & T660. What will be the total number of columns after this upgrade? How many other vessels are there in the distillation plant and give reasons for only including 3 vessels in the analysis.**

Event E5 represents the equipment in the distillation section where the ethanol strength is greater than 80%, reason being that probability of ignition will be lower for dilute ethanol. The reason for including only the major equipment from the distillation section in the QRA was based on the assumption that the smaller equipment and pipes would only result in on site impact and won't be the major contributors to the off site risk due to smaller inventory involved.

There are no planned changes to the existing distillation section from this proposal.



4. **Table C2 gives the explosion consequence of 21 kPa overpressure at a distance of 53 m for the molecular sieve failure scenario. Given that 21 kPa is considered to cause failure of storage tanks, please give. Why has the distillation plant release scenario (also 10240 kg release) not been included for explosion consequences?**

Both mol sieve and distillation section are expected to generate similar overpressure consequences, due to similar inventories involved, with respect to distance to overpressure. The 21 kPa overpressure contour given in Fig C2 in Appendix C does not impact the ethanol storage tank farm or the loading bay.

5. **Table C1 does not give distances to thermal radiation levels of 23 kW/m², at which steel is considered to fail and pressure vessels need to be relieved. Please give reasons to justify why the the escalation potential was not considered, in particular for the jet fire and pool fire scenarios, eg, E1,E3,E5 etc.**

The pool fire scenario for the storage tank for 23 kW/m² thermal radiation extends 26m and does not impact on any adjacent plant that are considered hazardous. The jet fire scenario for the mol sieve and distillation section for 23 kW/m² thermal radiation does not impact the adjacent plants or extend beyond the site boundary. The 23 kW/m² thermal radiation approximately extends 45m from the source.

Table C1 in Appendix C will be updated with 23 kW/m² thermal radiation and re-issued.

Regarding not including escalation scenarios, this has been covered in the response to Question 1.

6. **Table C2 shows a confined strength of 5 for the cogen plant. The cogen plant will be inside a building (mostly for noise reduction purposes). Any mitigating measures such as blast panels etc should be discussed to justify using a confined strength of 5.**

A higher confined strength (for example using 8) still does not increase the nominated risk beyond the site boundary.

Protection measures against fire and explosion, such as blast panels etc , in the co-generation plant to be considered by Manildra in the detail design phase of the project and other safety studies (e.g. HAZOP study).



Additional Questions (e-mail 2/9/08)

- 1. Clause 3.3.3 of the PHA refers to a Cogen plant of 15 MW. However, Page 29 of the EA document refers to 40 MW. PI clarify.**

It should be 40 MW.

- 2. Hazard ID table item No.E 1 states that the actual ethanol storage is normally 50% of capacity. Please clarify if the hazard analyses for the existing plant assumed that ethanol quantity was 50% of capacity. Given the proposed increase in throughput by 2.3 times, justification is required for 50% statement.**

The hazard scenario E1 in Table 6-1 refers to current operation where the ethanol tanks are normally at 50% of capacity.

For E1 in the QRA the largest tank (capacity: 434,500 kg) is assumed to catastrophically fail and spill the content into the bund. It is assumed that 50% of the spill will flow into the underground storage tank and the remaining 50% (217,000 kg) will be involved in the fire.

- 3. Hazard ID table item E2 states that only one ethanol load pump is used at any one time. Will the one pump loadout practice be followed after the increase in throughput?**

In the modeling it is conservatively assumed that the loading pump is continuously running where as in reality it is only operating during loading. After the uprate, it will still be single pump operation but running more often compared to current operation.

- 4. Hazard ID table item E 5 refers to distillation columns T680, T 540 and T660. Please give the identifications for the existing columns and the additional column/s to be installed.**

T680, T540 and T660 are the existing vessels. There are no changes to the distillation section as part of this uprate.

- 5. The PHA shows the risk contours. Please provide an assessment to demonstrate that the impact of the proposed activity on the existing site risk levels will not significantly increase the risks from the site and that the NSW published criteria are not exceeded.**

Figure 8-1 on page 29 shows the risk profile of the existing operation and the proposed changes with respect to ethanol production, ethanol storage and gas plants. The hazardous scenario not included in the model is the explosion overpressure from the dust (flour) cloud explosion. A PHA was completed for the flour mill and the storage facility in 2007 and was assessed as unlikely to cause an off site impact from dust cloud explosion.

There is potential for escalation from the dust cloud explosion but the flour storage and other solids handling are sufficiently separated from the ethanol plant and ethanol storage area. The dust cloud explosion is not expected to increase the risk profile (specifically the individual fatality risk of 50×10^{-6} pa) beyond the site boundary.



6. Please state the surface emissive power used in the calculations for heat radiation from an ethanol fire, and the justification for using the particular value

The surface emissive power used is 170 kW/m^2 , this is the default value in SAFETI. For pool fire SAFETI uses surface emissive power specific to the material in this case this would imply that 170 kW/m^2 is specific to ethanol.

Process Description for Mol Sieve Operation

Figure 5.1 gives an overview of the existing process of dehydration of industrial grade ethanol to fuel grade ethanol. The existing molecular system is located within the distillation plant which produces industrial grade ethanol of 95%, which is sent to storage tanks for delivery. When required, 95% ethanol is taken from storage tanks back into the distillation plant for further dehydration and returned to separate storage tanks. Dehydration is achieved by passing the 95% ethanol through molecular sieves, which absorb most of the remaining water content to give 99.5% ethanol.




FIGURE 5.1
OVERVIEW OF ETHANOL DEHYDRATION PROCESS

In essence, the molecular sieve process train consists of three parts as shown in Figure 5.2: The 95% ethanol is first heated and evaporated, using steam as the heat source. It then passes through one of the two molecular sieves on line, which absorbs the water content and allows the dehydrated ethanol in vapour form to pass through. In the final part, the dehydrated ethanol vapour is condensed, cooled and pumped back to storage. Two molecular sieves work in parallel with one on line for some ten minutes while water absorbing beads in the other are being regenerated. An automatic valve change-over system cycles the two sieves. A vacuum pump system is used to extract the absorbed water from the beads in the sieves.




FIGURE 5.2
OVERVIEW OF MOLECULAR SIEVE PROCESS


Attach

Molecular Sieve Stage V Area

Stream	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	127	128	129	130	131	132	133	134	135	136	137	138	139	140	141	142	143	144	145	146	147	148	149	150	151	152	153	154	155	156	157	158	159	160	161	162	163	164	165	166	167	168	169	170	171	172	173	174	175	176	177	178	179	180	181	182	183	184	185	186	187	188	189	190	191	192	193	194	195	196	197	198	199	200	201	202	203	204	205	206	207	208	209	210	211	212	213	214	215	216	217	218	219	220	221	222	223	224	225	226	227	228	229	230	231	232	233	234	235	236	237	238	239	240	241	242	243	244	245	246	247	248	249	250	251	252	253	254	255	256	257	258	259	260	261	262	263	264	265	266	267	268	269	270	271	272	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287	288	289	290	291	292	293	294	295	296	297	298	299	300	301	302	303	304	305	306	307	308	309	310	311	312	313	314	315	316	317	318	319	320	321	322	323	324	325	326	327	328	329	330	331	332	333	334	335	336	337	338	339	340	341	342	343	344	345	346	347	348	349	350	351	352	353	354	355	356	357	358	359	360	361	362	363	364	365	366	367	368	369	370	371	372	373	374	375	376	377	378	379	380	381	382	383	384	385	386	387	388	389	390	391	392	393	394	395	396	397	398	399	400	401	402	403	404	405	406	407	408	409	410	411	412	413	414	415	416	417	418	419	420	421	422	423	424	425	426	427	428	429	430	431	432	433	434	435	436	437	438	439	440	441	442	443	444	445	446	447	448	449	450	451	452	453	454	455	456	457	458	459	460	461	462	463	464	465	466	467	468	469	470	471	472	473	474	475	476	477	478	479	480	481	482	483	484	485	486	487	488	489	490	491	492	493	494	495	496	497	498	499	500	501	502	503	504	505	506	507	508	509	510	511	512	513	514	515	516	517	518	519	520	521	522	523	524	525	526	527	528	529	530	531	532	533	534	535	536	537	538	539	540	541	542	543	544	545	546	547	548	549	550	551	552	553	554	555	556	557	558	559	560	561	562	563	564	565	566	567	568	569	570	571	572	573	574	575	576	577	578	579	580	581	582	583	584	585	586	587	588	589	590	591	592	593	594	595	596	597	598	599	600	601	602	603	604	605	606	607	608	609	610	611	612	613	614	615	616	617	618	619	620	621	622	623	624	625	626	627	628	629	630	631	632	633	634	635	636	637	638	639	640	641	642	643	644	645	646	647	648	649	650	651	652	653	654	655	656	657	658	659	660	661	662	663	664	665	666	667	668	669	670	671	672	673	674	675	676	677	678	679	680	681	682	683	684	685	686	687	688	689	690	691	692	693	694	695	696	697	698	699	700	701	702	703	704	705	706	707	708	709	710	711	712	713	714	715	716	717	718	719	720	721	722	723	724	725	726	727	728	729	730	731	732	733	734	735	736	737	738	739	740	741	742	743	744	745	746	747	748	749	750	751	752	753	754	755	756	757	758	759	760	761	762	763	764	765	766	767	768	769	770	771	772	773	774	775	776	777	778	779	780	781	782	783	784	785	786	787	788	789	790	791	792	793	794	795	796	797	798	799	800	801	802	803	804	805	806	807	808	809	810	811	812	813	814	815	816	817	818	819	820	821	822	823	824	825	826	827	828	829	830	831	832	833	834	835	836	837	838	839	840	841	842	843	844	845	846	847	848	849	850	851	852	853	854	855	856	857	858	859	860	861	862	863	864	865	866	867	868	869	870	871	872	873	874	875	876	877	878	879	880	881	882	883	884	885	886	887	888	889	890	891	892	893	894	895	896	897	898	899	900	901	902	903	904	905	906	907	908	909	910	911	912	913	914	915	916	917	918	919	920	921	922	923	924	925	926	927	928	929	930	931	932	933	934	935	936	937	938	939	940	941	942	943	944	945	946	947	948	949	950	951	952	953	954	955	956	957	958	959	960	961	962	963	964	965	966	967	968	969	970	971	972	973	974	975	976	977	978	979	980	981	982	983	984	985	986	987	988	989	990	991	992	993	994	995	996	997	998	999	1000	1001	1002	1003	1004	1005	1006	1007	1008	1009	1010	1011	1012	1013	1014	1015	1016	1017	1018	1019	1020	1021	1022	1023	1024	1025	1026	1027	1028	1029	1030	1031	1032	1033	1034	1035	1036	1037	1038	1039	1040	1041	1042	1043	1044	1045	1046	1047	1048	1049	1050	1051	1052	1053	1054	1055	1056	1057	1058	1059	1060	1061	1062	1063	1064	1065	1066	1067	1068	1069	1070	1071	1072	1073	1074	1075	1076	1077	1078	1079	1080	1081	1082	1083	1084	1085	1086	1087	1088	1089	1090	1091	1092	1093	1094	1095	1096	1097	1098	1099	1100	1101	1102	1103	1104	1105	1106	1107	1108	1109	1110	1111	1112	1113	1114	1115	1116	1117	1118	1119	1120	1121	1122	1123	1124	1125	1126	1127	1128	1129	1130	1131	1132	1133	1134	1135	1136	1137	1138	1139	1140	1141	1142	1143	1144	1145	1146	1147	1148	1149	1150	1151	1152	1153	1154	1155	1156	1157	1158	1159	1160	1161	1162	1163	1164	1165	1166	1167	1168	1169	1170	1171	1172	1173	1174	1175	1176	1177	1178	1179	1180	1181	1182	1183	1184	1185	1186	1187	1188	1189	1190	1191	1192	1193	1194	1195	1196	1197	1198	1199	1200	1201	1202	1203	1204	1205	1206	1207	1208	1209	1210	1211	1212	1213	1214	1215	1216	1217	1218	1219	1220	1221	1222	1223	1224	1225	1226	1227	1228	1229	1230	1231	1232	1233	1234	1235	1236	1237	1238	1239	1240	1241	1242	1243	1244	1245	1246	1247	1248	1249	1250	1251	1252	1253	1254	1255	1256	1257	1258	1259	1260	1261	1262	1263	1264	1265	1266	1267	1268	1269	1270	1271	1272	1273	1274	1275	1276	1277	1278	1279	1280	1281	1282	1283	1284	1285	1286	1287	1288	1289	1290	1291	1292	1293	1294	1295	1296	1297	1298	1299	1300	1301	1302	1303	1304	1305	1306	1307	1308	1309	1310	1311	1312	1313	1314	1315	1316	1317	1318	1319	1320	1321	1322	1323	1324	1325	1326	1327	1328	1329	1330	1331	1332	1333	1334	1335	1336	1337	1338	1339	1340	1341	1342	1343	1344	1345	1346	1347	1348	1349	1350	1351	1352	1353	1354	1355	1356	1357	1358	1359	1360	1361	1362	1363	1364	1365	1366	1367	1368	1369	1370	1371	1372	1373	1374	1375	1376	1377	1378	1379	1380	1381	1382	1383	1384	1385	1386	1387	1388	1389	1390	1391	1392	1393	1394	1395	1396	1397	1398	1399	1400	1401	1402	1403	1404	1405	1406	1407	1408	1409	1410	1411	1412	1413	1414	1415	1416	1417	1418	1419	1420	1421	1422	1423	1424	1425	1426	1427	1428	1429	1430	1431	1432	1433	1434	1435	1436	1437	1438	1439	1440	1441	1442	1443	1444	1445	1446	1447	1448	1449	1450	1451	1452	1453	1454	1455	1456	1457	1458	1459	1460	1461	1462	1463	1464	1465	1466	1467	1468	1469	1470	1471	1472	1473	1474	1475	1476	1477	1478	1479	1480	1481	1482	1483	1484	1485	1486	1487
--------	---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------

Stream	1	2	3	4	5	6	7	8	9	10	11	12
	Feed from Preheated Feedwater	Feed from Preheated Feedwater	Steam	Feed w/1. Preheated	Feed w/2. Preheated	Water w/1. Reheat Steam	Reheat Steam	Steam Preheated	Steam to Preheated Preheated	Condensate Preheated	Steam to Preheated Preheated	Condensate Preheated
Ethanol %w/w	92.0	92.0	-	92.0	92.0	99.7	0.0	30.0	-	0.0	0.0	0.0
Water %w/w	8.0	8.0	-	8.0	8.0	0.0	70.0	-	100.0	100.0	100.0	100.0
Flow b1 (max) (as liquid)	28,000	28,000	-	28,000	28,000	20,600	7,400	-	-	-	-	-
Flow b1 (ave) (as liquid)	25,000	25,500	-	25,000	25,500	18,392	6,608	-	-	-	-	-
Flow k1 (max)	22,500	22,500	-	22,500	22,500	16,068	6,216	-	2,900	2,900	9,500	9,500
Flow k1 (ave)	20,000	20,000	-	20,000	20,000	14,346	5,900	-	2,590	2,590	8,484	8,484
Temperature °C	20-35	100	-	115	155	155	130	-	120	120	165	165
Pressure kPa	800-1	800	-	320	300	100	100	-	300	200	700	700
S.G. (as liquid)	0.81	0.81	-	0.80	-	0.78	0.84	-	N/A	N/A	N/A	N/A

Notes:
1. All flows above are preliminary estimates
2.
3.



Motor List	Tag	Description	Duty	S.G.	Make	Model	Speed	kW	Status
P504		Ethanol Feed to Stage IV	16m3/hr vs 100m	0.8	Grundfos	CRNXXX	2900	7.5	OK
P703a		Ethanol Feed to Stage V/I	20m3/hr vs 120m	0.8	Grundfos	CRN15-12	2900	11.0	OK
P703b		Ethanol Feed to Stage V/I	20m3/hr vs 120m	0.8	Grundfos	CRN15-12	2900	11.0	OK

THIS DRAWING IS OWNED BY SCIENTIFIC DESIGN PTY. LTD.
IT IS ISSUED ON THE UNDERSTANDING THAT IT WILL NOT BE
REPRODUCED OR COPIED IN WHOLE OR IN PART WITHOUT
WRITTEN PERMISSION, NOR IS INFORMATION TO BE FURNISHED
FROM IT WHICH WILL BE INJURIOUS TO THE ABOVE COMPANY

TITLE: Ethanol Stages VI/VII
Molecular Sieve Area

DWG. NO.

REV. NO.

Sheet 3 of 5

REV.	DESCRIPTION
------	-------------

ANNEXURE B(ii)

Revised Preliminary Hazard Analysis

prepared by

**GHD Pty Ltd
October 2008**

ANNEXURE B(ii)



CLIENTS | PEOPLE | PERFORMANCE

Shoalhaven Starches
Ethanol Production Upgrade
Preliminary Hazard Analysis
October 2008

Contents

1.	Executive Summary	6
2.	Introduction	9
2.1	Background	9
2.2	Aims and Objectives	9
3.	Facility Description	10
3.1	Site Location	10
3.2	Site Layout	10
3.3	Existing Operation	11
3.4	Previous Studies	12
4.	Statutory Requirement	13
5.	Methodology	14
5.1	General	14
5.2	Preliminary Risk Screening	14
5.3	Hazard Identification	14
5.4	QRA Methodology	15
6.	Hazard Identification	18
6.1	Hazardous Materials	18
6.2	Hazardous Scenarios	25
7.	Study Assumptions	27
8.	Results and Discussions	28
8.1	Frequency Analysis	28
8.2	Consequence Modelling	28
8.3	Risk Assessment	28
9.	Recommendations	31
10.	Conclusion	32
11.	References	33

Table Index

Table 3–1 Previous Relevant Hazard Studies	12
Table 5–1 Individual Fatality Risk Level Criteria	17
Table 6–1 Hazard Identification	19

Figure Index

Figure 1-1 Individual Fatality Risk Profile for the Shoalhaven Operation	7
Figure 3-1 Site Layout	10
Figure 5-1 The QRA Process	15
Figure 8-1 Individual Fatality Risk	29

Appendices

- A. Background Data
- B. Consequence Models
- C. Consequence Results
- D. Frequency Analysis

GLOSSARY

DUAP – Department of Urban Affairs and Planning;

DoP – Department of Planning;

EPA – Environment Protection Authority;

SEPP – State Environmental Planning Policy;

PHA – Preliminary Hazard Assessment;

QRA – Quantitative Risk Assessment;

HIPAP – Hazardous Industry Planning Advisory Paper;

SAFETI – Software for Assessment of Fire Explosion and Toxic Impact;

IRPA – Individual Risk Per Annum;

ESD – Emergency Shutdown Device;

EA – Environmental Assessment.

DISCLAIMER

This report has been prepared at the request of Shoalhaven Starches Pty Ltd and is for the sole purpose of evaluating the risks associated with the proposed ethanol upgrade at Shoalhaven Starches Bomaderry plant.

This report is not for use by any related or third party or for any other project. The information and recommendations are to be read and considered as a whole and the content is not to be used selectively as this may misrepresent the content of the report and provide erroneous project or decision outcomes.

The recommendation, opinions, assessments, analyses and summaries presented in this report are based exclusively on information, data, assumptions and advice provided and verified by Shoalhaven Starches Pty Ltd. This information has not been independently verified by GHD Pty Ltd, and where assumptions are identified and recommendations made these need to be verified and tested.

As GHD has been unable to independently verify the input information, data, assumptions and advice provided by Shoalhaven Starches Pty Ltd, GHD does not represent, warrant or guarantee the assessment provided in this report.

This Report must not be copied without the prior permission of GHD.

1. Executive Summary

Introduction

Shoalhaven Starches, part of the Manildra Group, is proposing to increase the ethanol production capacity at their Shoalhaven plant from 126 million litres (ML) per year to 300 ML per year by upgrading the facility.

A Preliminary Hazard Assessment (PHA) for the proposed upgrade was prepared as part of the planning approval process required by the NSW Department of Planning (DoP).

Manildra Group commissioned GHD to complete the PHA for the proposed upgrade of the Ethanol Facility at the Shoalhaven site. The PHA was completed in accordance with the screening criteria detailed in the State Environmental Planning Policy (SEPP) 33 guideline of the then Department of Urban Affairs and Planning (DUAP), now the DoP. The Hazard Assessment was completed in accordance to Hazardous Industry Planning Advisory Paper (HIPAP) No 6.

The major hazards identified in the PHA were included in the Quantitative Risk Assessment (QRA), which was completed using SAFETI (Software for the Assessment of Fire, Explosion, Toxic Impact) and the risk criteria given in HIPAP No 4 for off site impact.

The QRA included the existing operation and the new hazards introduced by the proposed upgrade.

Hazard identification

The major hazards, introduced by the proposed upgrade, that have potential for off site impact are:

- » Cogeneration Plant: Potential for fire and explosion associated with natural gas;
- » Ethanol Loading Bay: Increased loading frequency associated with increased ethanol production leading to increased likelihood of release of ethanol due to human factors or mechanical failures;
- » Gas Fire Boiler (150 tph steam).

The existing major hazards, included in the QRA, that have potential for off site risk are:

- » Ethanol Storage Tank Farm: the storage capacity will not change;
- » Ethanol Loading Pump: will operate more frequently;
- » Distillation Units;
- » Molecular Sieves;
- » Gas Fired Boiler No 2.

The dust cloud explosion hazards are not included in this QRA. A separate risk assessment was completed for the dust cloud explosion during an earlier plant upgrade last year and was demonstrated not to have off site impact.

Frequency Analysis

The failure frequencies of equipment were calculated using failure rate data obtained from the UK Health and Safety Executive (HSE) for pipes and equipment. The UK HSE data is derived from off shore operations in a harsh environment and hence is considered to be conservative when applied to a clean on shore process.

Consequence Assessment

Thermal radiation with respect to fire, and overpressure with respect to explosion, associated with ethanol and natural gas were assessed.


The ethanol fire was modelled as a pool fire and natural gas fire was modelled as a jet fire. Overpressure was modelled as a vapour cloud explosion with respect to ethanol vapour and natural gas.

Risk Assessment

The failure frequencies and consequences were combined in SAFETI to calculate the risk contours for the Shoalhaven facility.

Individual Fatality Risk contours were calculated and overlaid on the map of the Shoalhaven facility to show the impact zone. The Individual Risk results for the nominated risk criteria of HIPAP No 4 are given below.

Figure 1-1 Individual Fatality Risk Profile for the Shoalhaven Operation



The risk calculated for the existing operation and the proposed upgrade of the Shoalhaven facility is acceptable as the risk contours are in compliance with the nominated risk criteria of HIPAP No 4. There are no sensitive areas nearby the site affected by the operation.

There is no injury risk to the residential area from thermal radiation or explosion overpressure. Thermal radiation and explosion overpressure from the ethanol facility does not cause off site property damage.

2. Introduction

2.1 Background

The Manildra Group owns and operates the Shoalhaven Starches Factory located on Bolong Road at Bomaderry. The factory produces a range of products and ethanol is one of them. Currently, the factory has capacity to produce 126 ML of ethanol annually. The ethanol produced at the site is transported to the customers by road tankers.

Manildra Group envisages an increase in demand for ethanol in the near future due to NSW government's plans to increase ethanol blending in the petrol from the current levels of 2% to 10% by 2011. In anticipation of increased ethanol demand, the Manildra Group is planning to increase the production capacity of ethanol to 300 ML per annum by implementing a number of changes to its Shoalhaven Factory.

The Shoalhaven plant currently uses coal in the boilers for steam generation but is moving towards natural gas for steam generation in order to reduce the greenhouse gas emission. A coal-fired boiler (No 2) has already been converted to gas-fired boiler. Further, the Manildra Group is considering installation of a gas fired cogeneration plant at the Shoalhaven site to further reduce the greenhouse gas emission and optimise energy consumption in the production facility.

The increase in ethanol production capacity and gas usage on site will change the risk profile of the site with respect to off site risk.

The Manildra Group commissioned GHD to complete the PHA of the Shoalhaven site as part of the EA (Environmental Assessment) process to demonstrate that the off site risk from the proposed increase in ethanol production remains acceptable.

2.2 Aims and Objectives

The aim of the PHA is to assess the total off site risk, generated from the existing operation at Shoalhaven Factory and from the proposed upgrade of the facility, with respect to harm to people and damage to properties.

The objectives of the PHA are:

- » Identify all hazards from existing operation and from the proposed changes that have the potential for off site impact;
- » Assess and quantify the off-site risks to people, property and the environment;
- » Compare the risks generated with the nominated risk criteria of NSW Hazardous Industry Planning Advisory Paper (HIPAP) No. 4;
- » Identify risk reduction or mitigation measures as required;
- » Prepare a concise and clear report of the risk assessment and the results.

An increase in ethanol production capacity will result in increased truck movement to and from the site hence higher likelihood of traffic related incidents on the road i.e. collision and loss of containment. Transportation risk assessment is not included in this study.

3.3 Existing Operation

The raw materials used in the process are grain, flour and wheat transported to the site by road and rail. The existing plants and operating units on the site are:

- » Starch Plant;
- » Grain Plant;
- » Flour Mill;
- » Fermentation;
- » Evaporation;
- » Ethanol Plant and Storage Facility;
- » Ethanol Loading Bay;
- » Drying;
- » Coal fired steam boilers.

The proposed upgrades that have potential to contribute to off site impact are listed below:

3.3.1 Ethanol Plant

The waste from the starch, gluten and syrups components feed the fermentation units, which produces ethanol. The ethanol is separated from 'beer' and water in the separation columns and molecular sieves to provide pure ethanol ready for sale. Ethanol so produced is pumped to storage tanks ready for loading and despatch by road tanker.

There are 7 storage tanks with the combined capacity to store 1.9 ML. Normally only half of the 7 tanks are full. The tanks are inside a bund. Any spill in the bund is pumped away to the underground recovery tank. There is a level alarm in the bund sump if the sump pump fails. There is a flow sensor in the discharge line from the sump to the recovery tank to alert the operators of spills in the bund.

The ethanol production unit and storage capacity will remain unchanged by the proposed upgrade.

A new set of molecular sieves and superheater are planned to be added in the future. This will bring the total molecular sieves to 4 sets.

3.3.2 Ethanol Loading Bay

The loading bay is located approx 20m from the storage tank farm. Ethanol is loaded into the B-Double road tanker or Single Road tanker and transported to the customer. The capacity of the tankers is:

- » B-Double: 50,000L and
- » Single: 34,000L

Typically, 6 B-Double and 1 Single tanker are loaded per day but this will more than double with the proposed doubling in the ethanol production rate. At 300 ML/year production capacity, the loading frequency is expected to be:

- » 14 B-Double tankers per day; and
- » 4 Single tankers per day.

Loading is by done by the tanker driver. Only a single tanker is loaded at a time. The loading bay has 2 drain points to allow any spillage to flow to an underground recovery tank.

The loading hose is steel braided. There is an excess flow valve on the liquid loading line to stop flow if the hose fails catastrophically or disconnects.

3.3.3 Co Generation Plant

A gas fired co-generation plant (40 MW) is proposed to be installed on the north west end of the site.

3.3.4 Gas Fired Boiler

Manildra is planning to move away from the coal fired boilers to gas fired boilers to generate steam in order to improve its performance against the green house gas release.

Therefore, a 150 tph gas fired boiler is proposed to be installed at the Shoalhaven site.

3.4 Previous Studies

A number of risk assessments have been completed for the Shoalhaven site in the past associated with plant upgrades. Some of the recent studies are listed below.

Table 3–1 Previous Relevant Hazard Studies

Study	Authors & Date	Purpose of the Study
PHA of Sorghum Plant	Ren Mahant, Bechtel Services Australia, Nov 2000	Hazard analysis of grain plant
PHA of Protein Isolate Plant	Ren Mahant, Bechtel Services Australia, Nov 2000	Hazard analysis of DDG Dryer
Hazard Analysis of Stillage Production Facility	Ren Mahant, Bechtel Services Australia, July 2002	Includes hazard analysis of Molecular Sieves.
PML Damage Contours	Matrix Risk Pty Ltd. Feb 2005	Consequence analysis of fire and explosion associated with ethanol production, storage and loading bay.
PHA of Proposed flour Mill Upgrade	Rebecca Freeman, GHD, May 2007.	Hazard analysis associated with the installation of Short Flour Mill.

4. Statutory Requirement

The current structure for project assessment is established by the *Environmental Planning and Assessment Act 1979* (the EP&A Act). This project is considered to be a major project under Part 3a of the EP&A Act, and therefore an Environmental Assessment (EA) is required to accompany the development application.

The Director-General's Requirements for the EA require a PHA as per *State Environmental Planning Policy No.33 – Hazardous and Offensive Development* (SEPP 33)[1]. A PHA broadly examines the likely potential hazards that may occur as a result of a hazardous or offensive development.

SEPP 33 requires developments that are potentially hazardous to be the subject of a PHA to determine the risk to people, property and the environment at the proposed location and in the presence of controls. Should such risk exceed the criteria of acceptability, the development is classified as 'hazardous industry' and may not be permissible within most industrial zones in NSW.

This PHA was prepared applying SEPP 33, and generally in accordance with the Department of Planning (DoP) (formerly Department of Urban Affairs and Planning) publications *Hazardous Industry Planning Advisory Paper No. 6 - Guidelines for Hazard Analysis* (1992) (HIPAP 6)[2] and *Hazardous Industry Planning Advisory Paper No. 4 – 'Risk Criteria For Land Use Safety Planning'*.

This PHA considers risks associated with the development in terms of accidental loss scenarios and their potential for hazardous incidents. General handling of waste materials and emissions produced during normal operations are dealt with elsewhere in the EA.

The primary objectives of a PHA are to:

- » Identify potential hazards associated with the proposal;
- » Analyse the consequences of significant hazards on people and the environment, and the likelihood or frequency of these hazards occurring;
- » Estimate the resultant risk to the surrounding land uses and environment; and
- » Analyse the safeguards to ensure they are adequate, and therefore demonstrate that the operation can operate within acceptable risk levels to its surroundings.

5. Methodology

5.1 General

A PHA is to provide sufficient information and assessment of risks associated with the proposed development to show that it satisfies the risk management requirements of the proponent company and the relevant public authorities. Within this brief, the main objective of the PHA is to show that the residual risk levels are acceptable in relation to the surrounding land use, and that risk will be appropriately managed. This is done by systematically:

- » Identifying intrinsic hazards and abnormal operating conditions that could give rise to hazards;
- » Identifying the range of safeguards;
- » Assessing the risks by determining the probability (likelihood) and consequence (effects) of hazardous events for people, the surrounding land uses and environment; and
- » Identifying approaches to reduce the risks by elimination, minimisation and/or incorporation of additional protective measures.

With proper application, this method should demonstrate that the proposed plant can operate within acceptable risk levels in relation to its surroundings.

The PHA needs to be carefully and clearly documented with the assumptions and uncertainties of final design and operation defined.

5.2 Preliminary Risk Screening

The need for a PHA under SEPP 33 is determined by a preliminary risk screening of the proposed development. The preliminary screening methodology concentrates on the storage of specific dangerous goods classes that have the potential for significant off-site effects. Specifically the assessment involves the identification of classes and quantities of all dangerous goods to be used, stored or produced on site with an indication of storage depot locations. Details of the methodology are described in DoP's - Applying SEPP 33 – Hazardous and Offensive Development Application Guidelines (1994).

5.3 Hazard Identification

The hazard identification for the proposed upgrade of ethanol production included the review of:

- » Various dangerous goods kept on the Shoalhaven site;
- » Location and type of storage;
- » Inventories of all chemicals and ethanol;
- » Processing units handling dangerous goods and flammable materials;
- » Process and ethanol loading operation;
- » Hazardous property of each chemical with respect to the Dangerous Goods code and reference to the MSDS;


The focus of the exercise is to identify hazardous scenarios that could have potential offsite consequences.

The major hazards identified from the Hazard Identification above were included in the Quantitative Risk Assessment (QRA) to determine the off site risk in accordance to the nominated risk criteria of NSW HIPAP No 4

5.4 QRA Methodology

The methodology employed in this assessment is summarised below in Figure 5-1 The QRA Process. Each stage identified in the process is discussed in detail.

Figure 5-1 The QRA Process



5.4.1 Consequence Analysis

The objectives of the consequence analysis are to:

- » Determine relevant toxic and flammable inventories;
- » Analyse a representative set of spill or loss of containment cases;
- » Determine the consequences of each spill with regards to the potential of fire and explosion and offsite impact to people, environment and properties.

The processes used to complete the analysis are;

- » Discharge rate modelling;
- » Dispersion Modelling; and

- » Fire and Explosion Impact Modelling.

Spill, dispersion, and subsequent fire effects calculations are performed using the SAFETI (Software for the Assessment of Fire Explosion and Toxic Impact) commercial software package. The SAFETI package models have been extensively validated and a description of the consequence models employed in SAFETI is provided in Appendix B.

5.4.2 Frequency Analysis

The objective of the frequency analysis is to determine the frequency of each of the hazardous events. The process followed is:

- » Selection of appropriate generic base leak frequencies from available industry data sources;
- » Completion of a parts count of the plant to determine the number of components able to initiate the identified hazardous events;
- » Selection of ignition probabilities for flammable releases from available data published for onshore plants; and
- » Combination of release frequencies with immediate and delayed ignition probabilities (and applicable mitigation measures) enabling determination of a range of gas release and fire event frequencies.

The selection of leak frequency data, parts count, ignition probabilities and individual scenario leak frequencies can be seen in Appendix D.

5.4.3 Risk Calculation Methodology

This risk assessment is completed using SAFETI commercial software package. Individual risk per annum (IRPA) contours are plotted according to:

- » Fire frequency;
- » Location of release;
- » Magnitude of consequence
 - Radiation exposure; and
- » Local meteorology.

5.4.4 Project Risk Criteria

The risk levels calculated in the above step are compared against the nominated project risk criteria. The risk criteria chosen are those detailed HIPAP No 4 'Risk Criteria for Land Use Safety Planning'. The paper documents the risk criteria to be used for land use and safety planning issues.

Individual Fatality Risk

'Individual Fatality Risk' is the risk of death to a person at a particular point and the criteria is summarised in Table 5–1 Individual Fatality Risk Level Criteria.

Table 5–1 Individual Fatality Risk Level Criteria

Exposure Type	Risk Levels
Hospitals, schools, child-care facilities and old age housing developments	Half in a million per year (0.5×10^{-6} per year)
Residential developments and places of continuous occupancy (hotels/resorts)	One in a million per year (1×10^{-6} per year)
Commercial developments, including offices, retail centres, warehouses with showrooms, restaurants and entertainment centres	Five in a million per year (5×10^{-6} per year)
Sporting complexes and active open space areas	Ten in a million per year (10×10^{-6} per year)
Industrial sites	Fifty in a million per year (50×10^{-6} per year)

The location of the Manildra facility is in an industrial area. The acceptable individual fatality risk level is fifty-in-a-million per year (50×10^{-6} per year) at the site boundary.

Injury Risk

- » Incident heat flux radiation at residential areas should not exceed 4.7 kW/m^2 at frequencies of more than 50 chances in a million per year.
- » Incident explosion overpressure at residential areas should not exceed 7 kPa at frequencies of more than 50 chances in a million per year.

Societal Risk

The societal risk analysis combines the consequences and likelihood information with population information. The result is presented in the form of 'F-N curve', which is a graph showing the cumulative frequency (F) of killing 'n' or more people (N).

Property Damage

- » Incident heat flux radiation at neighbouring potentially hazardous installations or at land zoned to accommodate such installations should not exceed a risk of 50 in a million per year for 23 kW/m^2 heat flux,
- » Incident explosion overpressure at neighbouring potentially hazardous installations, at land zoned to accommodate such installations or at nearest public buildings should not exceed risk of 50 in a million per year for the 14 kPa explosion overpressure level

6. Hazard Identification

The first step in a risk assessment is to identify all potential sources of leakage on site. The focus is on hazardous or flammable materials, which can result in offsite consequences. Causes of potential leaks were identified as:

- » Pipe and fittings failure;
- » Pumps (seal/gland failure);
- » Storage vessel/tank failure;
- » Corrosion erosion (minor leaks);
- » Loading Arm and Hose failure;
- » Maloperation (eg not connecting hose properly);
- » Incorrect plant and equipment modifications;

Individual failure modes of all equipment items used on the facility are discussed in Appendix D.

A plant visit was completed to review the process and the proposed modifications. The hazards were identified in a desktop exercise and reviewed and validated by Shoalhaven Starches personnel. The hazard identification involved review of the project scope and the changes to the inventory of the hazardous materials on the Shoalhaven site as a result of the project.

The hazard identification results are given in Table 6–1 Hazard Identification.

6.1 Hazardous Materials

A full list of hazardous materials kept on the site are given in Appendix A. Not all hazardous materials kept on site have the potential to cause off site impact and there are no changes to the inventory or type of chemical stored on site from the proposed ethanol plant upgrade. There is no increase in the ethanol storage capacity on site. However, there will be an increase in the handling of ethanol with respect to loading i.e. doubling the current tanker loading rate. This will increase the likelihood of ethanol release in the loading bay due to mechanical failure i.e. hose failure or human error.

There will be an increase in natural gas usage on site due to the co-generation plant.

The materials that are considered to cause off site impact and included in this risk assessment are:

- » Ethanol; and
- » Natural Gas.

The chemical and physical properties of these 2 materials are given in Appendix A.

Table 6–1 Hazard Identification

HAZARD IDENTIFICATION					
Project	Shoalhaven Ethanol Production Upgrade			Date: 27/08/07	
Present					
No	Hazard Scenario	Causes	Consequence	Safeguards	Actions
E1	<p>Ethanol release at the storage bay.</p> <p>There are 7 ethanol storage tanks. Ethanol is stored at ambient temperature and atmospheric pressure. The combined storage capacity is 1.9 million litres of ethanol but the actual storage is normally 50% of the capacity.</p> <p>There is no change to ethanol storage capacity as part of the upgrade.</p>	<ol style="list-style-type: none"> 1. Tank catastrophic failure ; 2. Valve & Piping failure; 	<p>Ethanol vapour ignites and burns as a pool fire. Thermal radiation from the fire.</p>	<ol style="list-style-type: none"> 1. Tank and pumps are fully bunded.; 2. Any spill in the bund is automatically pumped away to the recovery tank. There is a flow alarm to seek operator attention; 3. Operator surveillance of the bund; 4. Foam injection into the tank to smother fire; 5. Fire monitor 2; 6. Hot work control and permit to work system; and 7. Inspection and Maintenance Systems. 	

HAZARD IDENTIFICATION					
Project		Shoalhaven Ethanol Production Upgrade		Date: 27/08/07	
Present					
No	Hazard Scenario	Causes	Consequence	Safeguards	Actions
E2	<p>Ethanol Release at the loading bay.</p> <p>Ethanol is loaded into B-Double or Single road tankers and transported to the customer site. There are 3 loading pumps for 3 different grades of ethanol. Only one pump is used during loading of a product. A B-Double can hold 50,000 L of ethanol and a Single tanker can hold 34, 000 L.</p> <p>Normally 6 B-Double and 1 Single tankers are loaded per day. The loading rate is expected to increase to 14 B-Doubles and 4 Single tankers per day to meet the upgraded 3 ML per annum production capacity.</p> <p>Currently a single loading arm is used for loading but post upgrade 2 loading arms could be used.</p>	<ol style="list-style-type: none"> 1. Hose failure; 2. Hose not connected properly (human factors); 3. Pipe or flange failure (mechanical); 4. Drive away with hose connected (human factors). 	<ol style="list-style-type: none"> 1. Loading bay drains blocked or underground storage tank full leading to pool formation and pool fire in the loading bay. 2. Potential for explosion (flash fire) in the loading bay if the ethanol vapour fails to ignite immediately. 	<ol style="list-style-type: none"> 1. Steel braided hose for loading; 2. Hose inspection and testing program; 3. Driver in attendance during loading; 4. Emergency Stops (3) in the loading bay to shut down loading; 5. 2 IR flame detectors; 6. Foam sprinkler on the loading bay. Automatic foam activation upon break glass; 7. Fire break glass alarm; 8. Local fire authority automatic notification upon fire break glass activation; and 9. On site full time fire crew. 10. 2 drains in the loading bay to drain any spill to the underground storage tank 	

HAZARD IDENTIFICATION					
Project	Shoalhaven Ethanol Production Upgrade			Date: 27/08/07	
Present					
No	Hazard Scenario	Causes	Consequence	Safeguards	Actions
E3	<p>Ethanol release from the Molecular Sieve plant.</p> <p>Release of 99.5% ethanol from the molecular sieve vessel or associated equipment.</p> <p>Ethanol from the Molecular Sieve is transferred/pumped to storage at 200 kPa and 160 °C.</p> <p>Ethanol will flash off and form vapour cloud leading to potential explosion in the distillation section building.</p>	<ol style="list-style-type: none"> 1. Vessel failure; 2. Pipe failure; and 3. Gasket or flange failure. 	<p>Ethanol is in vapour form in the mol sieve hence ethanol release from this section will be in vapour form.</p> <p>Potential for a vapour cloud explosion.</p>	<ol style="list-style-type: none"> 1. Operator surveillance; 2. Plant remote isolation; 3. Bund to contain the spill and automatic transfer to recovery system; 4. Foam application for fire fighting; 5. Spill in the bund will be detected via the flow meter on the bund transfer line to the recovery tank; and 6. Inspection and Maintenance System. 	
E4	Ethanol release from ethanol pump inside the ethanol tank bund.	<ol style="list-style-type: none"> 1. Gasket failure; 2. Flange failure; and 3. Pipe failure. 	Formation of ethanol pool and potential pool fire.	<ol style="list-style-type: none"> 1. Pump located within bund; 2. Operator monitoring; 3. Loss of flow alarm; and 4. Inspection and Maintenance System. 	

HAZARD IDENTIFICATION					
Project	Shoalhaven Ethanol Production Upgrade			Date: 27/08/07	
Present					
No	Hazard Scenario	Causes	Consequence	Safeguards	Actions
E5	Ethanol release from the Distillation Columns (T680, T540, T660). Ethanol concentration: 92%.	1. Vessel failure; 2. Gasket failure; 3. Flange failure; and 4. Pipe failure,	Formation of ethanol pool and potential pool fire.	1. Bund to contain the leak; 2. Alarms & operator monitoring; 3. Inspection and maintenance program.	
E6	Gas release at No 2 steam boiler A 4" gas pipeline supplies gas to the burner. Due to the location of burner and the pipe line, there is potential for gas accumulation and delayed ignition resulting in explosion in the building. The utilities control room and the workshop are relatively close to the burner and could be affected by the explosion.	1. Pipe failure; 2. Gasket Failure; 3. Flange failure; and 4. Valve failure.	Delayed ignition resulting in vapour cloud explosion. Off site impact is not likely due to the separation distance from the public road.	1. Burner management system; 2. Burner management system and piping designed to code; 3. Safety shut off system; 4. Boiler trip testing; and 5. Routine inspection and maintenance.	

HAZARD IDENTIFICATION					
Project	Shoalhaven Ethanol Production Upgrade			Date: 27/08/07	
Present					
No	Hazard Scenario	Causes	Consequence	Safeguards	Actions
E7	Gas release at the Cogeneration Plant. A gas fired cogeneration plant is proposed for the Shoalhaven site. The plant will be located away from the main plants and buildings. There is potential for gas release leading to fire or explosion.	1. Pipe failure; 2. Gasket Failure; 3. Flange failure; and 4. Valve failure.	1. Jet fire and thermal radiation. 2. Potential for gas cloud explosion in the case of delayed ignition.	1. Burner management system; 2. Burner management system and piping designed to code; and 3. Routine inspection and maintenance.	
E8	A second gas fired boiler for steam generation is proposed as part of this expansion.	1. Pipe failure; 2. Gasket Failure; 3. Flange failure; and 4. Valve failure	Delayed ignition resulting in vapour cloud explosion. Off site impact is not likely due to the separation distance from the public road	1. Burner management system; 2. Burner management system and piping designed to code; 3. Safety shut off system; 4. Boiler trip testing; and 5. Routine inspection and maintenance	

HAZARD IDENTIFICATION					
Project	Shoalhaven Ethanol Production Upgrade			Date: 27/08/07	
Present					
No	Hazard Scenario	Causes	Consequence	Safeguards	Actions
E9	<p>Gas release at the metering station.</p> <p>A gas metering station is proposed to be installed across the road from the production facility. The pipe line from the metering station will run underground to the site.</p> <p>The station is owned by a third party and is not in Manildra's boundary, therefore, it was not included in the modelling.</p>	<ol style="list-style-type: none"> 1. Pipe, flange or gasket failure; 2. Collision with pipe; and 3. Object dropped on the pipe. 	Release of gas resulting in jet fire and potential for thermal radiation. A public road runs approximately 20m from the metering station.	<ol style="list-style-type: none"> 1. Metering station fenced to prevent collision or vandalism. 	
E10	<p>Diesel Storage Tank</p> <p>There is a diesel storage tank for the fire water pumps. Tank capacity 5000 L.</p> <p>Not included in the model due to small inventory.</p>	<ol style="list-style-type: none"> 1. Tank failure. 	Diesel pool fire. Off site impact from thermal radiation not expected due to small inventory.	<ol style="list-style-type: none"> 1. Away from vehicle access way (collision protection and no ignition source). 2. Fire monitors nearby. 	

6.2 Hazardous Scenarios

The hazardous scenarios that have the potential to cause off site impact and included in the model are given below:

1. Ethanol storage tank catastrophic failure and release of ethanol in the bund resulting in a pool fire in the bund (E1);
2. Ethanol release in the loading bay due to hose or loading arm failure resulting in a pool fire (E2);
3. Ethanol vapour release from the Mol Sieves and associated equipment resulting in jet fire or vapour cloud explosion (E3);
4. Ethanol release from the ethanol loading pump resulting in a pool fire near the storage tank (E4);
5. Ethanol release from the distillation unit resulting in pool fire in the distillation section (E5);
6. Natural gas release from the gas fired boiler (No 2 & proposed boiler) resulting in delayed ignition and explosion (E6/E8); and
7. Natural gas release from the pipe line & fittings at the Cogeneration Plant resulting in jet fire (E7).

The gas metering station across the road is not included in the model as it is owned by the gas supplier and is not on Manildra's property.

Table 6-1 Hazardous Scenarios and Process Conditions

Event ID	Description	Isolation	Condition	Consequence
E1	Single Ethanol Storage Tank catastrophic failure in the storage bund. Most of spillage will be pumped away into the underground recovery tank.	Spill: 217,000 kg Failure of largest tank)	Temp: 20 °C Press: atmospheric	Pool Fire
E2	Ethanol release in the loading bay (hose or loading arm failure).	Isolation Time: 1800s (Spill: 10,000 kg)	Temp: 20 °C Press: atmospheric	Pool Fire
E3	Ethanol release in the plant (Molecular Sieve)	Isolation Time: 3600s (Max spill: 10,240 kg)	Temp: 155 °C Pressure: 500 kPag	Vapour Cloud Explosion
E4	Ethanol release in the bund from loading pump.	Isolation Time: 1800s (Spill: 10,000 kg)	Temp: 20 °C Press: 400 kPag	Pool Fire
E5	Ethanol release from the distillation section.	Isolation Time: 3600s (Max spill: 10,240 kg)	Temp: 160 °C Pressure: 600 kPag	Pool Fire & VCE

E6/E8	Natural gas release at boiler 2 and proposed boiler.	Max Gas release: 1000 kg	Temp: 20 °C Press: 210 kPag	Jet Fire & Vapour Cloud Explosion
E7	Natural gas release at the Cogeneration Plant	Max gas release: 5000 kg	Temp: 20 °C Press: 2300 kPag	Jet Fire & Vapour Cloud Explosion

7. Study Assumptions

A number of assumptions were made in completing the risk model. These assumptions are listed below:

- » Liquid ethanol is modelled as a pool fire;
- » Gas leak is modelled as jet fire;
- » Unignited ethanol vapour cloud is modelled as vapour cloud explosion;
- » An isolation time of 60 minutes assumed for process units (distillation and mol sieve). For ethanol loading pump and loading bay, an isolation time of 30 minutes is assumed because personnel (driver) would be present at the scene to detect the event and take action to stop the leak or pump.
- » Fumes generated from the fire will be carried upwards by the heat of the fire. They are therefore assumed to have no contribution to fatalities for offsite risk;
- » Dust cloud explosion not considered in this study as there is no change to storage of raw materials (starches) used in the production of ethanol. A PHA for the flour mill was completed during the flour mill upgrade;
- » It is assumed that 50% content of the largest ethanol tank will be involved in a pool fire for the catastrophic tank failure scenario (E1), the rest of the ethanol will be pumped away into the underground storage tank;
- » Hazard scenarios and the parts count have been verified by Shoalhaven staff;
- » A bund of (10m x 10m) was used to model the pool fire in the loading bay;
- » A bund of (20m x 10m) was used to model the pool fire in the ethanol tank storage bund;
- » Ignition probability of Cox, Lees and Ang used;
- » Release from molecular sieve is ethanol vapour;
- » Only the major equipment in the distillation and molecular sieve sections are considered in the failure scenarios.

8. Results and Discussions

Modelling of each of the hazardous scenarios was completed in order to assess the severity of the impacts. In all cases the consequences and likelihood of occurrence were determined and combined together with the site layout and local meteorological conditions to determine the risk levels.

8.1 Frequency Analysis

The leak frequency data obtained from the UK HSE was used in the assessment of the failure frequencies of equipment associated with the hazardous scenarios in this study. UK HSE data is based on the leak frequencies of equipment in off shore operation which is in a harsh environment. The details of the frequency assessment can be found in Appendix D.

8.2 Consequence Modelling

Consequence of each hazard scenario were assessed using SAFETI (Software for Assessment of Fire, Explosion and Toxic Impact). The following consequences were considered in the risk assessment:

- » Pool Fire (Thermal Radiation) for Fire Events associated with Ethanol pool fire;
- » Jet Fire (Thermal Radiation) for gas release;
- » Vapour Cloud Explosion.

Levels of thermal radiation included in this risk assessment were 4.7 kW/m^2 , 12.6 kW/m^2 and 35 kW/m^2 . The radiation effects as given in HIPAP No 4 are:

- » 4.7 kW/m^2 : potential to cause injury;
- » 12.6 kW/m^2 : potential to cause fatality for extended exposure;
- » 35 kW/m^2 : potential to cause fatality instantaneously.

For each of the identified hazardous scenarios, the distances to consequences of interest are determined. The consequences of interest are based on human impact criteria i.e. the exposure to thermal radiation for periods of time.


The consequences of hazardous scenarios and input data for scenarios are reported in Appendix C.

8.3 Risk Assessment

8.3.1 Individual Risk of Fatality

The Individual Fatality Risk is the risk of death to a person while standing at a particular point. The Individual Fatality Risks calculated for the Shoalhaven site are given in Figure 8-1 below. The risk contours are the nominated risk criteria for land use safety planning of NSW DoP (HIPAP No 4).

Figure 8-1 Individual Fatality Risk



The individual fatality risk from the proposed upgrade of the Shoalhaven facility in Bomaderry does not breach any of the nominated risk criteria of NSW HIPAP No 4.

The key information from the Individual Fatality Risk profile are:

- » 50×10^{-6} /yr risk contour around the ethanol production and storage facility is within the site boundary. The industrial sites around the Manildra plant are not affected;
- » The 5×10^{-6} /yr to 0.5×10^{-6} /yr risk contours go over the Bolong Road but does not breach the risk criteria;
- » The Cogen plant to be located in the south corner of the site does not breach any risk criteria.

The off site risk from the existing operation and the proposed modification is acceptable. However, opportunities for risk reduction should be continuously reviewed and implemented.

8.3.2 Societal Risk

There are no residential or sensitive population close to the site to be affected by a large incident on the site. The closest residential area is over 350 m away to the west beyond the railway line.

8.3.3 Injury Risk

The closest residential area is over 350 m away from the ethanol facility and the maximum distance from an explosion or fire is.

- » 4.7 kW/m² (70 m)
- » 7 kPa (110 m)

Therefore, injury risk to people in the residential area is not possible from a fire or explosion event in the ethanol facility.

8.3.4 Property Damage

There are no hazardous industries close to the site to cause escalation issue from an incident on the Manildra site.

- » The overpressure of 14 kPa does not extend more than 70 m from the ethanol facility. The explosion overpressure (14 kPa) from the co-generation unit does not exceed the boundary. Figures C1 and C2 in Appendix C shows the explosion overpressure contours for the cogeneration unit and mol sieve.
- » The thermal radiation of 23 kW/m² does not extend beyond the site.

Therefore, there is no possibility of property damage beyond the site boundary, using the criteria for property damage as given in Section 5.4.4.

9. Recommendations

The off site risk assessment completed for the proposed ethanol production upgrade is in compliance with the DoP risk criteria given in HIPAP No 4. However, it is recommended to identify opportunities during the design phase of the project to improve the safety of the process. This can be achieved through design reviews and appropriate safety studies.

The following recommendations are made to improve the safety of the proposed upgrade:

1. Complete the Hazard and Operability (HAZOP) for the new plants i.e. co-generation, gas fired boiler and mol sieve at the completion of the detail design;
2. Review the impact of the increased production capacity on the existing process units (vessels and pipes) with respect to mechanical integrity;
3. Consider completing a traffic risk assessment with respect to increased traffic movement associated with raw materials and ethanol movement to and from the site;
4. Review the fire fighting capability with respect to new plant and equipment such as the co-generation plant and gas fired boilers;
5. Review the emergency shutdown system and emergency procedures with respect to the new plants (co-generation and boiler).

10. Conclusion

The Quantitative Risk Assessment (QRA) as part of the Preliminary Hazard Analysis (PHA) was completed for the proposed Ethanol Facility upgrade at the Shoalhaven site. The QRA incorporated the proposed ethanol production upgrade and the existing operation to show the total risk associated with the site.

The hazardous materials and hazardous operations that have potential for off site impact were included in the QRA. The new hazards with potential for off site impact introduced by the proposed upgrade are:

- » Cogeneration Plant; and
- » Increased ethanol loading frequency, as a result of doubling of ethanol production capacity, which increases the likelihood of release of ethanol in the loading bay.

The PHA was completed in accordance with the State Environmental Planning Policy (SEPP) 33 guideline of NSW DUAP (now DoP) and HIPAP No 6 guideline for Hazard Analysis. The QRA was completed using the Risk Criteria for Land Use Safety Planning given in HIPAP No 4.

Individual Fatality Risk was calculated using SAFETI (Software for the Assessment of Fire, Explosion and Toxic Impact) and the risk is demonstrated to be acceptable as all the risk contours are in compliance with the nominated risk criteria of HIPAP No 4.

11. References

- Hazardous Industry Planning Advisory Paper No. 6 "Guidelines for Hazard Analysis", NSW Department of Planning. 1992;
- Applying SEPP 33, Hazardous and Offensive Development Application Guidelines, NSW Department of Urban Affairs and Planning;
- Lees, F.P., "Loss Prevention in the Process Industries", Vol 2, Butterworth Heinemann, Oxford, United Kingdom, 1996;
- Quantified Risk Assessment: Its Input to Decision Making, UK Health & Safety Executive, 1989;
- SAFETI (Software for the Assessment of Fire Explosion and Toxic Impact) v6.4.2 help file;
- SAFETI Modelling Software User Manual, DNV, 1995;
- Preliminary Assessment Report, A Background Review of the Proposal, Proposed Ethanol Production Upgrade including New Waste Water Treatment Plant, August 2007;
- Mahant, R., 'Hazard Analysis New Molecular Sieves at Ethanol Plant', 2000;
- 'Manildra Group – Bomaderry Site PML Events Damage Contours', Matrix Pty Ltd, 2005.

Appendix A

Background Data

- A I. Site Layout
- A II. Register of Hazardous Materials Register
- A III. Properties of Hazardous Material
- A IV. Weather Data

A I . Site Layout

An aerial photograph and site layout of the Manildra Ethanol plant are given in Figure A 1 below.

Figure A 1 Shoalhaven Site Aerial Photograph



A II . Hazardous Material Register

The hazardous materials identified on the site are given in Table A II 1 below.

Table A II 1 Hazardous Materials

Hazardous Material	Location	UN Code	Class	Quantity
Sulfuric Acid	Farm	2796	8	15,000 L
Acetic Anhydride	Zone 1A	1715		3,000 L
Hypochlorite Solution	Zone 1A	1791	8	30,000 L
Hydrogen Peroxide (solution)	Zone 1B	2014	5.1	1,000 L
Butanol	Zone 2A	1120	3	5,000 L
n-Propanol	Zone 2A	1274	3	5,000 L
n-Propyl Acetate	Zone 2A	1276	3	5,000 L
Butanol	Zone 2B	1120	3	1,800 L
Methyl Isobutyl Ketone	Zone 2B	1245	3	1,800 L
n-Propanol	Zone 2B	1274	3	3,600 L
n-Propyl Acetate	Zone 2B	1276	3	3,600 L
Ethanol	Zone 2C	1170	3	2,970,000 L
Dimethyl Ether	Zone 2D	1033	2.1	100,000 L
Petrol	Zone 2E	1203	3	5000 L
Methanol	Zone 2E	1230	3	5000 L
Methyl Isobutyl Ketone	Zone 2E	1245	3	5000 L
Hydrochloric Acid	Zone 4			30,000 L
Sodium Hydroxide Solution	Zone 4			52,000 L
Ammonia Solution	Zone 4	2672	8	35,000 L
Sulfuric Acid	Zone 6	2796	8	2,700 L
Hydrochloric Acid	Zone 7	1789	8	20,000 L
Phosphoric Acid	Zone 7	1805	8	36,000 L
Sodium Hydroxide Solution	Zone 7	1824	8	20,000 L

A III . Properties of Hazardous Materials

Natural Gas

Natural gas is used on the site mainly for steam generation in the boilers and is proposed to be used in the Co-Generation plant.

Natural gas is a non toxic, colourless gas at ambient conditions. It is odourless , however, an odourant is normally added before it is shipped to end users. Natural gas is lighter than air. It is highly flammable, with flammability ranging from 5% to 15% volume in air. If it does not immediately ignite upon release, it can form an explosive mixture with air. If it is burned in limited supply of air, carbon monoxide may be produced. While it is regarded as being stable, it is not compatible with strong oxidising agents.

The physical and chemical properties of natural gas are given in Table A III 2.

Ethanol

Ethanol is highly flammable, the vapours can form an explosive mixture when mixed with air. The physical and chemical properties of ethanol are given in Table A III 2 below.

Table A III 2 Physical & Chemical Properties of Ethanol & Natural Gas

Material	Boiling Point (°C)	Specific Gravity	Vapour Pressure KPa (at 20 °C)	Flash Point	LEL %	UEL %	Melting Point (°C)	Auto Ignition Temp (°C)
Ethanol	78	0.790	5.7	13 °C	3.3	19.0	-117	N/A
Natural Gas	-162	0.615	N/A	-218	5.0	15.0	NA	540

A IV . Weather Data

Weather is classed according to wind speed and weather stability class. Table A IV 1 below shows the different weather stability classes.

Table A IV 1 Weather Stability Classes

Class	Type	Description
A	Very Unstable	Daytime – sunny, light winds (strong insolation)
B	Unstable	Daytime – moderately sunny, light to moderate winds
C	Unstable / Neutral	Daytime – moderate winds, overcast or windy and sunny
D	Neutral	Daytime – windy, overcast or Night-time - windy
E	Stable	Night-time - moderate winds with little cloud or light winds with more clouds

Class	Type	Description
F	Very Stable	Night-time - light wind, little cloud (strong temperature inversion)

Local meteorological data was obtained from the Nowra weather station for the Shoalhaven site.

The weather classes and wind speeds selected for this QRA are:

Wind 1.5 m/s, weather stability class F;

Wind 3 m/s, weather stability class C;

Wind 5 m/s, weather stability class D;

Wind 7 m/s, weather stability class D;

Average Temperature: 21 °C;

Relative Humidity: 70%

Appendix B

Consequence Models

- B I. Discharge Modelling
- B II. Dispersion
- B III. Flammable Effects

Consequence Modelling

A part of the risk assessment process involves generating consequences for the release events identified. The steps involved in determining consequences are:

- » Determine release conditions based upon materials involved, process conditions and available inventory etc;
- » Based on release conditions, determine the types of events which will occur (eg jet fire, toxic cloud, evaporating pool etc);
- » Calculate the extent of the consequences; and
- » Establish the impact of the consequence (e.g. proportion of people killed when exposed to a toxic dose)

The consequences are calculated using empirically derived models, which can then be used to determine which release cases generate offsite effects and should be included in the risk model. The level at which fatal consequences are considered to occur will directly influence the risks.


This Appendix discusses basic concepts and theory behind the various consequence models used in the analysis. The models discussed are:

- » Discharge Modelling;
- » Dispersion;
- » Flammable Effects:
 - § Jet Fire;
 - § Flash Fire;
- » Toxic Effects.

B I. Discharge Modelling

If there is a hole in a pipeline, vessel, flange or other piece of process equipment, the fluid inside will be released through the opening, provided the process pressure or static head is higher than ambient pressure. The properties of the fluid upon exiting the hole play a large role in determining consequences, eg, vapour or liquid, velocity of release etc. Figure B 1 illustrates an example scenario.

Figure B 1 Typical Discharge



The discharge can be considered to have two stages; the first is expansion from initial storage conditions to orifice conditions, the second from orifice conditions to ambient conditions.

The conditions at the orifice are calculated by assuming isentropic expansion, ie, entropy before release = entropy at orifice. This allows enthalpy and specific volume at the orifice to be calculated.

The equations for mass flow rate (\dot{m}) and discharge velocity (u_0) are then given by:

$$\dot{m} = C_d A_o \rho_o \sqrt{-2(H_0 - H_i)}$$

$$\text{And } u_0 = C_d \sqrt{-2(H_0 - H_i)}$$

Where

- » C_d = Discharge coefficients;
- » A_o = Area of the orifice;
- » ρ_o = density of the material in the orifice;
- » H_o = Enthalpy at the orifice; and
- » H_i = Enthalpy at initial storage conditions.

The discharge parameters passed forward to the dispersion model are as follows:

- » release height (m) and orientation;
- » thermodynamic data: release temperature (single phase) or liquid mass fraction (two-phase), initial drop size;
- » other data;
 - » for instantaneous release: mass of released pollutant (kg), expansion energy (J)
 - » for continuous release: release angle (degrees), rate of release (kg/s), release velocity (m/s), release duration (s).

B II. Dispersion


When a leak occurs, the material will be released into the atmosphere. Upon being released it will start to disperse and dilute into the surrounding atmosphere. The limiting (lowest) concentration of interest is related to flammable and toxic limits for flammable and toxic substances respectively. The model used to determine extent of release is described below, along with some of the key input parameters.

The consequence modelling package PHAST utilises the Unified Dispersion Model (Witlox *et al*, 1999). This models the dispersion following a ground level or elevated two phase unpressurised or pressurised release. It allows for continuous, instantaneous, constant finite duration and general time varying releases. It includes a unified model for jet, heavy and passive two phase dispersion including possible droplet rain out, pool spreading and re-evaporation.

B II.1 Jet Dispersion

For a continuous, pressurised release, the material is released as a jet, ie, high momentum release. The jet eventually loses momentum and disperses as a passive cloud. Figure B 2 below shows a typical release and the various phases involved.

Figure B 2 Jet Dispersion



The cloud is diluted by air entrainment until it eventually reaches the lower limit of concern. During the jet phase, the mixing is turbulent and much air is entrained. In the passive phase, less air is potentially entrained, and it occurs via a different mechanism to the turbulent jet phase. The calculation of the plume therefore depends on many factors, the key parameters being:


- » Material released, specifically molecular weight;
- » Discharge conditions including phase(s) of release, velocity etc;

Atmospheric conditions (a cloud will generally travel further in more stable conditions with lower wind speeds).

B II Dispersion from Pool Evaporation

If a rupture occurs from a refrigerated tank or vessel, the refrigerated liquid product will leak out and form a pool on the ground. This pool will evaporate and the resulting vapour cloud disperses as a low momentum cloud. Due to the low momentum, the cloud is not turbulent, which is a significant factor in air entrainment and dilution of the cloud. Figure B 3 below shows a typical release and some of the inputs into the calculation.

Figure B 3 Pool Evaporation Heat Balance



The rate of the evaporation depends on numerous factors, the most important ones being:

- » Surface it is released onto (eg its thermal properties and temperature);
- » Atmospheric conditions (a cloud will generally travel further in more stable conditions with lower wind speeds);
- » Boiling point of the liquid; and
- » Pool size.

The concentration of interest is normally related to the flammable, or toxic limits or specified Emergency Response Planning Guideline (ERPGs) limits set for the contained hazardous material.

B III Flammable Effects


If the release is of a flammable material, it is possible for the release to be ignited. The type of fire which results (eg jet, pool, explosion etc) depends on the physical properties of the release and whether the ignition is immediate or delayed. The various flammable effects are discussed below.

B III.1 Jet Fire

Jet fires are a result of high momentum releases. If a flammable release is ignited instantaneously, a jet fire will result. The flame will have a degree of 'lift off' as the flammable mixture has to dilute to be within the flammable limits. This section briefly discusses the model used for jet fires as well as key parameters in the calculation.

The jet fire calculation utilises the Chamberlain model (Chamberlain 1987). In this model, jet fires are modelled as a conical flame, with the ignited portion lift off, inclination and shape being determined by the material being released, the pressure at which it is being released and the hole size that it is being released through. These release parameters are the main inputs to the jet fire radiation calculations. Figure B 4 below shows a graphical representation of the jet fire model.

Figure B 4 Truncated Cone Jet Fire Model



Where;

L = Lift off;

I = Flame Inclination;

R_1 = Flame Base Radius;

R_2 = Flame End Radius; and

F_L = Flame Length.


The jet fire calculations model radiation from the entire surface of the ignited portion of the jet. This includes radiation from the cone forming the body of the flame, as well as from the ends of the cone. The amount of radiation that a nearby receiver is exposed to is determined by its distance from the flame surface, as well as by the orientation of the flame relative to the receiver. The key parameters in the calculation of the radiation exposure of a receiver are therefore the flame lift off, the flame inclination, and the dimensions of the ignited portion of the jet (i.e. flame length and end radii).

B III.2 Pool Fires

If a flammable/combustible liquid spill ignites it will form a pool fire. Pools can also form if a pressurised liquid is released and then 'rains out' to form a pool. Pool fires have low momentum flames and therefore their direction is dependent on wind conditions. This section describes the pool fire model and the equations used in calculating size and radiation emitted from a pool fire.

Pool fire flames are modelled as cylinders sheared in the direction of the wind, with diameter D , height H and tilt angle q (measured from the vertical). The flame is described by three circles (c_1 , c_2 , c_3) arranged along the centreline of the flame, each defined by the downwind co-ordinate x and elevation z of the centre of the circle, and by the radius r . These flame-circle co-ordinates are the main input to the radiation calculations. Figure B 5 below shows a graphical representation of the pool fire model.

Figure B 5 ‘Sheared Cylinder’ Pool Fire Model



With these three circles, the radiation calculations will model radiation from two surfaces: from the side of the flame between c1 and c2, and from the top of the flame between c2 and c3. This approach ensures that the bottom of the pool fire is not treated as a radiating surface.

The flame length H, flame diameter D and tilt angle θ are used to calculate three co-ordinates of the flame, as follows:

$x_1 = 0.0$	$x_2 = H \sin \theta$	$x_3 = H \sin \theta$
$z_1 = d_{\text{elev}}$	$z_2 = H \cos \theta + d_{\text{elev}}$	$z_3 = H \cos \theta + d_{\text{elev}}$
$r_1 = D/2$	$r_2 = D/2$	$r_3 = 0.0$

Where:

d_{elev} = elevation of flame surface above ground

B III.3 Flash Fire

Flash fires are transient in nature and are the product of delayed ignition of a dispersing cloud in an unconfined environment. In a delayed ignition from vertical release the fireball formed dies back to a steady state jet flame from the source.

B IV Multi Energy Explosion Model

The Multi Energy Model gives overpressure of an explosion as a function of distance from the explosion. The explosion is modelled as a sphere and overpressure is calculated based on scaled distance from the centre. This section explains the key parameters involved in the multi energy model.

The energy released by the explosion, E, is calculated as the product of the mass of fuel in the cloud and the heat of combustion. This assumes a stoichiometric mixture of fuel and air.

The distance scaling factor, S, is related to the energy released by the explosion and the atmospheric pressure by

$$S = \left[\frac{E}{P_a} \right]^{1/3}$$


The scaled distance r is then given by

$$r = \frac{d}{S}$$

where d is the actual distance of the receiver from the cloud centre.

To calculate overpressure a set of 10 curves is used. The actual curve used depends on the degree of confinement, with a confinement of 1 being least confined and 10 most confined. Process plants generally have a confinement factor of 7, though it needs to be assessed for each individual process. The graph showing the 10 curves is included in Figure B 6 below.

Figure B 6 Multi Energy Curves



References:

AIHA, Emergency Response Planning Guidelines, AIHA, Akron, 1989.

Chamberlain, G. A., 1987, Developments in design methods for predicting thermal radiation from flares, Chem. Eng. Res. Des. v65 (1987).

Cox, A., Lees, F., and Ang, M., Classification of Hazardous Locations, Institute of Chemical Engineers, Warwickshire, 1990.

Daubert, T.E. and Danner, R.P. 1989, *Physical and thermodynamic properties of pure chemicals*, Data compilation by Design institute for physical property data and American institute of chemical engineers, Hemisphere Publishing Corporation.

Hazardous Industry Planning Advisory Paper No. 6 "Guidelines for Hazard Analysis", NSW Department of Planning. 1992.

Lees, F.P., "Loss Prevention in the Process Industries", Vol 2, Butterworth Heinemann, Oxford, United Kingdom, 1996.

Mellor J.W 1967, *Mellor's comprehensive treatise on inorganic and theoretical chemistry*, vol. 8(2) Nitrogen Part II, Longmans London, quoted in Daubert and Danner.

SAFETI (Software for the Assessment of Fire Explosion and Toxic Impact) v6.4.2 help file.

SAFETI Modelling Software User Manual, DNV, 1995.

Ten Berge, W.F. Swart, A, Appelman, L.M. 'Concentration – Time Mortality Response Relationship or Irritant and Systematically Acting Vapours and Gases, *Journal of Hazardous Materials*, (1986), 301 – 309.

TNO Yellow book, 2nd edition, TNO, The Netherlands (1992).

Wiltox, H.W.M. and Holt, A., "A unified model for jet, heavy and passive dispersion including droplet rainout and re-evaporation", CCPS 1999 ADM paper.

Appendix C

Consequence Results

Consequence Results

This section presents the consequence results of the hazardous events included in the study. The consequences assessed in this study were:

- » Thermal radiation - kW/m² (pool fire for ethanol and jet fire for natural gas); and
- » Overpressure from vapour cloud explosion (VCE). Multi Energy Model was used for explosion modelling.

C I Thermal Radiation

This section presents the thermal radiation results for 4.7 kW/m² (potential injury) and 12.6 kW/m² (potential fatality) from the various fire scenarios assessed in this study. The results are for wind condition 1.5F, which represents the worse case scenario.

Table C 1 Thermal Radiation Consequence Results

Event	Section Description	Bund (m)/Hole Size (mm)	Process Conditions		Thermal Radiation Distances (m)		Release (kg)
			P (kPa,g)	T (°C)	12.6 kW/m ²	4.7 kW/m ²	
E1	Ethanol release from the largest storage tank. Liquid Pool Fire	20 X 10	atm	25	33	49	217,000
E2	Ethanol release in the Loading Bay (Duration: 1800s) Liquid Pool Fire	10 X 10	400	25	25	37	10,000
E3	Ethanol Release from Mol Sieve Section (Duration: 3600s) Vapour Jet Fire	100 mm	200	150	53	63	10,240
E4	Ethanol release from Ethanol loading pump (duration: 1800s) Liquid Pool Fire	10 X 5	400	25	18	28	10,000
E5	Ethanol release from Distillation Unit (3600s) Liquid/Vapour Jet Fire	100 mm	450	155	60	70	10,240
E6	Gas release from the boiler No 2 (duration: 3600s) Jet Fire	5	21	20	-	-	50
		25			6	7	185
		50			12	14	1000

Event	Section Description	Bund (m)/Hole Size (mm)	Process Conditions		Thermal Radiation Distances (m)		Release (kg)
			P (kPa,g)	T (°C)	12.6 kW/m ²	4.7 kW/m ²	
E7	Gas release from Cogen Plant (duration: 600s) Jet Fire	5	2300	20	-	-	1000
		25			27	32	1000
		50			53	56	5000
E8	Gas release from the proposed boiler (duration: 3600s) Jet Fire	5	21	20	-	-	50
		25			6	7	185
		50			12	14	1000

C II Explosion Overpressure

This section presents the explosion overpressure of scenarios of interest with the largest impact.

Figure C 1 Gas Explosion Overpressure for Cogeneration plant






Figure C 2 Ethanol Vapour Explosion Overpressure for the Molecular Sieve

Table C 2 Summary of Explosion Consequences

Descriptor	Inventory (kg)	Confined Strength	Confined Volume (m ³)	Distances to Overpressure (m)		
				21 kPa	14 kPa	7 kPa
Cogeneration Plant	5000	5	600	-	24	44
Molecular Sieve	10240	7	200	53	70	110

Appendix D

Frequency Analysis

D I Parts Count

D II Leak Size Group

D III Failure Frequencies

D IV Probability of Ignition

D V Event Trees

Frequency Assessment

This Appendix describes the leak frequencies employed by GHD as the basis for determining the relative likelihood of releases from the process in the ethanol plant and gas line at the boiler.

Leak frequency data is an essential requirement of Quantitative Risk Assessments (QRAs). A wide variety of data sets exist and the findings of a risk analysis are highly dependent upon the data that is employed. During the 1990s, the offshore process industry in the North Sea made the most comprehensive collection of leak frequency data that is currently available in any industry, and this has now become the standard data source for offshore risk analyses (HSE 2005). After careful consideration of the strengths and limitations of different data sources, and the expected differences in leak frequencies in offshore and onshore industries, GHD has concluded that it is appropriate to use the high-quality *offshore* data for *onshore* QRAs with very few exceptions, until verifiable onshore experience becomes available. The relevant arguments are summarised below.

The UK Health & Safety Executive data cover a large population of equipment over a considerable period of time, providing a valid statistical basis for estimating the frequency with which different sizes of leaks occur. Data previously collected was frequently from indirectly related sources, inconsistently collected and representative of a poorly defined equipment population – factors which combine to introduce considerable uncertainty. The UK HSE data set was initially collected over 15 years from 1990 – 2005 and is updated every year taking account of some of the most recent technology developments and current industry best practice.

The HSE 2005 data provides a detailed breakdown of hole sizes for individual equipment items. Different size leaks occur more or less frequently than others. For example, full bore rupture is expected to occur much less frequently than a pin hole size leak. Given the data is categorised into different leak sizes, an accurate calculation can be made of leak frequencies for various hole sizes.

The operating environment that offshore equipment operates in is harsher than the environment that the onshore plant equipment is used in. The offshore environment frequently has more sand or other impurities in the process streams than onshore plants, which can lead to corrosion / erosion leaks. Moreover, the salt water environment means the atmosphere is also more corrosive. In addition to this, the closely spaced nature of an offshore plant can lead to increased leaks from eg collisions / impact. However, the HSE data set on leak causes shows that corrosion / erosion is a minor contributor, with operational / procedural faults and mechanical defects being the primary causes.

D I Parts Count

In order to estimate the leak frequency, a parts count is required to identify all pieces of equipment and associated fittings where a release could potentially occur. Within each section, the number of valves, flanges, lengths of pipe, vessels etc and their individual sizes are counted. For each type of equipment, selected failure data is used to aggregate the release frequency into a hole size distribution, specific to the facility. The frequency of release size is then summed for all the parts in an identified section prior to location on the study grid.

The parts count for the ethanol system and gas system are given in Table D 1.

Table D 1 Parts Count for Ethanol and Gas Leak

	E1	E2	E3	E4	E5	E6	E7	E8
Tank	7							
Loading Arm		2						
Loading Hoses		2						
Flange100		10						
MV100		5						
AV100		2						
Vessels (Mol Sieve ¹)			4		3			
Heat Exchangers			6					
Pump			3	2	1			
Pipe75 (m)						20		20
Flange75						5		5
MV75						4		4
AV75						2		2
Pipe50 (m)							50	
AV50							2	
MV50							5	
Flange50							10	

1. There are 2 mol sieves per set and only one will be on line at any time, hence 4 mol sieves included in the model representing 4 sets of mol sieves.

D II Leak Size Group

This QRA is a preliminary analysis, focussing on offsite affects. Therefore only events which can impact offsite are included. Small releases will only have local effects, and are not included in this analysis. This analysis only consider releases of 5 mm or greater. In this Appendix, leak frequencies are given for representative hole sizes, as shown in Table D 2. The nominal size for each leak size range is the suggested size of a hole to be used in discharge and consequence modelling.

Table D 2 Leak Size Groups

Range	Nominal Size
< 5 mm	Small
5–25mm	Medium
25-50	Medium to Large
50 -100 mm	Large
> 100 mm	Catastrophic

D III Failure Frequencies

The failure frequencies used for components in this QRA is given in Table D 3.

Table D 3 Failure Frequencies

	5mm	25mm	50mm	100mm	Rupture
Hose	9.0E-06	9.0E-06	0.00	1.8E-06	0.00
Loading Arm	0.00	0.00	4.6E-05	0.00	5.1E-06
Vessel	1.7E-03	6.4E-04	4.8E-04	1.1 E-04	2.1E-04
Tank	1.3E-03	1.6E-04	8.0E-04	0.00	1.6E-04
Pipe100	5.4E-05	4.1E-06	3.1E-06	6.8E-07	0.00
Flange100	5.1E-05	3.1E-06	2.6E-06	2.6E-06	0.00
MV100	8.3E-05	1.8E-05	1.1E-05	0.00	0.00
AV100	6.8E-04	6.0E-05	5.0E-05	9.4E-06	0.00
Pipe75	2.0E-04	2.5E-05	1.1E-05	2.3E-06	0.00
Flange75	3.2E-05	3.0E-06	3.0E-06	2.7E-07	0.00
MV75	8.3E-04	1.8E-05	1.1E-05	0.00	0.00
AV75	6.8E-04	6.0E-05	5.0E-05	9.4E-06	0.00
Pump-C	7.9E-03	5.9E-04	7.4E-05	0.00	0.00

The parts count data in Table D 1 is then combined with the failure frequencies in Table D 3 to give a total leak frequency for each section given in Table D 4 and the frequency of occurrence of each hole size within each section.

Table D 4 Failure Frequency of the Hazardous Events

Event	Scenario	5mm (/yr)	25mm (/yr)	50mm (/yr)	100mm (/yr)	Rupture (/yr)
E1	Ethanol Tank (Tank farm)	9.0E-03	1.12E-03	5.62E-03	0.00	1.12E-03
E2	Loading Bay	2.81E-03	3.0E-04	3.02E-04	5.6E-05	1.02E-05
E3	Mol Sieve	1.1E-05	1.8E-04	0.00	1.94E-05	1.3E-05
E4	Ethanol loading pump	1.57E-02	1.18E-03	1.47E-04	0.00	0.00
E5	Distillation Unit	9.6E-03	1.2E-03	5.5E-04	1.1E-04	2.1E-04
E6	Gas Fired Boiler No 2	5.85E-03	7.02E-04	3.84E-04	0.00	0.00
E7	Cogen plant	1.09E-02	1.4E-03	5.83E-04	0.00	0.00
E8	Proposed Gas Fired Boiler	5.85E-03	7.02E-04	3.84E-04	0.00	0.00

D IV Failure Frequency of Loading Operation

The ethanol loading operation will double as a result of doubling in the ethanol production. The likelihood of release of ethanol during the loading operation as a result of human factors has been calculated as given in Table D 5 below.

Table D 5 Failure Frequency due to Operational Factors

	Target Production	300,000,000	L	pa	
		5,769,231	L/week		
		824,176	L/day		
	B-Double Capacity	50,000	L		
	Single Capacity	34,000	L		
	14 B-Doules/day	700,000	L		
	4 single	136,000	L		
		836,000	L		
	No of B Double Operation pa	5096	pa		
	No of Single Operation pa	1456	pa		
	Total Operation pa	6552	pa		
	Initiating Frequency	6552	/yr		
Human Error	Completely familiar, well designed, highly practised routine task, oft-repeated and performed by well-motivated, highly trained individual with time to correct failures but without significant job aids.	0.0004			
	Minor leaks	2.62	/yr	5	months
	Major Leak (1 in 100 operations resulting in major leak)	0.026	/yr	38	yrs
Failure Freq - human factors	Large pool of ethanol in loading bay	2.62E-02		38	yrs

NB: Human Error Frequency obtained from: James Reason; Human Error, Cambridge University Press, Cambridge, 1990, p.63-65.

D V Probability of Ignition

The probability of ignition as given by Cox, Less and Ang [1] was used in calculating the frequencies for fire and explosion, these probabilities are:

Table D 6 Ignition probability of flammable materials

	Gas	Liquid
Minor Leak (< 1kg/s)	0.01	0.01
Major Leak (1-50 kg/s)	0.07	0.03
Massive Leak (>50 kg/s)	0.3	0.08

Table D 7 Probability of Explosion

	Probability of Explosion
Minor Leak (< 1kg/s)	0.04
Major Leak (1-50 kg/s)	0.12
Massive Leak (>50 kg/s)	0.3

Reference:

Lees F. P., Loss Prevention in the Process Industries, 2nd Edition, 1996.

GHD Pty Ltd ABN 39 008 488 373

180 Lonsdale Street

Melbourne, Victoria 3000

T: (03) 8687 8000 F: (03) 8687 8111 E: melmail@ghd.com.au

© **GHD Pty Ltd 2008**

This document is and shall remain the property of GHD Pty Ltd. The document may only be used for the purposes for which it was commissioned and in accordance with the Terms of Engagement for the commission. Unauthorised use of this document in any form whatsoever is prohibited.

Document Status

Rev No.	Author	Reviewer		Approved for Issue		
		Name	Signature	Name	Signature	Date
0	Pilar Gallardo & Raj Chatiar	Chris Griffioen				12/05/08
1	Pilar Gallardo & Raj Chatiar	Chris Griffioen	*	James Ellaway	*	11/8/08

* Denotes Signature