


Appendix 6

Supporting Documentation

- A Correspondence from DPI-MR Regarding
Licencing of the Gas Flow Line
- B Technical Description of Genset
- C Noise Measurements of a Gas
Compressor

(No. of pages excluding this page = 19)



Appendix 6A

Correspondence from DPI-MR Regarding Licencing of the Gas Flow Line

(No. of pages excluding this page = 1)



OUT07/8013

RECEIVED
05 OCT 2007

Mr Dennis Morton
Managing Director
Eastern Star Gas Limited
GPO Box 4526
SYDNEY NSW 2001

Dear Mr Morton

Thank you for your letter of 24 July 2007 to Mr Barry Buffier, Director-General, Department of Primary Industries, concerning the Narrabri Coal Seam Gas Gathering Infrastructure. The Director-General has asked me to respond to you on his behalf.

The gas gathering pipeline proposed within your Petroleum Assessment Lease Application No 3 (PALA 3) is not a 'distribution pipeline' under the *Gas Supply Act 1996*. As the pipeline is to be constructed for conveying petroleum for the purposes of recovery of petroleum it is not subject to the *Pipelines Act 1967*. As such, the proposed gas gathering pipeline may be constructed under the *Petroleum (Onshore) Act 1991* on the basis that it is a low pressure pipeline which is not a prescribed pipeline under the *Pipelines Act 1967*.

Any title granted in satisfaction of PALA 3 will include conditions pertaining to the design, installation, operation and removal of the gas gathering pipeline.

Yours sincerely

Alan Coutts
Deputy Director-General

02 OCT 2007

Appendix 6B

Technical Description of Genset

(No. of pages excluding this page = 10)



Technical Description

Genset

JGS 620 GS-S.L

Eastern Star Wilga Park

Electrical output

3039 kW el.

Emission values

NOx < 400 mg/Nm³ (5% O₂)



0.01 Technical Data (at genset)	4
Main dimensions and weights (at genset)	5
Connections	5
Output / fuel consumption	5
0.02 Technical data of engine	6
Thermal energy balance	6
Exhaust gas data	6
Combustion air data	6
Sound pressure level	7
Sound power level	7
0.03 Technical data of generator	8
Reactance and time constants	8
connection variant 1K	9
0.05 Cooling water circuit	10
Oil - heat (Engine jacket water cooling circuit)	10
Engine jacket water - heat (Engine jacket water cooling circuit)	10
Mixture Intercooler (1st stage) (Engine jacket water cooling circuit)	10
Mixture Intercooler (2nd stage) (Low temperature circuit)	10
0.10 Technical parameters	11
1.00 Scope of supply - Genset	12
1.01 Spark ignited gas engine	12
1.01.01 Engine design	12
1.01.02 Engine accessories	13
1.01.02 Engine accessories – Commissioning spare parts	14
1.01.03 Standard tools (1/plant)	14
1.02 Generator-medium voltage	15
1.03 Module accessories	15
1.03.01 Engine jacket water system	17
1.03.02 Automatic lube oil replenishing system	17
1.05 Gas train	18
1.07 Painting	18
1.11 Engine generator control panel – DIA.NE XT	19
1.11.03 Remote Data-Transfer with DIA.NE XT - HERMES	23
1.20.01 Starting system	26
1.20.03 Electric jacket water preheating	26
1.20.04 Flexible connections	27
2.00 Electrical equipment	27



2.03.02 Power control	27
4.00 Delivery, installation and commissioning	28
4.01 Carriage	28
4.02 Unloading	28
4.03 Assembly and installation	28
4.04 Storage	28
4.05 Start-up and commissioning	28
5.02 Factory tests and inspections	28
5.02.01 Engine tests	28
5.02.02 Generator tests	28
5.02.03 Module tests	28
5.03 Documentation	29



0.01 Technical Data (at genset)

Data at:			Full Part Load		
			load		
Fuel gas LHV		kWh/Nm ³	9,5		
			100%	75%	50%
Energy input		kW	[2] 7.195	5.560	3.925
Gas volume		Nm ³ /h	*) 757	585	413
Mechanical output		kW	[1] 3.119	2.339	1.559
Electrical output		kW el.	[4] 3.039	2.275	1.504
Heat to be dissipated			[5]		
~ Intercooler 1st stage (Engine jacket water cooling circuit)		kW	597		
~ Intercooler 2nd stage (Low temperature circuit)		kW	273		
~ Lube oil (Engine jacket water cooling circuit)		kW	337		
~ Jacket water		kW	547		
~ Surface heat	ca.	kW	[7] 274		
~ Balance heat		kW	72		
Spec. fuel consumption of engine		kWh/kWh	[2] 2,31	2,38	2,52
Lube oil consumption	ca.	kg/h	[3] 0,94	~	~
Electrical efficiency		%	42,2%	40,9%	38,3%

*) approximate value for pipework dimensioning
 [] Explanations: see 0.10 - Technical parameters

All heat data is based on standard conditions according to attachment 0.10. Deviations from the standard conditions can result in a change of values within the heat balance, and must be taken into consideration in the layout of the cooling circuit/equipment (intercooler; emergency cooling; ...). In the specifications in addition to the general tolerance of +/- 8% on the thermal output a further reserve of 10% is recommended for the dimensioning of the cooling requirements.



Main dimensions and weights (at genset)

Length	mm	~ 8.900
Width	mm	~ 2.200
Height	mm	~ 2.800
Weight empty	kg	~ 29.700
Weight filled	kg	~ 30.700

Connections

Jacket water inlet and outlet	DN/PN	100/10
Exhaust gas outlet	DN/PN	600/10
Fuel gas (at gas train)	DN/PN	100/16
Fuel Gas (at genset)	DN/PN	100/10
Water drain ISO 228	G	½"
Condensate drain	mm	18
Safety valve - jacket water ISO 228	DN/PN	2x1½"/2,5
Lube oil replenishing (pipe)	mm	28
Lube oil drain (pipe)	mm	28
Jacket water - filling (flex pipe)	mm	13
Intercooler water-Inlet/Outlet 1st stage	DN/PN	100/10
Intercooler water-Inlet/Outlet 2nd stage	DN/PN	65/10

Output / fuel consumption

ISO standard fuel stop power ICFN	kW	3.119
Mean effe. press. at stand. power and nom. speed	bar	20,00
Fuel gas type		Coal Bed Methane
Based on methane number Min. methane number	MZ d)	94 80
Compression ratio	Epsilon	11,00
Min. fuel gas pressure for the pre chamber	bar	3,3-4,0
Min./Max. fuel gas pressure at inlet to gas train	mbar	80 - 200 c)
Allowed Fluctuation of fuel gas pressure	%	± 10
Max. rate of gas pressure fluctuation	mbar/sec	10
Maximum Intercooler 2nd stage inlet water temperature	°C	40
Spec. fuel consumption of engine	kWh/kWh	2,31
Specific lube oil consumption	g/kWh	0,30
Max. Oil temperature	°C	80
Jacket-water temperature max.	°C	95
Filling capacity lube oil (refill)	lit	~ 765

c) Lower gas pressures upon inquiry
d) based on methane number calculation software AVL 3.1



0.02 Technical data of engine

Manufacturer		GE Jenbacher
Engine type		J 620 GS-E02
Working principle		4-Stroke
Configuration		V 60°
No. of cylinders		20
Bore	mm	190
Stroke	mm	220
Piston displacement	lit	124,75
Nominal speed	rpm	1.500
Mean piston speed	m/s	11,00
Length	mm	5.542
Width	mm	1.900
Height	mm	2.540
Weight dry	kg	12.000
Weight filled	kg	13.000
Moment of inertia	kgm ²	69,21
Direction of rotation (from flywheel view)		left
Flywheel connection		SAE 24"
Radio interference level to VDE 0875		N
Starter motor output	kW	30
Starter motor voltage	V	24

Thermal energy balance

Energy input	kW	7.195
Intercooler	kW	870
Lube oil	kW	337
Jacket water	kW	547
Exhaust gas total	kW	2.055
Exhaust gas cooled to 180 °C	kW	1.202
Exhaust gas cooled to 100 °C	kW	1.645
Surface heat	kW	194
Balance heat	kW	72

Exhaust gas data

Exhaust gas temperature at full load	°C [8]	390
Exhaust gas mass flow rate, wet	kg/h	18.531
Exhaust gas mass flow rate, dry	kg/h	17.368
Exhaust gas volume, wet	Nm ³ /h	14.603
Exhaust gas volume, dry	Nm ³ /h	13.208
Max.admissible exhaust back pressure after engine	mbar	60

Combustion air data

Combustion air mass flow rate	kg/h	18.013
Combustion air volume	Nm ³ /h	13.934
Max. admissible pressure drop in front of intake-air filter	mbar	10

basis for exhaust gas data: natural gas: 100% CH₄; biogas 65% CH₄, 35% CO₂



Sound pressure level

Aggregate b)		dB(A) re 20µPa	101
31,5	Hz	dB	88
63	Hz	dB	95
125	Hz	dB	101
250	Hz	dB	99
500	Hz	dB	94
1000	Hz	dB	93
2000	Hz	dB	92
4000	Hz	dB	94
8000	Hz	dB	95
Exhaust gas a)		dB(A) re 20µPa	123
31,5	Hz	dB	112
63	Hz	dB	121
125	Hz	dB	131
250	Hz	dB	119
500	Hz	dB	117
1000	Hz	dB	118
2000	Hz	dB	117
4000	Hz	dB	112
8000	Hz	dB	98

Sound power level

Aggregate		dB(A) re 1pW	122
Measurement surface		m ²	144
Exhaust gas		dB(A) re 1pW	131
Measurement surface		m ²	6,28

a) average sound pressure level on measurement surface in a distance of 1m according to DIN 45635, precision class 2.
 b) average sound pressure level on measurement surface in a distance of 1m (converted to free field) according to DIN 45635, precision class 3.
 Operation with 1200 rpm see upper values, operation with 1800 rpm add 3 dB to upper values.
 Engine tolerance ± 3 dB



0.03 Technical data of generator

Manufacturer		AVK e)
Type		DIG 140 k/4 e)
Type rating	kVA	4.000
Driving power	kW	3.119
Ratings at p.f. = 1,0	kW	3.039
Ratings at p.f. = 0,8	kW	3.013
Rated output at p.f. = 0,8	kVA	3.766
Rated current at p.f. = 0,8	A	198
Frequency	Hz	50
Voltage	kV	11
Speed	rpm	1.500
Permissible overspeed	rpm	2.250
Power factor lagging		0,8 - 1,0
Efficiency at p.f. = 1,0	%	97,4%
Efficiency at p.f. = 0,8	%	96,6%
Moment of inertia	kgm ²	190,00
Mass	kg	10.300
Radio interference level to VDE 0875		N
Construction		IMB 24
Protection Class		IP 23
Insulation class		F
Temperature (rise at driving power)		F
Maximum ambient temperature	°C	40
Total harmonic distortion	%	5,0

Reactance and time constants


xd direct axis synchronous reactance	p.u.	1,88
xd' direct axis transient reactance	p.u.	0,26
xd'' direct axis sub transient reactance	p.u.	0,16
Td''' sub transient reactance time constant	ms	40
Ta Time constant direct-current	ms	80
Tdo' open circuit field time constant	s	3,80

e) GE Jenbacher reserves the right to change the generator supplier and the generator type. The contractual data of the generator may thereby change slightly. The contractual produced electrical power will not change.

EASTERN STAR J 620 GS-E02

Engine jacket water cooling circuit (calculated with Glykol 37%)

Heat to be dissipated = 1,461 kW
(Excludes CO₂ reserve to each requirement)
Engine jacket water flow rate = 71,3 m³/h



Low temperature circuit (calculated with Glykol 37%)

Heat to be dissipated = 273 kW
(Excludes CO₂ reserve to each requirement)
Cooling water flow rate = 40,0 m³/h



0.05 Cooling water circuit

Oil - heat (Engine jacket water cooling circuit)

Nominal output	kW	337
Max. Oil temperature	°C	80
Nominal pressure of engine jacket water	bar	10
Loss of nominal pressure of engine jacket water	bar	0,40
Safety valve - max press. set point	bar	2,50

Engine jacket water - heat (Engine jacket water cooling circuit)

Nominal output	kW	547
Max. engine jacket water temperature (outlet engine)	°C	90
Engine jacket water flow rate	m³/h	71,3
Safety valve - max press. set point	bar	2,50

Mixture Intercooler (1st stage) (Engine jacket water cooling circuit)

Nominal output	kW	597
Max. inlet cooling water temp. (intercooler)	°C	74,6
Nominal pressure of cooling water	bar	10
Loss of nominal pressure of engine jacket water	bar	0,50
Safety valve - max press. set point	bar	2,50

Mixture Intercooler (2nd stage) (Low temperature circuit)

Nominal output	kW	273
Max. inlet cooling water temp. (intercooler)	°C	40
Aftercooler water flow rate	m³/h	40,0
Nominal pressure of cooling water	bar	10
Intercooler water pressure drop	bar	0,60
Safety valve - max press. set point	bar	2,50

Appendix 6C

Noise Measurements of a Gas Compressor

(No. of pages excluding this page = 4)

Faszer
Farquharson
& ASSOCIATES LTD.

Consultants in Acoustics
& Noise Control

May 8, 2001

Mr. Greg Holden
JIRO Manufacturing Ltd.
Box 1450
Stettler, Alberta
T0C 2L0

Dear Mr. Holden:

**Re: JIRO Model 8400 Caterpillar 3306NA Engine Driven Compressor
Noise Impact Assessment
FFA File 101-382-02**

JIRO Manufacturing Ltd. (JIRO) wished to determine the environmental noise impact of their Model 8400 engine driven portable compressor unit, and retained Faszer Farquharson & Associates Ltd. Consultants in Acoustics & Noise Control to conduct this assessment. Clients using the JIRO Model 8400 engine driven portable compressor unit can use this information as a general guide for determining compliance with the Alberta Energy and Utilities Board (EUB) Noise Control Directive ID 99-8 (Directive).

On March 14, 2001, Mr. Peter Davis of Faszer Farquharson & Associates conducted sound pressure level measurements of the significant noise sources associated with the JIRO Model 8400 engine driven portable compressor unit at JIRO's manufacturing facility in Stettler, Alberta. The unit tested was fitted with a Noise Solutions Inc. engine exhaust silencer. A Caterpillar Model 3306NA engine drove the compressor unit. The engine was noted as operating at 1800 rpm during the test. The sound pressure level measurements were conducted with a Brüel & Kjær Model 2260 Real Time Analyzer. The sound measurement system was field calibrated with a Brüel & Kjær Model 4231 calibrator at the commencement of the measurements and then checked upon the completion. The Brüel & Kjær Model 2260 measures the 1/3 octave band sound level and the overall sound level. Octave band sound pressure levels were calculated from the 1/3 octave band spectra and are presented in Table 1.

Table 1
JIRO Model 8400 Compressor Unit
Sound Pressure Levels

Measurement Description	Sound Pressure Level (dBA)									Sum (dBA)
	Octave Band Centre Frequency (Hz)									
	31.5	63	125	250	500	1000	2000	4000	8000	
Building Air Inlet (Right)	88.5	97.0	101.8	103.0	102.7	103.4	97.5	93.0	50.0	106.4
Building Air Inlet (Left)	83.7	88.5	93.6	101.0	99.2	100.9	96.7	92.3	50.0	104.2
Open Doors	83.4	91.5	98.1	100.1	99.0	98.4	94.9	92.7	50.0	102.7
Cooler Outlet	91.8	90.5	96.3	102.9	96.7	97.8	95.0	88.2	78.9	102.1
Engine Exhaust Silencer Shell	80.9	110.2	116.0	82.3	76.2	72.9	77.5	77.7	66.9	100.1
Building	79.1	96.5	102.7	95.2	83.4	78.4	74.5	68.6	52.9	90.6
Engine Exhaust	81.3	97.8	103.5	86.6	74.1	70.2	70.8	72.3	65.5	88.4

FFA File 101-382-02

To evaluate the environmental noise impact of the portable compressor unit, the sound power level of each significant noise source was determined from the sound pressure level measurements. Faszzer Farquharson & Associates used accepted acoustical engineering evaluation methods for the determination of sound power levels from sound pressure levels for large machinery. The calculated sound power levels for the JIRO Model 8400 engine driven portable compressor are presented in Table 2.

Table 2
JIRO Model 8400 Compressor Unit
Sound Power Levels

Source Description	Sound Power Level (dB re: 10 ⁻¹² W)									Sum (dBA)
	Octave Band Centre Frequency (Hz)									
	31.5	63	125	250	500	1000	2000	4000	8000	
Open Doors	86.7	94.8	101.4	103.3	102.3	101.7	98.2	96.0	53.3	106.0
Building	93.8	111.2	117.4	109.9	98.1	93.1	89.2	83.3	67.6	105.3
Engine Exhaust Silencer Shell	85.6	114.8	120.6	86.9	80.9	77.5	82.1	82.3	71.5	104.7
Cooler Outlet	93.1	91.8	97.6	104.2	98.0	99.1	96.3	89.5	80.2	103.4
Open Windows	83.0	91.1	97.7	99.6	98.5	97.9	94.5	92.2	49.5	102.3
Building Air Inlet (Right)	84.0	92.6	97.3	98.5	98.3	99.0	93.1	88.6	45.6	102.0
Building Air Inlet (Left)	79.3	84.1	89.2	96.5	94.8	96.5	92.3	87.9	45.6	99.8
Engine Exhaust	86.3	102.7	108.5	91.6	79.1	75.1	75.8	77.3	70.5	93.4

FFA File 101-382-02

The sound power level values, along with information regarding a typical layout for the unit and the meteorological conditions of interest, were incorporated into ENM, a leading environmental noise assessment software package from RTA Technology Pty. Ltd. The modelling was undertaken using calm conditions and a 5.0 kph wind from the portable compressor unit to the point of reception, a temperature of +25° C and a relative humidity level of 50%. The JIRO Model 8400 portable compressor unit was situated on a short grass covered plain for the purposes of this assessment.

The results of the modelling for a calm wind condition along with a 5.0 kph wind from the JIRO Model 8400 portable compressor unit to the points of reception are presented in Table 3.

Table 3
JIRO Model 8400 Compressor
Predicted Facility Sound Levels

Distance from Unit (metres)	Predicted Sound Pressure Level	
	Calm Wind Condition (dBA)	5.0 kph Downwind Condition (dBA)
50	69.4	69.6
100	63.1	63.6
200	55.3	55.8
300	49.9	50.5
400	45.9	46.6
500	42.7	43.6
600	40.2	41.2
700	38.0	39.1
1500	27.1	28.2

FFA File 101-382-02

The modelling results for the calm condition are presented as noise contour values in the attached Figure 1.

Faszer Farquharson & Associates Ltd. recommends that the modelled sound level results should only be used as a guide for determining the noise impact of this portable compressor unit to the community. Environmental factors such as wind velocity and direction, terrain type and changes in facility operating conditions will effect the propagation of sound.

Should you have any questions regarding this matter or require additional information please contact the undersigned at your convenience.

Sincerely,

Faszer Farquharson & Associates Ltd.



James Farquharson, CET

Attachment

Faszer
arquharson
& ASSOCIATES LTD.

Consultants in Acoustics
& Noise Control

Figure 1
Noise Contours (dBA)
Enhanced Recovery Systems
Model 8400



This page has intentionally been left blank