

Memorandum

ARUP

To	Joe Romeo (Laing O'Rourke) Perry Milledge (Laing O'Rourke)	Date 31 August 2011
Copies	Robert Saidman; Rudolph Chan; Greg Kalisz ;Jacky Chan	Reference number 0005 Memo
From	Greg Kalisz	File reference 221811
Subject	100 Mount Street Utility Status	

This memo provides a summary of the status of discussions with each of the utilities suppliers as of the 31st August 2011-08-31:

Utility Name	Utilities Provided	Status
Sydney Water	Cold Water	Cold water mains confirmed available in Walker Street, and Mount Street. Connection proposed in Walker Street subject to design development and approval by Sydney Water.
	Sewer	Sewer mains confirmed available in Mount Street, Spring Street and Walker Street. Connection location subject to design development and approval by Sydney Water.
North Sydney Council	Stormwater	Stormwater main located adjacent to development in Mount Street. Connection subject to design development and approval by North Sydney Council
Jemena	Natural Gas	Gas main confirmed available in Mount Street, Walker Street and Spring Street. Application made for connection to Walker Street, awaiting formal response.
Ausgrid	Electricity	Application for approval of current building demand sent to Ausgrid. Application acknowledged, awaiting formal response.