

TABLE OF COMPLIANCE WITH RESIDENTIAL FLAT DESIGN CODE

SEPP 65 CODE REQUIREMENT	COMMENT
PART 01 – LOCAL CONTEXT	
Building depth	
<p><i>In general an apartment building of a maximum depth of 18 metres is appropriate.</i></p>	<p>Complies</p> <p>The proposed building depth is between 17.3 and 21.6m, and is consistent with the original approval.</p> <p>Locally building is increased to 24.6 m. Increase as a result of incorporating Approved Plan SK- 010.</p>
Building Separation	
<p><u>Up to 4 storeys</u></p> <ul style="list-style-type: none"> ▪ 12m between habitable rooms/ balconies ▪ 9 m between habitable/balconies & non habitable ▪ 6m between non habitable <p><u>5 to 8 storeys</u></p> <ul style="list-style-type: none"> ▪ 18m between habitable rooms/ balconies ▪ 13 m between habitable/balconies & non habitable ▪ 9m between non habitable <p><u>9 storeys & above</u></p> <ul style="list-style-type: none"> ▪ 24m between habitable rooms/ balconies ▪ 18 m between habitable/balconies & non habitable ▪ 12m between non habitable 	<p>Complies</p> <p>The residential tower is not located adjacent to any residential dwellings or residential flat buildings. The closest residential flat building is located to the south – east of the proposed residential tower.</p>



TABLE OF COMPLIANCE WITH RESIDENTIAL FLAT DESIGN CODE

SEPP 65 CODE REQUIREMENT	COMMENT
PART 02 – SITE DESIGN	
Site Analysis	
<i>A detailed site analysis is to accompany development proposals.</i>	Complies A site analysis plan is enclosed with the Architectural Plan. A-0002 Revision C.
Deep Soil Zones	
<i>A minimum of 25% of the open space area shall be deep soil zones. Exemptions may be made in urban areas where sites are built out and there is no capacity for water infiltration.</i>	Complies Revised relative to the original approval The site is in a dense urban environment the basement car parking will be provided below to the site to meet the parking requirements, Over 1200sqm of open space will be provided in the public area on the site .A large additional landscaped area is located above the podium.
Fences and Walls	
<i>Fences and walls should be designed to define the boundaries between the development, provide privacy and security and contribute positively to the public domain.</i>	Complies The public domain area is defined on the Ground Floor Plan A-0100 Rev C and on the Landscaping Plans.



TABLE OF COMPLIANCE WITH RESIDENTIAL FLAT DESIGN CODE

SEPP 65 CODE REQUIREMENT	COMMENT
Landscape Design	
<p><i>A landscape design should:</i></p> <ul style="list-style-type: none"> ▪ <i>improve the amenity of open space</i> ▪ <i>contribute to the streetscape character</i> ▪ <i>improve the energy efficiency and solar efficiency of the public domain</i> ▪ <i>contribute to the sites characteristics</i> ▪ <i>contribute to water and stormwater efficiency</i> ▪ <i>provide a sufficient depth of soil for planting</i> ▪ <i>minimise maintenance</i> 	<p>Complies</p> <p>Refer to Landscape Plans as enclosed.</p> <p>Note, large area of landscaping additional to original approval above podium.</p>
Open Space Configuration	
<p><i>Area of open space should generally be between 25 – 30% of the site.</i></p> <p><i>Where developments are unable to achieve this, they must demonstrate that the residential amenity is provided in the form of increased private open space.</i></p> <p><i>Minimum area of private open space at ground level shall be 25m². A minimum preferred dimension in one direction is 4m.</i></p>	<p>Complies</p> <p>Revised relative to the original approval. Open Space at ground floor level is provided as per the Ground Floor Plan A-0100 Rev C and on the Landscaping Plans. The private open space is provided in the form of private balconies. As noted above, a significant landscaped area has been incorporated in the open space above the car park podium.</p>
Orientation	
<p><i>In order to achieve better design practise:</i></p> <ul style="list-style-type: none"> ▪ <i>Plan the site to optimise solar access</i> ▪ <i>Select building types or layouts that respond to the streetscape by optimising solar access</i> ▪ <i>Optimise solar access to living spaces</i> ▪ <i>Detail building elements to modify environmental considerations</i> 	<p>Complies</p> <p>Orientation is as per the original approval.</p>



TABLE OF COMPLIANCE WITH RESIDENTIAL FLAT DESIGN CODE

SEPP 65 CODE REQUIREMENT	COMMENT
Planting on Structures	
<p><i>In terms of soil provision there is no minimum standard that can be applied to all situations as the requirements vary with the size of plants and trees at maturity. The following are recommended as minimum standards for a range of plant sizes:</i></p> <p>Large trees such as figs (canopy diameter of up to 16 metres at maturity)</p> <ul style="list-style-type: none"> ▪ <i>Minimum soil volume 150 cubic metres</i> ▪ <i>Minimum soil depth 1.3 metre</i> ▪ <i>Minimum soil area 10 metre x 10 metre area or equivalent</i> <p>Medium trees (8 metre canopy diameter at maturity)</p> <ul style="list-style-type: none"> ▪ <i>Minimum soil volume 35 cubic metres</i> ▪ <i>Minimum soil depth 1 metre</i> ▪ <i>Approximate soil area 6 metre x 6 metre or equivalent</i> <p>Small trees (4 metre canopy diameter at maturity)</p> <ul style="list-style-type: none"> ▪ <i>Minimum soil volume 9 cubic metres</i> ▪ <i>Minimum soil depth 800mm</i> ▪ <i>Approximate soil area 3.5 metre x 3.5 metre or equivalent</i> <p>Shrubs</p> <ul style="list-style-type: none"> ▪ <i>Minimum soil depths 500-600mm</i> <p>Ground cover</p> <ul style="list-style-type: none"> ▪ <i>Minimum soil depths 300-450mm</i> <p>Turf</p> <ul style="list-style-type: none"> ▪ <i>Minimum soil depths 100-300mm</i> <p><i>Any subsurface drainage requirements are in addition to the minimum soil depths.</i></p>	<p>Complies</p> <p>Planting will be carried out in accordance with these minimum requirements.</p>



TABLE OF COMPLIANCE WITH RESIDENTIAL FLAT DESIGN CODE

SEPP 65 CODE REQUIREMENT	COMMENT
Safety	
<p><i>Carry out a formal crime risk assessment for residential development of more than 20 dwellings.</i></p>	<p>Complies</p> <p>Buildings have been designed to reduce blind corners. Extensive Lighting will be provided within the site and entrances will be via an intercom system.</p> <p>All public areas are well lit, surrounded by active retail or commercial areas. All form part of active public links across the site, following pedestrian desire lines to the town centre and railway station.</p>
Building Entry	
<p><i>Building entries should:</i></p> <ul style="list-style-type: none"> ▪ <i>Create entries that provide a desirable residential amenity.</i> ▪ <i>Orientate the visitor.</i> ▪ <i>Contribute positively to the streetscape or building façade design.</i> 	<p>Complies</p> <p>The entrances to the lobbies of each building address the streets with defined points of entry. The residential building is accessed from the main Plaza and the serviced apartment building's main entry is designed with a porte cochere and also has access to plaza .The entries will be clearly identifiable and accessible.</p>
Pedestrian Access	
<p><i>Identify the access requirements from the street or car parking area to the apartment entrance.</i></p> <p><i>Follow the accessibility standard set out in Australian Standard AS 1428 (parts 1 and 2), as a minimum.</i></p> <p><i>Provide barrier free access to at least 20 percent of dwellings in the development.</i></p>	<p>Complies</p> <p>Access is available from the basement parking level and from the street level to both buildings. This is described on the architectural plans enclosed.</p>
Vehicle Access	



TABLE OF COMPLIANCE WITH RESIDENTIAL FLAT DESIGN CODE

SEPP 65 CODE REQUIREMENT	COMMENT
<p><i>Generally limit the width of driveways to a maximum of six metres.(the width of both the right of way and exit ramp to be 6-8m total)</i></p> <p><i>Locate vehicle entries away from main pedestrian entries and on secondary frontages.</i></p>	<p>Complies.</p> <p>The original approval permitted a width of the main entry at 8m wide with the kerb in the middle separating entering and exiting vehicles.</p> <p>Vehicle entry and exit points are located as far as practicable from pedestrian entry points into the building. The location of the driveway does not conflict with the pedestrian network.</p> <p>The width of both the right of way and exit ramp is kept to a minimum. Right of way is 4m wide – to accommodate trucks and the exit/entry from basement is 6.4 wide.</p> <p>The width of the Strep in between accommodating structure of the building above is also kept to a minimum.</p> <p>The proposed revisions to the car parking area disentangle the public, service and residential car park areas, each now provided with its own access and egress point. Accordingly access to the public car park is possible without crossing service areas (as currently approved).</p>



TABLE OF COMPLIANCE WITH RESIDENTIAL FLAT DESIGN CODE

SEPP 65 CODE REQUIREMENT	COMMENT
PART 03 – BUILDING DESIGN	
Apartment Layout	
<p><i>Single-aspect apartments should be limited in depth to 8 metres from a window.</i></p> <p><i>The back of a kitchen should be no more than 8 metres from a window</i></p> <p><i>The width of crossover or cross-through apartments over 15 metres deep should be 4 metres or greater to avoid deep narrow apartment layouts.</i></p> <p><i>The following apartment sizes are provided as a guide:</i></p> <p><i>1 bedroom 50sqm; 2 bedroom 70sqm; and 3 bedroom 95sqm</i></p>	<p>Complies</p> <p>Single aspect apartment with the depth range from 8.1 to 10m.</p> <p>273 apartments - 77.3% with kitchens less than 8m the depth from the back of the kitchen to the window.</p> <p>80 apartments – 22.7% with kitchens more than 8 m the depth from the back of the kitchen to the window.</p> <p>The proposed apartment sizes are as follows:</p> <p>1bed- 59-65sqm</p> <p>2bed- 76-94sqm</p> <p>3bed -107-133sqm</p> <p>The apartment sizes in this development exceed all the minimum sizes.</p>
Balconies	
<p><i>Provide primary balconies for all apartments with a minimum depth of 2 metres. Developments which seek to vary from the minimum standards must demonstrate that negative impacts from the context-noise, wind-can not be satisfactorily mitigated with design solutions.</i></p> <p><i>Require scale plans of balcony with furniture layout to confirm adequate, useable space when an alternate balcony depth is proposed.</i></p>	<p>Complies</p> <p>Balconies with the depth of 2m are provided for all apartments (depth range is 2-2.4m). All apartments have balconies which is an improvement on the original approved design.</p>
Ceiling Heights	

TABLE OF COMPLIANCE WITH RESIDENTIAL FLAT DESIGN CODE

SEPP 65 CODE REQUIREMENT	COMMENT
<p><i>The following recommended dimensions are measured from finished floor level (FFL) to finished ceiling level (FCL). These are minimums only and do not preclude higher ceilings, if desired.</i></p> <p><i>Developments which seek to vary the recommended ceiling heights must demonstrate that apartments will receive satisfactory daylight (eg. Shallow apartments with large amount of window area).</i></p>	<p>Complies</p> <p>The floor to ceiling heights as measured on the architectural plans have a floor to ceiling height of 2.7m in all habitable rooms and 2.4m in all non-habitable rooms.</p>
<p>Ground Floor Apartments</p>	
<p><i>Optimise the number of ground floor apartments with separate entries and consider requiring an appropriate percentage of accessible units.</i></p> <p><i>Provide ground floor apartments with access to private open space, preferably as a terrace or garden.</i></p>	<p>Not Applicable</p> <p>There are no ground floor apartments provided.</p>
<p>Internal Circulation</p>	
<p><i>In general, where units are arranged off a double-loaded corridor, the number of units accessible from a single core / corridor should be limited to eight. Exceptions may be allowed:</i></p> <ul style="list-style-type: none"> ▪ <i>For adaptive reuse buildings;</i> ▪ <i>Where developments can demonstrate the achievement of the desired streetscape character and entry response;</i> ▪ <i>Where developments can demonstrate a high level of amenity for common lobbies, corridors and units (cross over, dual aspect apartments).</i> 	<p>Complies</p> <p>3-8 apartments per core - 29 levels (Levels 4-8,22-45).</p> <p>9 apartments per core - 14 levels 9-21 (Level 9-21, level 46).</p> <p>Previously, 10 apartments per floor, from level 2- 10, approved 10 per floor on levels 6-10.</p>

TABLE OF COMPLIANCE WITH RESIDENTIAL FLAT DESIGN CODE

SEPP 65 CODE REQUIREMENT	COMMENT
Storage	
<p><i>In addition to kitchen cupboards and bedroom wardrobes, provide accessible storage facilities at the following rates:</i></p> <ul style="list-style-type: none"> ▪ <i>One bedroom apartments: 6m³</i> ▪ <i>Two bedroom apartments: 8m³</i> ▪ <i>Three plus bedroom apartments: 10m³</i> <p><i>At least 50% of required storage within each apartment.</i></p>	<p>Complies</p> <p>Storage is provided in each apartment and in the basement in the form of storage cages.</p> <p>1 bedroom apartments – min 3.7m³ within apartment and 3m³ in the Loading Dock/Car Park Level area.</p> <p>2 bedroom apartments – min 4.23m³ within apartment and 4m³ in the Loading Dock/Car Park Level area.</p> <p>3 bedroom apartments - min 5.67m³ within apartment and 5m³ in the Loading Dock/Car Parking level area.</p>
Acoustic Privacy	
<p><i>To ensure a high level of amenity by protecting the privacy of residents within residential flat buildings both within the apartments and in private open spaces.</i></p>	<p>Complies</p> <p>A detailed Noise Impact Assessment Report prepared by Acoustic Logic has been prepared for this submission and is enclosed . The report concludes that the buildings in meeting specifically identified Australian Standards will achieve acoustic privacy within the apartments.</p>
Awnings	
<p><i>To provide shelter for public streets and to ensure signage is in keeping with desired streetscape character and with the development in scale, detail and overall design. .</i></p>	<p>Complies</p> <p>Main building entrance is designed from ground floor covered walkway which has been designed to be fully integrated into the overall design of the building.</p> <p>There is no signage proposed on the facade of the buildings.</p> <p>Refer Architectural Plans which include the photomontages for the building.</p>



TABLE OF COMPLIANCE WITH RESIDENTIAL FLAT DESIGN CODE

SEPP 65 CODE REQUIREMENT	COMMENT
Facades	
<p><i>To provide high architectural quality in residential flat buildings.</i></p> <p><i>To ensure that new developments have facades which define and enhance the public domain and desired street character</i></p> <p><i>To ensure that building elements are integrated into the overall building form and facade design.</i></p>	<p>Complies</p> <p>The facades have been carefully considered to ensure that each building has a clear identity. This is ensured by the sophisticated placement of vertical and horizontal architectural elements, and colours and materials that complement the surrounding buildings and context. Refer to Architectural Plans for drawings showing the Building Elevation, Materials and Finishes images and photomontages of each building.</p>
Roof Design	
<p><i>To provide quality roof designs, which contribute to the overall design and performance of residential flat buildings</i></p> <p><i>To integrate the design of the roof into the overall facade, building composition and desired contextual response.</i></p> <p><i>To increase the longevity of the building through weather protection.</i></p>	<p>Complies</p> <p>The roof designs complement the buildings, and generally have been designed as a flat structure with a slight 'lean to' to provide architectural interest and style into the design. The roof design is both functional and aesthetically pleasing. Refer to Architectural Plans for drawings showing the Building Elevations, Materials and Finishes images and photomontages of each building.</p>
Maintenance	
<p>To ensure long life and ease of maintenance for the development</p>	<p>Complies</p> <p>All Meriton apartments are be managed by an onsite, Site Manager who is available to 24/7 to ensure that the entire development is well maintained and co-ordinated. In addition all relevant contractors, for example waste removal, landscaping etc. are co-ordinated by the Site Manager to ensure that a high standard is maintained and that the development presents to its best advantage at all times.</p>



TABLE OF COMPLIANCE WITH RESIDENTIAL FLAT DESIGN CODE

SEPP 65 CODE REQUIREMENT	COMMENT
Waste Management	
<p><i>To avoid the generation of waste through design, material selection and building practices</i></p> <p><i>To plan for the types, amount and disposal of waste to be generated during demolition, excavation and construction of the development</i></p> <p><i>To encourage waste minimisation, including source separation, refuse and recycling</i></p> <p><i>To ensure efficient storage and collection of waste and quality design of facilities.</i></p>	Complies
Water Conservation	
<p><i>To reduce mains consumption of potable water</i></p> <p><i>To reduce the quantity of urban stormwater run off</i></p>	<p>Complies</p> <p>A comprehensive Environmental Sustainable Development Report prepared by EMF Griffith has been undertaken and is enclosed with this submission.</p>
Daylight Access	
<p><i>Living rooms and private open spaces for at least 70% of apartments in a development should receive a minimum of three hours direct sunlight between 9am and 3pm in mid winter. In dense urban areas a minimum of two hours may be acceptable.</i></p> <p><i>Limit the number of single aspect apartments with a southerly aspect (SW-SE) to a maximum of 10% of the total units proposed. Developments which seek to vary from the minimum standards must demonstrate how site constraints and orientation prohibit the achievement of these standards and how energy efficiency is addressed (see Orientation and Energy Efficiency).</i></p> <p><i>See Apartment Layout for additional rules of thumb.</i></p>	<p>Complies</p> <p>70% of living room spaces receive 2h of direct sunlight between 9.00am and 3pm in mid winter.</p>
Natural Ventilation	
<p><i>Building depths, which support natural ventilation typically range from 10 to 18m.</i></p>	<p>Complies</p> <p>The proposed building depth is between 17.3m and 21.5m and therefore complies.</p>



TABLE OF COMPLIANCE WITH RESIDENTIAL FLAT DESIGN CODE

SEPP 65 CODE REQUIREMENT	COMMENT
<i>60% of residential units should be naturally cross ventilated.</i>	<p>Complies 353 apartments 180 cross ventilated 51%. Previously - Refer to JBA report page 45 we had approximately 50%. Wide frontage included.</p>
<i>25% of kitchens within a development should have access to natural ventilation.</i>	<p>Complies 100% of all kitchens have access to natural ventilation through adjacent living space.</p>

