



To plan_comment@planning.nsw.gov.au

Cc Natasha Harras (Natasha.Harras@planning.nsw.gov.au)

From Jeffrey Crough (JCrough@ausgrid.com.au)

Date Monday 6th August 2012

Subject Environmental Assessment Exhibition - Mixed Use Development at Eastlakes Shopping Centre, Eastlakes (MP09_0146)

Dear Sir / Madam,

I could not access <http://www.majorprojects.planning.nsw.gov.au/> to view project specifics.

Electrical infrastructure exists on the site in question. While Ausgrid has no objections to the proposal, as this proposal develops, Ausgrid will require further information in regards to whether or not it is planned to keep, replace, relocate or remove the existing infrastructure. Ausgrid will also require proposed electrical load calculations in order to determine how to supply this development; which may include the installation of additional electrical infrastructure on the proposed site.

Kind Regards,

Engineer – Planning & Supply Negotiations Sydney City & Eastern Suburbs, **AUSGRID**

Ph: (02) 9663 9221 Fax: (02) 9663 9499 Email: jcrough@ausgrid.com.au