

23 February 2011

Mr Michael Woodland
Director
Metropolitan Projects
Department of Planning
22-33 Bridge Street,
Sydney NSW 2000

Re: MP 09_0165 Sydney Super Yacht Marina, Rozelle Bay

Attention: Michael Buckley

Dear Mr Woodland,

Thank you for your letter about the proposed redevelopment of the land based component of the Sydney Super Yacht Marina at Rozelle Bay. Sydney Water has reviewed the proposal and provides the following comments for the Department's consideration.

Water

The existing water system has capacity to service the proposed development. The developer will need to design and construct a connection to the available 250 mm main located in James Craig Road.

The connection will need to be sized and configured according to the Water Supply Code of Australia (Sydney Water Edition WSA 03-2002). Evidence of Code compliance should be attached with the extension design.

Wastewater

The existing wastewater system has capacity to service the proposed development. The developer will need to design and construct a connection to the available 225 mm main.

The connection will need to be sized and configured according to the Water Supply Code of Australia (Sydney Water Edition WSA 03-2002). Evidence of Code compliance should be attached with the extension design.

Trade Waste

In the event that trade wastewater is generated, the property owner is required to submit an application for permission to discharge trade wastewater to the sewerage system before business activities commence.

If this development type is "Industrial" then the property may be part of a sewerage catchment subject to a wastewater reuse scheme. This may impact the level of pollutants such as Total Dissolved Solids (TDS) that Sydney Water will accept from the property to the sewerage system. Businesses wishing to discharge wastewater (other than domestic sewage) should first contact a Sydney Water Business Customer Representative. The contact number for a Trade Waste Customer Representative is 02 9694 6500.

For further information please visit the Sydney Water website at:
<http://www.sydneywater.com.au/OurSystemsandOperations/TradeWaste/>

Sydney Water Servicing

Sydney Water will further assess the impact of the development when the proponent applies for a Section 73 Certificate. This assessment will enable Sydney Water to specify any works required as a result of the development and to assess if amplification and/or changes to the system are applicable. The proponent must fund any adjustments needed to Sydney Water infrastructure as a result of any development.

The proponent should engage a Water Servicing Coordinator to get a Section 73 Certificate and manage the servicing aspects of the development. The Water Servicing Coordinator will ensure submitted infrastructure designs are sized & configured according to the Water Supply Code of Australia (Sydney Water Edition WSA 03-2002) and the Sewerage Code of Australia (Sydney Water Edition WSA 02-2002).

Sydney Water requests the Department to continue to instruct proponents to obtain a Section 73 Certificate from Sydney Water. Details are available from Sydney Water's website at www.sydneywater.com.au.


Sydney Water e-planning

Sydney Water has created a new email address for planning authorities to use to submit statutory or strategic planning documents for review. This email address is urbangrowth@sydneywater.com.au. The use of this email will help Sydney Water provide advice on planning projects faster, in line with current planning reforms. It will also reduce the amount of printed material being produced. This email should be used for:

- Section 62 consultations under the Environmental Planning and Assessment Act 1979
- consultations where Sydney Water is an adjoining land owner to a proposed development
- Major Project applications under Part 3A of the Environmental Planning and Assessment Act 1979
- consultations and referrals required under any Environmental Planning Instrument
- draft LEPs, SEPPs or other planning controls, such as DCPs
- any proposed development or rezoning within a 400m radius of a Sydney Water Wastewater Treatment Plant
- any proposed planning reforms or other general planning or development inquiries

If you require any further information, please contact Sonia Jacenko of the Urban Growth Branch on 02 8849 4004 or e-mail sonia.jacenko@sydneywater.com.au

Yours sincerely,



Adrian Miller,
Manager of Urban Growth Strategy and Planning