

APPENDIX 11

Advice from Morris Goding Accessibility Consulting

24th January 2011

Julian Ardas
Barangaroo Delivery Authority
Level 21, AON/Maritime Trade Towers
201 Kent Street
Sydney NSW 2000

Dear Julian,

RE: BARANGAROO – CITY OF SYDNEY ACCESSIBILITY RESPONSE

With regards to the City of Sydney Recommendation 31,

1. Way finding maps will be provided at northern and southern access points of the park so that visitors may choose between the alternate accessible routes, that being, the northern 1:20 pathways or the southern passenger lift. In addition directional signage will be employed at relevant points along the foreshore pathway indicating the location of the accessible points/routes.
2. Continuous accessible path of travel will be provided in accordance with AS1428.1-2009 at points of public access between the foreshore pathways. This will occur during design development stage.
3. Accessible paths of travel will be provided to allow access to view the tidal pools. This will occur during design development stage.

Yours faithfully,



David Goding
Morris-Goding Accessibility Consulting