

SOUTH EASTERN SYDNEY  
ILLAWARRA  
**NSW HEALTH**  
DIVISION OF POPULATION HEALTH  
PUBLIC HEALTH UNIT

Mr Kerry Kyriacou  
Manager Development & Assessments  
Randwick City Council  
30 Frances Street  
Randwick NSW 2031

18 November 2010

Dear Mr Kyriacou

**ROYAL RANDWICK RACECOURSE SPECTATOR & STABLES PRECINCT  
REDEVELOPMENT –DA 871/2010 – 77 -97 Alison Road, Randwick NSW 2031**

Thankyou for referring the abovementioned application to the South Eastern Sydney Illawarra Public Health Unit for comment.

Assessment of the documentation was undertaken and the following comments are forwarded for your consideration.

1. The plumbing for the rainwater tanks requires colour coding in accordance with Enhealth Guidelines to prevent cross-connection with the potable water supply especially with respect to the proposed construction of stable residences. The plumbing should also comply with Australian Standard AS/NZS 3500 *NSW Plumbing Code of Practice* –which sets out the variations that meet the requirements of water utilities in Sydney and country areas of NSW.
2. That the water in the horse pool is treated in such a way to prevent disease transmission and insect infestations such as flies and mosquitoes.
3. Copies of any additional contamination reports prepared for the site are forwarded to the Public Health Unit for Human Health Risk Assessment and comment.

Thankyou for your referral. If you have further enquiries, please do not hesitate to contact Mr Mehmet Dariverenli, A/Senior Environmental Health Officer on 9382 –8252 during normal business hours.

Yours sincerely



Prof Mark Ferson MBBS MPH MD FRACP FAFPHM MASM  
Director & Medical Officer of Health