



CUNDALL

4th September 2010

Bungarribee Industrial Estate Sustainability Report

Prepared for

Goodman

Prepared by
CUNDALL

Level 7, 657 Pacific Highway
St Leonards NSW2065
Phone: +61 2 8424 7000
Fax: +61 2 8424 7001

Contact: Tim Elgood

Report	Green House Gas Report	Revision:	C	Date:	04/09/10
<p>Author: Tim Elgood</p> <p>Checker: Rochelle Phillis</p> <p>Approver:</p>					
Revision	Description				Date
A	Draft				10.08.10
B	DA submission draft report				30.08.10
C	Final Report				04.09.10
<p>This report has been prepared in accordance with the terms and conditions of appointment. Cundall Johnston & Partners Pty Ltd trading as Cundall (ABN 16 104 924 370) trading as Cundall cannot accept any responsibility for any use of or reliance on the contents of this report by any third party.</p>					
<p>The success and realisation of the proposed initiatives will be dependant upon the commitment of the design team, the development of the initiatives through the life of the design and also the implementation into the operation of the building. Without this undertaking the proposed targets may not be achieved. The use of computer simulation is by its nature predictive with output based on historic weather data and standard assumptions. The results of any computer simulations within this report do not guarantee future performance.</p>					

Cundall

Level 7, 657 Pacific Highway
St Leonards NSW2065

Tel: (02) 8424 7000

Fax: (02) 8424 7001

ABN: 16 104 924 370

www.cundall.com.au

Contents

1	Executive Summary	1
2	Introduction	3
2.1	The Site and Development	3
2.2	Equipment	3
2.3	Building Occupation.....	4
2.4	Tools and Standards.....	4
2.5	Planning Requirements	4
3	Green Star Strategy	5
4	Carbon reduction strategy	6
4.1	Operational carbon	6
4.2	Embedded carbon	8
4.3	Transport associated	8

1 Executive Summary

The objective of this report is to address the key Director General Requirements for delivering a sustainable Industrial distribution centre, for Metcash, located at the Bungarribee Industrial Estate.

This report outlines the following key elements:

1. A description of how the project will incorporate the principles of sustainability in the design, construction and ongoing operation of the facility.
2. A description of the measures that will be implemented to minimise the energy and water use.
3. Waste reduction strategies throughout construction.

How has the project incorporated the principles of sustainability in the design, construction and ongoing operation of the facility?

A number of key sustainability strategies have been integrated into the design with a formal certification process to measure this performance using the Green Star Industrial tool.


The project has committed to achieving a 4 Green Star rating adopting the following key strategies:

- Improved daylight to warehouse with up to 12% of the roof area as a sky light.
- Daylight controlled fluorescent lighting for the warehouse instead of metal halide, resulting in a considerable energy reduction and reduced maintenance.
- Improved efficiency in the office energy and indoor environmental quality including:
 - High efficiency glazing and shading to optimise daylight and comfort.
 - Carbon dioxide monitoring of the air quality in the office spaces linked to increased fresh air rates through the ventilation system.
 - Manual over ride of natural ventilation in warehouse areas to improve air quality/ amenity.
 - Fresh air heat recovery system for air conditioning.
- Recycled water for all WC flushing, irrigation and truck wash.
- Provision of break out spaces for staff that have high levels of amenity shaded from summer sun and sheltered from prevailing winds.
- Provision of a high level of cycle facilities for staff including showers, changing rooms and a dedicated cycle way from the main entrance to the changing facilities.
- Waste recycling of 80% during construction.

What energy and water strategies have been implemented?

The project has developed a carbon reduction strategy that reduces operational carbon by approximately 40% compared to a current BCA section J compliant development. The project also aims to achieve an 80% of the available water points in Green Star.

- The predicted energy consumption of the facility will be modelled in detail during the design phase of the project and these energy profiles established for each energy source such as lighting, power, air conditioning will be used as the reference base case.
- Energy meters for each major energy source will be specified.
- Energy bills will be reviewed on an annual basis to compare the predicted performance against the actual performance.



The report indicates in detail how the carbon reduction has been assessed using the Green Star energy calculator. The graph above illustrates the operational carbon emissions associated with the proposed Metacash facility in comparison to a BCA section J compliant facility. The methodology used to determine this energy performance is the Green Star energy calculator in the Industrial Green Star tool version V1.

2 Introduction

2.1 The Site and Development

Goodman Limited wish to implement all reasonable and feasible measures to reduce carbon emissions associated with the proposed Metcash NSW Distribution Centre located at the Bungarribee Industrial Estate. Metcash is a leading marketing and distribution company, whom wishes to consolidate their NSW operations to a single distribution centre. This site has been located due to its proximity to the M4 and M7 motorways from which Metcash will best serve their Sydney and NSW customer base.

The development consists of three warehouses with a total warehouse GLA of 91,067m² and approximately 12,000m² of office area.

The project consists of 3 warehouses:

- Warehouse 1 – Large Ambient Warehouse
- Warehouse 2 – Fresh Produce Warehouse
- Warehouse 3 – Perishables Warehouse

2.2 Equipment

The office aims to achieve the equivalent of a minimum NABERS rating of 4.5 stars using the Green Star energy calculator and the overall development aims to achieve a 4 star Green Star certified rating using the industrial tool. Energy and GHG savings are calculated based on a 3.5 star NABERS rated standard building. Process equipment associated with the function of the building have not been included in this report, only equipment associated with the physical attributes of the building are considered, these can be seen below.

- HVAC Warehouse Natural ventilation only
- HVAC Office Improvements in AC controls and zoning with economy cycles
- Lighting T5 54W fluorescent lighting with motion detection and Light level
- Hot water System Natural gas 80% thermal efficiency

WELS Star ratings of all water fittings can be seen below, energy savings are calculated based on 3 star ratings for all fittings.

- Toilets 4 star
- Urinals 4 star
- Taps 4 star
- Shower heads 3 star

2.3 Building Occupation

Metcash work on a shift basis with the following approximate occupancy densities:

Shift Staff					
Shift 1		Shift 2		Shift 3	
Number of staff	Working Hours	Number of staff	Working Hours	Number of staff	Working Hours
160	5am-2pm	170	8.30am-6pm	70	2pm-11pm

2.4 Tools and Standards

Estimates and calculation methods within this report are all sourced from the following tools and standards:

- BCA Section J - Deemed to satisfy
- Green Star Industrial V1
- National Greenhouse Accounts Factors

The National Greenhouse Accounts Factors, as seen in Table 1 below, quantify the GHG emissions associated with one unit of energy. The factors include all direct and indirect emissions and account for not only CO₂ but a number of other significant greenhouse gas emissions.

Table 15: Greenhouse Gas Emissions Factors for all states and territories in Australia from National Greenhouse Accounts (NGA) Factors Workbook (DCC, 2009)

State	Electricity (kgCO ₂ -e /kWh)	Gas (kgCO ₂ -e /MJ)	LPG (kgCO ₂ -e /MJ)	Diesel (kgCO ₂ -e /MJ)	Coal (kgCO ₂ -e /MJ)	Solid Biomass (kgCO ₂ -e /MJ)	Liquid Biofuels (kgCO ₂ -e /MJ)
ACT	1.07	0.0677	0.0649	0.0748	0.0930	0.0018	0.0003
NSW	1.07	0.0677					
NT	0.79	0.0557					
QLD	1.01	0.0548					
SA	0.92	0.0652					
TAS	0.25	0.0557*					
VIC	1.31	0.0558					
WA	0.94	0.0557					

Table 1 National Greenhouse Accounts Factors

2.5 Planning Requirements

The Department of Planning requirements for the project are:

1. Describe the principles of ESD in the design, construction and operation of the facility.
2. Describe the measures to minimise energy and water consumption.

3 Green Star Strategy

The project has a target to achieve a 4 Green Star rating using the Industrial tool. In order to achieve this, provisions are taken in each of the Green Star categories as seen below. (See Appendix 1 for a Green Star credit summary)

- Management
 - Commissioning, handover and tuning initiatives along with a building user's guide will ensure the building services operate optimally after handover, while environmental and waste management practices will be adopted to reduce waste associated with construction.
- Indoor Environmental Quality
 - Increased fresh air rates to the office space and higher levels of daylight levels throughout the facility. Break out spaces with far improved amenity have been provided.
- Energy
 - 40% reduction in carbon emissions through the implementation of energy conservation strategies including;
 - Improved daylight to warehouse with up to 12% of the roof area as a sky light.
 - Daylight controlled fluorescent lighting for the warehouse instead of metal halide, resulting in a considerable energy reduction and reduced maintenance.
 - Improved efficiency in the office energy and indoor environmental quality including:
 - Improved efficiency in the office energy and indoor environmental quality including:
 - High efficiency glazing and shading to optimise daylight and comfort.
 - Carbon dioxide monitoring of the air quality in the office spaces linked to increased fresh air rates through the ventilation system.
 - Manual over ride of natural ventilation in warehouse areas to improve air quality/ amenity.
 - Fresh air heat recovery system for air conditioning.
- Transport
 - This site has been selected by Metcash to minimise carbon emissions associated with transport with the close location to the M4 and M7 motorways from which Metcash readily service their Sydney and NSW customer base. A high level of cyclist facilities with associated showers and changing facilities will be provided.
- Water
 - Occupant consumption of potable water is reduced through the use of water efficient fittings.
 - Rainwater rain water for WC flushing, irrigation and truck wash down.
- Materials
 - Consideration is taken to reduce embodied energy and resource depletion through the use of environmentally responsible materials.
- Land Use & Ecology
 - While the previous site use was agricultural, it was gazetted as a State Significant site in 2007 and rezoned as 'IN1 General Industrial' to promote employment generating uses on the site.
- Emissions
 - On site stormwater detention and water quality measures will ensure the minimisation of peak stormwater flows and pollutants to the municipal sewerage system.

4 Carbon reduction strategy

4.1 Operational carbon

The Metcash NSW Distribution Centre located at the Bungarribee Industrial Estate will incorporate a number of energy minimisation initiatives to reduce Greenhouse gas (GHG) emissions. Energy and greenhouse gas savings are estimated based on a standard practice building.

Key energy efficiency strategies include:

- Improved daylight to warehouse with up to 12% of the roof area as a sky light.
- Daylight controlled fluorescent lighting for the warehouse instead of metal halide, resulting in a considerable energy reduction and reduced maintenance.
- Mixed mode ventilation to the offices.
- Integration of solar electric panels to the office.
- High efficiency glazing and shading for the offices.

Through these measures approximately 40% GHG emission savings can be achieved as seen in Figure 1




Figure 1 Operational Carbon Comparison

The methodology used to determine this energy performance is the Green Star energy calculator in the Industrial Green Star tool version V1.

HVAC

The use of mixed mode ventilation in the office is estimated to reduce HVAC energy consumption by a conservative 20%. Based on a standard office with NABERS rating of 3.5star, an annual saving of 440MWh can be achieved.

Lighting

A 50% lighting energy reduction can be achieved through the use of a fluorescent lighting system linked to daylight performance rather than a typical high intensity discharge system. The use of skylights and a motion detection and light level sensor can achieve a further energy saving of 50%. An energy audit with further calculations can be seen in Appendix 2.

Domestic Hot Water

Annual hot water usage for the site is calculated using the Green Star potable water calculator and can be seen in the Green Star results table below. The BCA specifies the thermal efficiency for hot water systems to be at least 80%, the calculation below also assumes a temperature rise of 40°C.

	Proposed Building	Standard Practice Building
Annual Domestic Hot Water Usage (L/year)	1,494,675	1,609,650

Table 2 Green Star potable water calculator results

An annual reduction of 24,000MJ can be achieved through the use of water efficient fittings as shown in the calculations shown in Appendix 2.

Summary

Energy consumption and savings due to the above mentioned energy efficiency strategies can be seen in Table 3 below. The largest reductions come from energy efficiency measures associated with lighting energy.

Energy consumption	Fuel Type	Standard Building	Proposed Building	Energy savings
HVAC System (MWh)	Electricity	2200	1760	440
Lighting (MWh)	Electricity	4774.2	2171.6	2602.6
Domestic Hot Water	Natural Gas	337.2	313.1	24.1

Table 3 Annual energy consumption


An annual GHG emission reduction of approximately 43.5% can be achieved. GHG emissions are calculated according to the Greenhouse emission factors for NSW.

GHG emissions	Standard Building Tonne CO2e emissions	Proposed Building Tonne CO2e emissions
HVAC System	2354	1883.2
Lighting	5108	2323.6
Domestic Hot Water	22.8	21.2
Annual Savings	3256.8 tonne	43.5 %

Table 4 Annual CO2e emissions

4.2 Embedded carbon

The content of embedded carbon in materials can have an important impact on the 'whole life carbon' of a building. The report 'Redefining Zero' by Sturgis Associates, estimates embedded carbon accounts for 60% of 'whole life carbon' for a warehouse, as operational energy efficiency increases it is suggested that the embedded carbon contribution could increase to 95% with further increases in energy/ carbon targets.



Where possible, materials will be chosen to reduce the embedded carbon of the development. The use of recycled and low embodied energy materials will be utilised to achieve compliance with Materials credits of the Green Star requirements.

4.3 Transport associated

This site has been selected by Metcash to minimise carbon emissions associated with transport with the close location to the M4 and M7 motorways from which Metcash readily service their Sydney and NSW customer base. A high level of cyclist facilities with associated showers and changing facilities will be provided.

Appendix 1: Green Star points

The table below provides an example of the points that can be achieved for the 4 star rating. The individual points might alter in the design development stage but the overall target will be to achieve the 4 Green Star rating.

Category	Title	Credit No.	Points Available	Points Achieved
Management				
	Green Star Accredited Professional	Man-1	2	2
	Commissioning	Man-2	1	1
			1	1
	Building Tuning	Man-3	1	1
	Independent Commissioning Agent	Man-4	1	1
	Building Users' Guide	Man-5	1	1
	Environmental Management	Man-6	3	3
	Waste Management	Man-7	2	2
	Metering	Man-16	2	2
			1	1
		TOTAL	15	15
Indoor Environment Quality				
	Ventilation Rates	IEQ-1	3	3
	Air Change Effectiveness	IEQ-2	2	0
	Indoor Pollutant Monitoring & Control	IEQ-3	1	1
	Daylight	IEQ-4	3	2
	Thermal Comfort	IEQ-5	3	0
	Hazardous Materials	IEQ-6	0	na
	Internal Noise Levels	IEQ-7	2	1
	Volatile Organic Compounds	IEQ-8	1	1
			1	0
			0	na
	Formaldehyde Minimisation	IEQ-9	1	0
	Daylight Glare Control	IEQ-11	1	1
	Electric Lighting Levels	IEQ-13	1	1
	External Views	IEQ-14	2	0
	Air Distribution System	IEQ-17	0	na
	Breakout Space	IEQ-19	2	0
		TOTAL	23	10
Energy				
	Conditional Requirement	Ene-Con	Conditional Requirement	Yes
	Greenhouse Gas Emissions	Ene-1	20	12
	Peak Energy Demand Reduction	Ene-3	2	0
		TOTAL	22	12
Transport				
	Provision of Car Parking	Tra-1	2	1
	Fuel Efficient Transport	Tra-2	1	0
	Cyclist Facilities	Tra-3	2	2
	Commuting Mass Transport	Tra-4	5	0
	Trip Reduction - Mixed Use	Tra-5	2	0
		TOTAL	12	3

Category	Title	Credit No.	Points Available	Points Achieved
Water				
	Occupant Amenity Water	Wat-1	5	5
	Landscape Irrigation	Wat-3	1	1
	Heat Rejection Water	Wat-4	2	1
	Fire System Water Consumption	Wat-5	2	1
		TOTAL	10	8
Materials				
	Recycling Waste Storage	Mat-1	2	1
	Building Re-use	Mat-2	0	NA
	Recycled Content & Re-used Products and Materials	Mat-3	2	0
	Concrete	Mat-4	3	1
	Steel	Mat-5	2	1
	PVC	Mat-6	2	1
	Timber	Mat-7	1	1
	Dematerialisation	Mat-9	1	0
		TOTAL	13	5
Land Use & Ecology				
	Conditional Requirement	Eco-	Conditional Requirement	Yes
	Topsoil	Eco-1	1	0
	Re-use of Land	Eco-2	1	0
	Reclaimed Contaminated Land	Eco-3	2	0
	Change of Ecological Value	Eco-4	4	1
		TOTAL	8	1
Emissions				
	Refrigerant ODP	Emi-1	1	1
	Refrigerant GWP	Emi-2	2	0
	Refrigerant Leaks	Emi-3	2	0
	Insulant ODP	Emi-4	1	1
	Stormwater	Emi-5	3	2
	Discharge to Sewer	Emi-6	4	1
			1	0
	Light Pollution	Emi-7	1	1
	Legionella	Emi-8	1	1
	Noise Pollution	Emi-10	1	0
		TOTAL	17	7
Total weighted points:			52	

Appendix 2 Domestic Hot Water Calculations

$$\text{Annual consumption} = \frac{\text{specific heat capacity water} \times \text{Temperature rise} \times \text{Litres}}{\text{thermal efficiency}}$$

Standard Building Calculation

$$\text{Annual consumption} = \frac{0.00419\text{MJ}/^{\circ}\text{C} \times 40^{\circ}\text{C} \times 1,609,650\text{L}/\text{yr}}{0.80}$$

$$\text{Annual consumption} = 337,221\text{MJ}/\text{yr}$$

Proposed Building Calculation

$$\text{Annual consumption} = \frac{0.00419\text{MJ}/^{\circ}\text{C} \times 40^{\circ}\text{C} \times 1,494,675\text{L}/\text{yr}}{0.80}$$

$$\text{Annual consumption} = 313,134\text{MJ}/\text{yr}$$