



**REVISED PRELIMINARY HAZARD ANALYSIS,
MODIFICATION TO APPROVED GAS FIRED
CO-GENERATION PLANT,
SHOALHAVEN STARCHES,
BOMADERRY, NSW
CONSENT NUMBER: MP 06_0228 MODS 2 AND 23**

*Prepared by: Dean Shewring
4 January 2022*

Pinnacle Risk Management Pty Limited
ABN 83 098 666 703

PO Box 5024 Elanora Heights
NSW Australia 2101
Telephone: (02) 9913 7284
Facsimile: (02) 9913 7930

**Preliminary Hazard Analysis, Shoalhaven Starches,
Co-Generation Plant**

Disclaimer

This report was prepared by Pinnacle Risk Management Pty Limited (Pinnacle Risk Management) as an account of work for Shoalhaven Starches. The material in it reflects Pinnacle Risk Management's best judgement in the light of the information available to it at the time of preparation. However, as Pinnacle Risk Management cannot control the conditions under which this report may be used, Pinnacle Risk Management will not be responsible for damages of any nature resulting from use of or reliance upon this report. Pinnacle Risk Management's responsibility for advice given is subject to the terms of engagement with Shoalhaven Starches.

| Rev | Date | Description | Reviewed By |
|------------|-------------|----------------------------|---------------------|
| A | 21/3/21 | Draft for Comment | Shoalhaven Starches |
| B | 28/8/21 | Final Issue | Shoalhaven Starches |
| C | 31/8/21 | Tables 4 and 5 Updated | Shoalhaven Starches |
| D | 11/12/21 | LP Pipeline Layout Revised | Shoalhaven Starches |
| E | 4/1/22 | Comments on Rev D Included | Shoalhaven Starches |

Contents

| | |
|--|-----------|
| EXECUTIVE SUMMARY..... | 6 |
| GLOSSARY..... | 7 |
| 1 INTRODUCTION | 8 |
| 1.1 Background..... | 8 |
| 1.2 Objectives | 9 |
| 1.3 Scope..... | 9 |
| 1.4 Methodology | 10 |
| 2 SITE DESCRIPTION..... | 10 |
| 3 PROCESS DESCRIPTION | 14 |
| 3.1 Co-Generation Plant..... | 14 |
| 3.1.1 Introduction..... | 14 |
| 3.1.2 Natural Gas Supply | 14 |
| 3.1.3 Steam Export to Site..... | 14 |
| 3.1.4 Condensate | 17 |
| 3.1.5 Make-Up Water | 17 |
| 3.1.6 Electricity Supply | 17 |
| 3.1.7 Electricity Supply - Synchronization..... | 17 |
| 3.1.8 Electricity Supply – Reverse Power Protection..... | 17 |
| 3.1.9 Automatic Control | 17 |
| 3.2 Gas-Fired Boilers 2,4, 5 and 6 Modifications | 18 |
| 4 HAZARD IDENTIFICATION | 21 |
| 4.1 Hazardous Materials..... | 21 |
| 4.2 Potential Hazardous Incidents Review | 22 |
| 5 RISK ANALYSIS | 26 |
| 5.1 Natural Gas Releases – Jet Fires Consequences..... | 28 |

| | |
|--|-----------|
| 5.2 Natural Gas Releases – Flash Fires and Explosions Consequences..... | 29 |
| 5.3 Likelihood and Risk Analysis | 31 |
| 5.4 Propagation and Cumulative Risk | 37 |
| 5.5 Societal Risk | 37 |
| 5.6 Risk to the Biophysical Environment | 37 |
| 6 CONCLUSION AND RECOMMENDATIONS..... | 38 |
| 7 APPENDIX A – METEOROLOGICAL DATA | 39 |
| 8 REFERENCES | 41 |

LIST OF FIGURES

| | |
|--|-----------|
| Figure 1 - Site Locality Plan | 11 |
| Figure 2 - Site Layout | 13 |
| Figure 3 – Co-Generation Plant Layout..... | 15 |
| Figure 4 – Co-Generation Plant Process Flow Schematic | 16 |

LIST OF TABLES

| | |
|--|-----------|
| Table 1 – Boilers Gas and Air Flows | 18 |
| Table 2 – Hazard Identification Word Diagram | 23 |
| Table 3 - Risk Criteria, New Plants | 27 |
| Table 4 – Natural Gas Jet Fires – Boilers | 28 |
| Table 5 – Natural Gas Jet Fires – Co-Generation Plant..... | 29 |
| Table 6 – Effects of Explosion Overpressure | 30 |
| Table 7 - Natural Gas Flash Fires and Vapour Cloud Explosions | 30 |
| Table 8 – Piping Failure Frequencies | 32 |
| Table 9 – Risk Analysis | 34 |
| Table 10 – HIPAP 4 Risk Criteria Compliance..... | 35 |

EXECUTIVE SUMMARY

The Shoalhaven Starches factory located on Bolong Road, Bomaderry, produces a range of products for the food, beverage, confectionary, paper and motor transport industries including starch, gluten, glucose and ethanol.

Shoalhaven Starches propose to construct a new gas-fired co-generation plant which will consist of two natural gas turbines that will generate an anticipated power output each of 30 MW, providing a total power to the site of 60 MW. The new gas fired co-generation plant will replace the approved gas fired and coal fired co-generators. In addition, Shoalhaven Starches also proposed to convert their existing coal fired boilers 2, 4, 5 and 6 to gas as well.

The waste heat from each of the gas turbine exhausts will be used to generate 11 barg steam in two 110 t/hr heat recovery steam boilers. The boilers will be co-fired with natural gas and will be able to operate at full output when the turbines are offline for maintenance.

As part of the project requirements, a Preliminary Hazard Analysis (PHA) is required.

The risks associated with the proposed modifications at the Shoalhaven Starches Bomaderry site have been assessed and compared against the Department of Planning risk criteria.

The results presented in this report show compliance with all risk criteria. **This revision of the report includes the modification to the low pressure natural gas pipe to the existing boilers at the Shoalhaven Starches site. For ease of identifying the changes to the report, all modified text is shown in blue.**

Societal risk, area cumulative risk and environmental risk are also concluded to be acceptable.

The primary reason for the low risk levels from the modifications is the low likelihood of significant pipe failures leading to off-site impact from jet or flash fires, or explosions.

Based on the analysis in this PHA, the following recommendations are made:

1. Provide natural gas leak detection in the proposed co-generation plant building with, at least, an alarm in the control room.
2. Provide an actuated valve on the natural gas supply pipe outside of the co-generation plant building for isolation in an emergency.
3. Given the high natural gas pressure in the supply pipeline, class the pipe as a critical pipe and therefore perform routine inspections and integrity checks.
4. **Include the pipe design controls as detailed in AS2885, in particular, for the section of the low pressure pipe under Abernethy's Creek given the risk of corrosion and possible scouring and wash-away events.**

GLOSSARY

| | |
|--------|--|
| ALARP | As Low As Reasonably Practicable |
| AS | Australian Standard |
| DoP | NSW Department of Planning |
| HAZAN | Hazard Analysis |
| HIPAP | Hazardous Industry Planning Advisory Paper |
| HRSG | Heat Recovery Steam Generator |
| HSE UK | Health and Safety Executive United Kingdom |
| IBC | Intermediate Bulk Container |
| LEL | Lower Explosive Limit |
| PHA | Preliminary Hazard Analysis |
| QRA | Quantitative Risk Assessment |
| STEL | Short Term Exposure Limit |
| TLV | Threshold Limit Value |

REPORT

1 INTRODUCTION

1.1 BACKGROUND

Shoalhaven Starches is a member of the Manildra Group of companies. The Manildra Group is a wholly Australian owned business and the largest processor of wheat in Australia. It manufactures a wide range of wheat-based products for food and industrial markets both locally and internationally.

The Shoalhaven Starches factory located on Bolong Road, Bomaderry, produces a range of products for the food, beverage, confectionary, paper and motor transport industries including starch, gluten, glucose and ethanol.

Project Approval MP06_0228 for the Shoalhaven Starches Expansion Project made provision for a gas fired co-generation plant that would comprise two natural gas turbine generators that would deliver an anticipated net power output of 40 MW for the site.

Subsequently under Mod 16 the Independent Planning Commission approved an additional coal fired co-generation plant. This coal fired co-generation plant would generate a total of 15 MW of power for the site.

Neither the approved gas nor coal fired co-generation plants have been constructed to date.

Following the original Project Approval, Shoalhaven Starches have obtained approval and/or are seeking approval for a range of modifications to the original Project comprising a range of additional developments that were not envisaged as part of the original Project Approval. Shoalhaven Starches are forecasting that the electrical power load demand created by these and other additional works, subsequent to the original Project Approved development, will exceed the power supply capacity of the approved gas fired and coal fired co-generation plants.

Shoalhaven Starches now propose to construct a new gas-fired co-generation plant which will consist of two natural gas turbines that will generate an anticipated power output each of 30 MW, providing a total power to the site of 60 MW. The new gas fired co-generation plant will replace the approved gas fired and coal fired co-generators. In addition, Shoalhaven Starches also proposed to convert their existing coal fired boilers 2,4, 5 and 6 to gas as well.

The waste heat from each of the gas turbines' exhausts will be used to generate 11 barg steam in two 110 t/hr heat recovery steam boilers. The boilers will be co-fired with natural gas and will be able to operate at full output when the turbines are offline for maintenance.

As part of the project requirements, a Preliminary Hazard Analysis (PHA) is required. This revised PHA includes the new route for the low pressure (210 kPag) natural gas pipe from the Gas Pressure Reduction Station to site (MOD 2). The pipeline length is approximately the same as previously proposed.

The alignment of the low pressure gas pipeline that connects the proposed Gas Pressure Reduction Station on the northern side of Bolong Road to the Shoalhaven Starches factory site will be modified. It is proposed that the realigned pipeline route will travel from the proposed Gas Pressure Reduction Station east across the Shoalhaven Starches Packing Plant site, under Abernethy's Creek, to a point adjacent to the existing low pressure gas pipeline crossing point to the factory site, i.e. under Bolong Road as per the existing natural gas supply pipe.

All changes to the PHA have been shown in blue text. This is to allow easier identification of the changes for the reader.

Shoalhaven Starches requested that Pinnacle Risk Management prepare the PHA for the proposed modifications. This PHA has been prepared in accordance with the guidelines published by the Department of Planning (DoP) Hazardous Industry Planning Advisory Paper (HIPAP) No 6 (Ref 1).

1.2 OBJECTIVES

The main aims of this PHA study are to:

- Identify the credible, potential hazardous events associated with the proposed modifications, i.e. the co-generation plant and the associated new plant and equipment, and the conversion of the existing boilers 2,4, 5 and 6 from coal to natural gas;
- Evaluate the level of risk associated with the identified potential hazardous events to surrounding land users and compare the calculated risk levels with the risk criteria published by the DoP in HIPAP No 4 (Ref 2);
- Evaluate the potential for propagation events;
- Review the adequacy of the proposed safeguards to prevent and mitigate the potential hazardous events; and
- Where necessary, submit recommendations to Shoalhaven Starches to ensure that the proposed modifications are operated and maintained at acceptable levels of safety and effective safety management systems are used.

1.3 SCOPE

This PHA assesses the credible, potential hazardous events and corresponding risks associated with the Shoalhaven Starches proposed co-generation plant and

the associated new plant and equipment, and the conversion of the existing boilers 2,4, 5 and 6 from coal to natural gas.

There are no changes to the road or rail transport of Dangerous Goods to or from the site as part of this project. Therefore, transport is not assessed.

1.4 METHODOLOGY

In accordance with the approach recommended by the DoP in HIPAP 6 (Ref 1) the underlying methodology of the PHA is risk-based, that is, the risk of a particular potentially hazardous event is assessed as the outcome of its consequences and likelihood.

The PHA has been conducted as follows:

- Initially, the proposed modifications and their locations were reviewed to identify credible, potential hazardous events, their causes and consequences. Proposed safeguards were also included in this review;
- As the potential hazardous events are located at a significant distance from other sensitive land users, the consequences of each potential hazardous event were estimated to determine if there are any possible unacceptable off-site impacts;
- Included in the analysis is the risk of propagation between the proposed equipment and the adjacent processes; and
- If adverse off-site impacts could occur, assess the risk levels to check if they are within the criteria in HIPAP 4 (Ref 2).

2 SITE DESCRIPTION

The Shoalhaven Starches factory site is situated on various allotments of land on Bolong Road, Bomaderry, within the City of Shoalhaven (see Figure 1). The factory site, which is located on the south side of Bolong Road on the northern bank of the Shoalhaven River, has an area of approximately 12.5 hectares.

The town of Bomaderry is located approximately 0.5 km to the west of the factory site and the Nowra urban area is situated 2.0 km to the south west of the site. The “Riverview Road” area of the Nowra Township is situated approximately 600 metres immediately opposite the factory site across the Shoalhaven River.

The village of Terara is situated approximately 1.5 kilometres to the south east of the site, across the Shoalhaven River. Pig Island is situated between the factory site and the village of Terara and is currently used for cattle grazing.


There are a number of industrial land uses, which have developed on the strip of land between Bolong Road and the Shoalhaven River. Industrial activities include a metal fabrication factory, the Shoalhaven Starches site, Shoalhaven Dairy Co-op (formerly Australian Co-operative Foods Ltd – now owned by the Manildra Group) and the Shoalhaven Paper Mill (also now owned by the Manildra

Group). The industrial area is serviced by a privately-owned railway spur line that runs from just north of the Nowra-Bomaderry station via the starch plant and the former Dairy Co-op site to the Paper Mill.

The Company also has an Environmental Farm of approximately 1,000 hectares located on the northern side of Bolong Road. This area is cleared grazing land and contains spray irrigation lines and wet weather storage ponds (total capacity 925 Mega litres). There are at present six wet weather storage ponds on the farm that form part of the waste water management system for the factory. A seventh pond approved in 2002 was converted into the biological section of the new wastewater treatment plant has now been commissioned.

The Environmental Farm covers a broad area of the northern floodplain of the Shoalhaven River, stretching from Bolong Road in the south towards Jaspers Brush in the north. Apart from its use as the Environmental Farm, this broad floodplain area is mainly used for grazing (cattle). The area comprises mainly large rural properties with isolated dwellings although there is a clustering of rural residential development along Jennings Lane (approximately 1 kilometre from the site), Back Forest Road (approximately 500 metres to 1.2 kilometres to the west) and Jaspers Brush Road (approximately 1.2 kilometres to the north).

Figure 1 - Site Locality Plan



Security of the site is achieved by a number of means. This includes site personnel and security patrols by an external security company (this includes weekends and night patrols). The site operates 7 days per week (24 hours per


day). Also, the site is fully fenced and non-operating gates are locked. Security cameras are installed for staff to view visitors and site activities.

There are approximately 180 people on site during Monday to Fridays 8 am to 5 pm and 100 people on site at other times.

The main natural hazard for the site is flooding. No other significant external events are considered high risk for this site.

A layout drawing showing the proposed location of the modifications is shown in Figure 2.

Figure 2 - Site Layout



3 PROCESS DESCRIPTION

3.1 CO-GENERATION PLANT

3.1.1 Introduction

The new gas fired co-generation plant will be housed within a building that will comprise a structure with a footprint of 2,160 m² and a height above ground level of 20.5 metres.

In addition to the above, it is proposed that the existing coal fired boilers 5 and 6 will be fitted with natural gas burners. Consequently, coal will no longer be used on the site following the commissioning of the new and modified plants.

The proposed co-generation plant will be a continuous process based on two natural gas fired turbines, each coupled to a generator capable of generating up to 30MW of power each at 11kV. The power will be connected to the site's main substation for distribution through the existing electrical distribution network.

The exhaust gases from the turbines will be ducted into two heat recovery steam generators (HRSG) which capture the waste heat from the exhaust in conjunction with co-firing of natural gas to produce up to 110te/hr of saturated steam per HRSG at 1,100 kPa.

Each HRSG will have a stack for emission of the combined exhaust gases from the turbine and HRSG.

The co-generation plant layout is shown in Figure 3. A process flow schematic for the plant is shown in Figure 4.

3.1.2 Natural Gas Supply

Natural gas will be supplied to the co-generation plant turbines at 4,000 kPa. The gas will be further reduced to 500kPa for supply to the co-firing of the HRSGs. The 4,000 kPa supply line will be a new pipe (nominal diameter of 300 mm) from a new pressure reduction station and flow metering facility at Bolong Road. The pipe will be constructed from Schedule 40 carbon steel.

Under maximum output conditions, natural gas consumption is 12,293 kg/hr for the turbines and 5,455 kg/hr for the HRSGs.

3.1.3 Steam Export to Site

Steam will be supplied from the co-generation plant at 1,100kPa and will be transported via a pipebridge to the existing site boiler house for distribution through the existing steam network. The co-generation plant has a total steam capacity of 220 te/hr.

Figure 3 – Co-Generation Plant Layout





Figure 4 – Co-Generation Plant Process Flow Schematic



3.1.4 Condensate

Condensate will be returned from the existing process plant via the boiler house and the pipebridge at 100°C. This return stream will provide 70% of the water requirements for the operation of the HRSGs. Condensate will be returned directly to the deaerators of the HRSGs.

3.1.5 Make-Up Water

Make-up water will be supplied at ambient temperature from the boiler house via the pipebridge and will provide the remainder of the water supply required for operation of the HRSGs. A 250m³ make-up water storage, equivalent to approximately 4 hours of make-up water supply, will be installed at the co-generation plant. The make-up water will be preheated prior to supply to the deaerators.

3.1.6 Electricity Supply

Power will be supplied from the co-generation plant at 11kV and will be reticulated via cabling on the pipebridge to the existing main substation for distribution through the existing electricity network. The co-generation plant has a capacity of 60MW.

3.1.7 Electricity Supply - Synchronization

The generators will be connected in parallel with the external electricity supply network. To prevent a catastrophic failure of the electrical infrastructure, the generators must be “in phase” with the network prior to connection in a process known as synchronization. The generator control system will adjust the throttle of the turbine to correct the frequency and phase of the generator and will also adjust the excitation voltage of the generator to correct the voltage output, such that these values correspond with the external supply. Prior to the closing of a critical circuit breaker, a “check sync” protection relay on the circuit breaker will compare the frequency and phase across the circuit breaker to allow closing of the circuit breaker.

3.1.8 Electricity Supply – Reverse Power Protection

To prevent the export of power from the Shoalhaven Starches co-generation plant to the off-site grid, a protection scheme will be provided to monitor the direction of power flow and will trip the incoming supply circuit breakers on detection of any export. The setting of the reverse power protection scheme will be determined in consultation with the local supply authority.

3.1.9 Automatic Control

Automatic control of the co-generation plant will be via a vendor supplied control system comprising Woodward Micronet+ controllers and MARK VI sequencers.

Turbine combustion control will be achieved by modulation of an electronically controlled fuel metering valve that will adjust the fuel supply to the turbine. The fuel will be mixed with the air flowing through the turbine before ignition in the combustor section. The Micronet+ controller will monitor the combustion process for abnormal conditions and will initiate pre-determined control actions including trip of the turbine.. Safety Integrity Systems (i.e. SIL rated) will be supplied by MARK Vle.

3.2 GAS-FIRED BOILERS 2,4, 5 AND 6 MODIFICATIONS

Boilers 2, 4, 5 and 6 are currently fired on coal and will be converted to fire on natural gas to achieve the same capacity output. The boilers will only operate as required. The gas supply will be connected to the existing reticulation system at a supply pressure of 210 kPa. The pressure will be reduced at each burner valve train.

The gas pipework reticulation, valve train, burner and controls will be in accordance with the current AS4041, AS3814 and AS2593 standards, or any other relevant standard.

The following table summarises the natural gas and air flows to boilers 2, 4, 5 and 6.


Table 1 – Boilers Gas and Air Flows

| | Gas Flow, GJ/hr | Gas Flow, kg/hr | Air Flow, m ³ /hr |
|----------|--------------------|--------------------|---------------------------------|
| Boiler 2 | 35 | 740 | 12,000 |
| Boiler 4 | 56 | 1,200 | 19,500 |
| Boiler 5 | 119 | 2,530 | 40,000 |
| Boiler 6 | 175 | 3,710 | 59,000 |

This additional natural gas flow will be provided by a new low pressure (210 kPag) pipe from the Gas Pressure Reduction Station on the northern side of Bolong Road (Shoalhaven Starches owned land). It is proposed that this realigned pipeline route will travel from the Gas Pressure Reduction Station east across the Shoalhaven Starches Packing Plant site, under Abernethy's Creek, to a point adjacent to the existing low pressure gas pipeline crossing point to the factory site, i.e. under Bolong Road as per the existing natural gas supply pipe.

Formerly, this low pressure natural gas pipe was to travel under Bolong Road from the Gas Pressure Reduction Station and then east through the Shoalhaven Starches factory (see Figure 5). In summary, the pipe length is the same as previous revisions of this PHA, there is still one road crossing and the pipe still remains on Shoalhaven Starches property.

Figure 5 - New Low Pressure Natural Gas Pipeline Alignment



Boilers 5 and 6 are fitted with economizers which reduce the flue gas temperatures to 170°C.

The boilers' conversion will include insulating of the existing coal grate and leaving the existing induced draught fan to assist in removal of flue products to the stack. New combustion air fans will be installed to suit the new burners.

The boilers' front plates will be modified to take the new gas burners.

New electrical controls will be included to operate the boiler automatically as per AS2593.

The boilers will have full time boiler attendants and they will perform the relevant checks as per the current Work-Safe code. The boiler attendants will be ticketed with advanced boiler licenses.

4 HAZARD IDENTIFICATION

4.1 HAZARDOUS MATERIALS

The hazardous materials involved with the modifications are:

- Natural gas; and
- Boiler feed water dosing chemicals.

Natural Gas:

Natural gas is flammable, i.e. if released and ignited, there is a risk of jet fires, flash fires and explosions (if confined).

Natural gas is a Class 2.1 Dangerous Good (DG), i.e. a flammable gas.

Natural gas is a colourless hydrocarbon fluid mainly composed of the following hydrocarbons:

- Methane (typically 88.5% or higher);
- Ethane (typically 8%);
- Propane (typically 0.2%);
- Carbon dioxide (typically 2%); and
- Nitrogen (typically 1.3%).

For a typical natural gas, the TLV (threshold limit value) is approximately 1,000 ppm and the STEL (short term exposure limit) is 30,000 ppm (i.e. approaching 5 vol% which is the lower explosive limit).

The hydrocarbons are not considered to represent a significant environmental threat. Their hazard potential derives solely from the fact that they are flammable materials.

To enable ready leak detection, natural gas is normally odourised with mercaptans (sulphur containing hydrocarbons).

The flammability range is typically 5% to 15% v/v in air. The vapours are lighter than air and will normally disperse safely if not confined and/or ignited.

Products of combustion include carbon monoxide and carbon dioxide.

Boiler Feed Water Dosing Chemicals:

The same boiler feed water dosing chemicals that are currently used at the site are to be used for the co-generation plant, i.e.:

- Amercor 8548 – Corrosion inhibitor (DG 8 – corrosive amine liquid) ;
- Amertrol HT 3510 – Deposit inhibitor (DG 8 - 3 to 5% caustic soda);
- Amersite 2 – Oxygen scavenger (DG 8); and
- Antispumin WC 5030 – Antifoam (non-DG).

The storage volumes are relatively small, e.g. IBC's (intermediate bulk containers) or drums, and these will be stored within dedicated bunds to avoid any losses of containment impacting the environment or people. The dosing chemicals will be located adjacent to the HRSGs. Given the relatively small volumes and that all containers are separately bunded then no further analysis of these materials is warranted.

4.2 POTENTIAL HAZARDOUS INCIDENTS REVIEW

In accordance with the requirements of *Guidelines for Hazard Analysis*, (Ref 1), it is necessary to identify hazardous events associated with the facility's operations. As recommended in HIPAP 6, the PHA focuses on "atypical and abnormal events and conditions. It is not intended to apply to continuous or normal operating emissions to air or water".

In keeping with the principles of risk assessments, credible, hazardous events with the potential for off-site effects have been identified. That is, "slips, trips and falls" type events are not included nor are non-credible situations such as an aircraft crash occurring at the same time as an earthquake.

The identified credible, significant incidents (in particular, with the potential for off-site impacts) for the proposed modifications are summarised in the Hazard Identification Word Diagram following (Table 2).

This diagram presents the causes and consequences of the events, together with major preventative and protective features that are to be included as part of the design.

Table 2 – Hazard Identification Word Diagram

| Event Number | Hazardous Event | Causes | Consequences | Existing Safeguards - Prevention Detection Mitigation |
|--------------|---|---|---|---|
| 1 | Natural gas explosion within the turbines or boilers 5 and 6 | Natural gas flow into the turbines or boilers when the burners are offline | <p>Buildup of natural gas in the turbines' systems or furnaces. If ignited, there is the potential for an internal explosion, i.e. damage to the turbines' systems or boilers.</p> <p>This is a local event and does not pose any credible off-site risks as the co-generation plant will be approximately 160 m from the nearest site boundary (Bolong Road)</p> | Burner management system will be certified to Australian Standards which will include the need for redundant actuated natural gas isolation and air purging prior to startup |
| 2 | Loss of containment of natural gas from the supply pipes (outside the co-generation plant building or to boilers 5 and 6) | Pipe failure, e.g. corrosion or weld defect, gasket failure, valve leak, impact | If ignited, potential for a jet fire, flash fire or explosion (if confined) which can impact personnel and equipment | <p>The pipes are to be protected from impact by locating them in piperacks.</p> <p>Minimum flanges used.</p> <p>Pipes to be included in the hazardous zone study.</p> <p>Remote isolation of the natural gas is possible at the gas metering station.</p> <p>The natural gas supply pipe is to be pressure tested following construction and protected against corrosion by painting.</p> <p>The natural gas piping and equipment items are to be compliant with the Australian Standards</p> |

| Event Number | Hazardous Event | Causes | Consequences | Existing Safeguards - Prevention Detection Mitigation |
|--------------|---|--|--|--|
| 3 | Loss of containment of natural gas from the pipes within the co-generation plant building | Pipe failure, e.g. corrosion or weld defect, gasket failure, valve leak or hose failure | <p>If ignited, there is the potential for an internal building explosion, i.e. damage to the building and equipment as well as the potential for injury to personnel.</p> <p>This is a local event and does not pose any credible off-site risks as the co-generation plant will be approximately 160 m from the nearest site boundary (Bolong Road)</p> | <p>The natural gas supply pipe is to be pressure tested following construction and protected against corrosion by painting.</p> <p>The natural gas piping and equipment items are to be compliant with the Australian Standards.</p> <p>Routine pipe inspections and maintenance</p> |
| 4 | HRSG or boiler rupture | Low level, loss of boiler feed water pumps, high factory demand for steam, failure of the level control, control valve stuck closed, low level in feedwater tank | Catastrophic failure of the HRSG or boiler, i.e. equipment damage and injury to on-site personnel when steam and hot condensate is released externally to the boiler, i.e. local event only | Australian Standard compliant low level protection, standby boiler feed water pumps, low and low-low level alarms, boiler trip on low-low level, maintenance on the valves and instruments, low level alarm and trip on the feedwater tank, operator checks on the boiler and feedwater tank sight glass |
| 5 | HRSG or boiler rupture | <p>Corrosion, e.g. poor boiler feed water chemistry.</p> <p>Erosion, e.g. from two phase flow</p> | Catastrophic failure of the HRSG or boiler, i.e. equipment damage and injury to on-site personnel when steam and hot condensate is released externally to the boiler, i.e. local event only | Water softeners on the boiler feedwater supply, daily sampling, pH and total dissolved solids checks, routine equipment inspections (weekly, monthly and yearly) |

| Event Number | Hazardous Event | Causes | Consequences | Existing Safeguards - Prevention Detection Mitigation |
|--------------|---|---|--|--|
| 6 | Failure of the steam drum or high pressure piping | Corrosion (e.g. under lagging corrosion), weld defect, safety relief valves stuck closed, failure of letdown valves | Catastrophic failure of the steam drum or piping, i.e. equipment damage and injury to on-site personnel from a release of steam and possible projectiles | Routine inspections (piping and equipment), operator inspections, operator training (boiler emergency procedure to delay the re-introduction of water following a low-low water level event), redundant safety relief valves, certifications on equipment, high pressure alarm for operator response |

5 RISK ANALYSIS

The assessment of risks to both the public as well as to operating personnel around the proposed modifications requires the application of the basic steps outlined in Section 1. As per HIPAP 6 (Ref 1), the chosen analysis technique should be commensurate with the nature of the risks involved. Risk analysis could be qualitative, semi-quantitative or quantitative.

The typical risk analysis methodology attempts to take account of all credible hazardous situations that may arise from the operation of processing plants etc.

Having identified all credible, significant incidents, risk analysis requires the following general approach for individual incidents:

$$\text{Risk} = \text{Likelihood} \times \text{Consequence}$$

The risks from all individual potential events are then summated to get cumulative risk.

For QRA (quantitative risk analysis) and hazard analysis, the consequences of an incident are calculated using standard correlations and probit-type methods which assess the effect of fire radiation, explosion overpressure and toxicity to an individual, depending on the type of hazard.

In this PHA, however, the approach adopted to assess the risk of the identified hazardous events is scenario-based risk assessment. The reason for this approach is the distances from the proposed modifications to residential and other sensitive land users are large and hence it is unlikely that any significant consequential impacts, e.g. due to radiant heat from fires, from the facility will have any significant contribution to off-site risk.

The risk criteria applying to developments in NSW are summarised in Table 3 on the following page (from Ref 2).

Table 3 - Risk Criteria, New Plants

| Description | Risk Criteria |
|--|-------------------------------|
| Fatality risk to sensitive uses, including hospitals, schools, aged care | 0.5×10^{-6} per year |
| Fatality risk to residential and hotels | 1×10^{-6} per year |
| Fatality risk to commercial areas, including offices, retail centres, warehouses | 5×10^{-6} per year |
| Fatality risk to sporting complexes and active open spaces | 10×10^{-6} per year |
| Fatality risk to be contained within the boundary of an industrial site | 50×10^{-6} per year |
| Injury risk – incident heat flux radiation at residential areas should not exceed 4.7 kW/m^2 at frequencies of more than 50 chances in a million per year or incident explosion overpressure at residential areas should not exceed 7 kPa at frequencies of more than 50 chances in a million per year | 50×10^{-6} per year |
| Toxic exposure - Toxic concentrations in residential areas which would be seriously injurious to sensitive members of the community following a relatively short period of exposure | 10×10^{-6} per year |
| Toxic exposure - Toxic concentrations in residential areas which should cause irritation to eyes or throat, coughing or other acute physiological responses in sensitive members of the community | 50×10^{-6} per year |
| Propagation due to Fire and Explosion – exceed radiant heat levels of 23 kW/m^2 or explosion overpressures of 14 kPa in adjacent industrial facilities | 50×10^{-6} per year |

As discussed above, the consequences of the potential hazardous events are initially analysed to determine if any events have the potential to contribute to the above-listed criteria and hence worthy of further analysis. The potential hazardous events of interest in this PHA are jet and flash fires, and vapour explosions.

5.1 NATURAL GAS RELEASES – JET FIRES CONSEQUENCES

Releases from the natural gas piping systems can be ignited. The natural gas pressure throughout the site is 210 kPag, i.e. this is the pressure within the proposed low pressure natural gas piping to the boilers. The pressure within the new high pressure piping to the co-generation plant is 4,000 kPag. As the natural gas supply pressures to the boilers and the co-generation plant are different then separate models for jet fires are detailed below.

These two pipes are wholly on the Shoalhaven Starches property (with the exception where the pipelines either cross Abernethy's Creek or Bolong Road). The nearest residential area is approximately 150 m from the 4,000 kPag pipe and 220 m from the 210 kPag (low pressure) pipe. Industrial and commercial facilities are closer, e.g. 15 m from the high pressure pipe.

The analysis of potential jet fires for the low pressure natural gas piping for the boilers is shown in Table 4. The mass rates, flame length and radiant heat were estimated using TNO's EFFECTS program. The new pipe diameter is 450 mm.

Table 4 – Natural Gas Jet Fires – Boilers

| Stream | Estimated Release Rate, kg/s | Estimated Length of Jet, m | Distance (m) to 12.6 kW/m ² |
|----------------------------|------------------------------|----------------------------|--|
| Full bore failure (450 mm) | 5.9 | 36 | 44 |
| 50 mm hole | 0.64 | 13 | 14 |

Notes: 1. Jet flames modelled using methane.

2. Full bore rate limited by upstream supply valving, i.e. 21,200 kg/hr = 5.9 kg/s
3. 13 mm hole size not included given low flows and small potential jet lengths
4. Distance to 12.6 kW/m² is for a worst-case horizontal jet fire

Adverse off-site impact from potential jet fires from the boilers' new supply pipe is possible if the failure was to occur close to Bolong Road. Based on the modelling, the distance to 4.7 kW/m² from a catastrophic pipe failure is up to 75 m (i.e. for a worst-case horizontal jet fire; significantly less for a vertical jet). Given the separation distances to the nearest residential areas exceed 75 m then no adverse impact is expected to these receptors.

If a worst-case horizontal jet is assumed then the distance to 12.6 kW/m² (i.e. potential for fatality from radiant heat for a 20 second exposure) is approximately 44 m (for a catastrophic pipe failure). Correspondingly, if the new boilers natural gas supply pipe fails within approximately 44 m of Bolong Road then adverse off-site impact could occur. This scenario is therefore analysed further in Section 5.3.

The analysis of potential jet fires for the high pressure natural gas piping to the co-generation plant is shown in Table 5. The mass rates, flame length and

radiant heat were again estimated using TNO's EFFECTS program. The new pipe diameter is 300 mm.

Table 5 – Natural Gas Jet Fires – Co-Generation Plant

| Stream | Estimated Release Rate, kg/s | Estimated Length of Jet, m | Distance (m) to 12.kW/m ² |
|----------------------------|------------------------------|----------------------------|--------------------------------------|
| Full bore failure (300 mm) | 4.7 (Note 1) | 29 | 29 |
| 50 mm hole | 4.7 (Note 1) | 29 | 29 |
| 13 mm hole | 0.57 | 11 | - |

Notes: 1. Full bore rate limited by upstream supply valving, i.e. 16,960 kg/hr = 4.7 kg/s.

2. Jet flames modelled using methane.

If a worst-case horizontal jet is assumed then the distance to 12.6 kW/m² (i.e. potential for fatality from radiant heat for a 20 second exposure) is approximately 29 m (a vertical jet poses significantly less radiant heat for the same release scenario). Correspondingly, if the new co-generation plant natural gas supply pipe fails within approximately 29 m of Bolong Road then adverse off-site impact could occur. [Given the separation distances to the nearest residential areas exceed 29 m then no adverse impact is expected to these receptors.](#) This scenario is therefore analysed further in Section 5.3.

5.2 NATURAL GAS RELEASES – FLASH FIRES AND EXPLOSIONS CONSEQUENCES

Potential flash fires and vapour cloud explosions can occur from natural gas pipe failures and delayed ignition.

For flash fires, any person inside the flash fire cloud is assumed to be fatally injured. As flash fires are of limited duration (typically burning velocity is 1 m/s, Ref 3) then those outside the flash fire cloud have a high probability of survival without serious injury.

The effects from explosion overpressures (Ref 2) are summarised in Table 6.

Table 6 – Effects of Explosion Overpressure

| OVERPRESSURE, kPa | PHYSICAL EFFECT |
|-------------------|--|
| 3.5 | 90% glass breakage No fatality, very low probability of injury |
| 7 | Damage to internal partitions & Joinery 10% probability of injury, no fatality |
| 14 | Houses uninhabitable and badly cracked |
| 21 | Reinforced structures distort, storage tanks fail 20% chance of fatality to person in building |
| 35 | Houses uninhabitable, rail wagons & plant items overturned. Threshold of eardrum damage, 50% chance of fatality for a person in a building, 15% in the open |
| 70 | Complete demolition of houses Threshold of lung damage, 100% chance of fatality for a person in a building or in the open |

The analysis of the potential flash fires and vapour cloud explosions from the natural gas pipe failures is shown in Table 7. The mass calculated in the flammable range is assumed to be 50% confined, i.e. the area where the releases can occur that can lead to off-site impact are not highly congested. As methane is not a highly reactive flammable gas and the quantities involved are relatively small then a medium deflagration (Curve 5) is assumed in the explosion calculations (multi-energy method – TNO).

Table 7 - Natural Gas Flash Fires and Vapour Cloud Explosions

| Stream | Mass of Natural Gas in the Flammable Range, kg | Radius of Flash Fire, m | Distance (m) to 14 kPa Explosion Overpressure | Distance (m) to 7 kPa Explosion Overpressure |
|---|--|-------------------------|---|--|
| <i>Boilers and Dryers Natural Gas Supply:</i> | | | | |
| Full bore failure (450 mm) | 563 | 120 m | 45 m | 91 m |
| 50 mm hole | 9 | 19 m | 5 m | 23 m |
| <i>Co-Generation Plant Natural Gas Supply:</i> | | | | |
| Full bore failure (300 mm) and 50 mm hole | 378 | 100 m | 39 m | 79 m |

Notes: 1. Pipeline failures assumed to be isolated within 5 minutes.

2. Radius of flash fires calculated to be the distance to LEL (lower explosion limit) at F weather stability and 1.5 m/s wind speed.

3. 13 mm holes are not modelled as they are too small to generate gas clouds of any significant size.

4. Overpressure distances are from the centre of the gas cloud. There needs to be a minimum of 1 to 15 tes for ignition of a vapour cloud to result in an explosion (Ref 4) for non-reactive gases such as methane. Quantities that are lower than 1 te are therefore not expected to develop overpressures when ignited. These events are included to be conservative only.

For the gas modelling, steady state conditions are reached soon after the release occurs, i.e. after approximately 2 minutes, therefore the distance to the LEL does not change at steady state dispersion conditions.

Given the modelling results in Table 7, if the new boilers and co-generation plant natural gas supply pipes fail within approximately 120 m and 100 m, respectively, of Bolong Road then adverse off-site impact (i.e. potential fatality) could occur. **Given the separation distances to the nearest residential areas exceed 45 m then no significant impact, i.e. fatality or injury, is expected to these receptors.**

The likelihood and risk for these events are assessed in the following section.

5.3 LIKELIHOOD AND RISK ANALYSIS

Adverse off-site impact (i.e. potential fatality) is possible from releases from the natural gas supply pipes (full bore and/or 50 mm holes) that can lead to jet fires, flash fires and vapour cloud explosions. This is not expected to occur at residential areas; only along Bolong Road or the adjacent industrial and commercial facilities.

The probability of ignition of flammable gas releases from gas pipelines is provided in AS2885.6 Table F2. For a large release rate from a pipeline of DN≤400 (i.e. the supply pipe to the Cogeneration Plant), the ignition probability is 0.1. For a pipeline >DN400 (i.e. the boilers supply pipe), the ignition probability is 0.3. However, in this PHA, the ignition probability for both pipelines is assumed to be 30% (i.e. conservative).

The low likelihoods for potential pipeline failures are supported by the following data (Ref: UK HSE (Ref 5). This data is used in the following risk analysis.

Table 8 – Piping Failure Frequencies

| Failure Rates (per m per year) for Pipework Diameter (mm) | | | | | |
|---|--------------------|--------------------|--------------------|--------------------|--------------------|
| Hole Size: | 0 - 49 | 50 - 149 | 150 - 299 | 300 - 499 | 500 – 1,000 |
| 3 mm diameter | 1×10^{-5} | 2×10^{-6} | | | |
| 4 mm diameter | | | 1×10^{-6} | 8×10^{-7} | 7×10^{-7} |
| 25 mm diameter | 5×10^{-6} | 1×10^{-6} | 7×10^{-7} | 5×10^{-7} | 4×10^{-7} |
| 1/3 pipework diameter | | | 4×10^{-7} | 2×10^{-7} | 1×10^{-7} |
| Guillotine | 1×10^{-6} | 5×10^{-7} | 2×10^{-7} | 7×10^{-8} | 4×10^{-8} |

The pipelines' risk analysis is presented in Table 9. The following notes apply to this conservative, simplified approach.

- The likelihood for 50 mm holes is taken to be the same as 25 mm holes (as data for 50 mm holes is not provided by the HSE). Typically, the likelihood of occurrence for a larger hole size will be lower than that for a smaller hole size;
- Standard quantitative risk analysis (QRA) methodology is used, i.e. risk at a point is determined by multiplying the likelihood of an event by the consequence. The consequential impact is the probability of fatality for individual and societal risk calculations. This value is 1.0 for the events analysed in this PHA;
- The risk of each event that can cause fatality at the point of interest is then summated to get total risk;
- The point of assessment is orthogonal to the pipeline where all modelled events are expected to cause fatality. This point can be anywhere along the pipeline. In effect, this shows the maximum risk from the pipeline to this point. Any further away from this point then there will be fewer events that can cause fatality, therefore, no further analysis at these greater distances is warranted (assuming the maximum calculated risk is below the HIPAP 4 risk criteria). This is a conservative approach as flame lift-off for jet fires may result in some scenarios not causing adverse impact;
- The “Probability of Wind Direction” in Table 9 is derived using the modelling results. For example, the plume width for a gas release with a subsequent flash fire is used to determine the total probability of wind direction blowing the gas to the point of assessment. A conservative value was chosen, i.e. the plume width or wind direction probability is based on the F1.5 modelling. The angles will be lower for the more unstable atmospheric classes and higher wind speeds;

- The “Pipeline Distance for Off-Site Impact” represents the length of pipeline where potential releases can occur that can result in fatality at the point of interest. The point of interest (or assessment) is orthogonal to the pipeline. There can be upstream and downstream releases that can also cause fatality at the point of interest. The modelling is used to determine how far upstream and downstream of this location that result in releases causing fatality at the point of interest. Any releases that are outside of this distance do not cause fatality at the point of interest and therefore do not need to be taken into consideration;
- The individual fatality risk is the likelihood of a release and ignition multiplied by the various probabilities and “Pipeline Distance for Off-Site Impact”;
- Cumulative risk is the summated values for each risk contributor;
- The pipeline distances correlate to the F1.5 weather / wind combination. In practice, these distances will be lower for the other, more unstable weather/wind conditions. The typical weather/wind data for the site is shown in Appendix A; and
- The pipeline distances are to 12.6 kW/m² and 14 kPa, i.e. to show that individual fatality risk of 50 pmpy remains within the site’s boundary.

The simplified risk analysis shows that the individual fatality risk at the site’s boundary will be no higher than 0.5 pmpy for the boilers low pressure natural gas supply pipe and 2 pmpy for the co-generation plant natural gas supply pipe. As this is less than 50 pmpy then this HIPAP 4 risk criterion is satisfied. As the two pipes enter the site at different locations with a separation distance of approximately 165 m then the results in Table 9 do not need to be summated for cumulative risk estimation.

This is a low level of risk, it is below the risk criteria shown in Table 3 for risk level at a site’s boundary and is not considered intolerable. The ALARP (As Low As Reasonably Practicable) principle is achieved; primarily due to compliance with the Australian Standards for piping.

Compliance with the HIPAP 4 risk criteria is shown in Table 10.

Table 9 – Risk Analysis

| Release Case: | Probability of Ignition | Probability of Event Type | Likelihood of Failure (times/year.m) | Pipeline Distance for Off-Site Impact (m) | Probability of Wind Direction (from the south) | Individual Fatality Risk Estimate (pmpy) |
|-------------------------------------|-------------------------|---------------------------|--------------------------------------|---|--|--|
| Boilers: | | | | | | |
| Jet Fire - Full Bore Pipe Failure | 0.3 | 0.3 | 7.00E-08 | 44 | 0.15 | 4.16E-08 |
| Jet Fire - 50 mm Hole | 0.3 | 0.3 | 5.00E-07 | 14 | 0.15 | 9.45E-08 |
| Flash Fire - Full Bore Pipe Failure | 0.3 | 0.4 | 7.00E-08 | 120 | 0.15 | 1.51E-07 |
| Flash Fire - 50 mm Hole | 0.3 | 0.4 | 5.00E-07 | 19 | 0.15 | 1.71E-07 |
| Vapour Explosion - Full Bore | 0.3 | 0.3 | 7.00E-08 | 45 | 0.15 | 4.25E-08 |
| Vapour Explosion - 50 mm hole | 0.3 | 0.3 | 5.00E-07 | 5 | 0.15 | 3.38E-08 |
| | | | | | Total | 5.35E-07 |
| Co-Generation Plant: | | | | | | |
| Jet Fire - Full Bore Pipe Failure | 0.3 | 0.3 | 7.00E-08 | 29 | 0.15 | 2.74E-08 |
| Jet Fire - 50 mm Hole | 0.3 | 0.3 | 5.00E-07 | 29 | 0.15 | 1.96E-07 |
| Flash Fire - Full Bore Pipe Failure | 0.3 | 0.4 | 7.00E-08 | 100 | 0.15 | 1.26E-07 |
| Flash Fire - 50 mm Hole | 0.3 | 0.4 | 5.00E-07 | 100 | 0.15 | 9.00E-07 |
| Vapour Explosion - Full Bore | 0.3 | 0.3 | 7.00E-08 | 39 | 0.15 | 3.69E-08 |
| Vapour Explosion - 50 mm hole | 0.3 | 0.3 | 5.00E-07 | 39 | 0.15 | 2.63E-07 |
| | | | | | Total | 1.55E-06 |

Probability of event type from the UKOOA Report (Ref 6).

Table 10 – HIPAP 4 Risk Criteria Compliance

| Description | Risk Criteria | Comments | Risk Acceptable? |
|--|-------------------------------|--|------------------|
| Fatality risk to sensitive uses, including hospitals, schools, aged care | 0.5×10^{-6} per year | No adverse levels of radiant heat or explosion overpressures to impact any of these land users. For example, the nearest residential area is approximately 400 m from the co-generation building | Yes |
| Fatality risk to residential and hotels | 1×10^{-6} per year | No adverse levels of radiant heat or explosion overpressures to impact any of these land users. For example, the nearest residential area is approximately 400 m from the co-generation building | Yes |
| Fatality risk to commercial areas, including offices, retail centres, warehouses | 5×10^{-6} per year | The estimated individual fatality risk at the site boundary is up to 2 pmpy. This is below this criterion | Yes |
| Fatality risk to sporting complexes and active open spaces | 10×10^{-6} per year | There are no sporting complexes or active open spaces where adverse levels of radiant heat or explosion overpressures are expected | Yes |
| Fatality risk to be contained within the boundary of an industrial site | 50×10^{-6} per year | The estimated risk at the site boundary is up to 2 pmpy. This is below this criterion | Yes |
| Injury risk – incident heat flux radiation at residential areas should not exceed 4.7 kW/m^2 at frequencies of more than 50 chances in a million per year or incident explosion overpressure at residential areas should not exceed 7 kPa at frequencies of more than 50 chances in a million per year | 50×10^{-6} per year | No adverse levels of radiant heat or explosion overpressures to impact any residential areas. For example, the nearest residential area is approximately 400 m from the co-generation building | Yes |

| Description | Risk Criteria | Comments | Risk Acceptable? |
|---|--------------------------------|---|------------------|
| Toxic exposure - Toxic concentrations in residential areas which would be seriously injurious to sensitive members of the community following a relatively short period of exposure | 10 x 10 ⁻⁶ per year | No toxic gases associated with this modification | Yes |
| Toxic exposure - Toxic concentrations in residential areas which should cause irritation to eyes or throat, coughing or other acute physiological responses in sensitive members of the community | 50 x 10 ⁻⁶ per year | No toxic gases associated with this modification | Yes |
| Propagation due to Fire and Explosion – exceed radiant heat levels of 23 kW/m ² or explosion overpressures of 14 kPa in adjacent industrial facilities | 50 x 10 ⁻⁶ per year | As the estimated individual fatality risk at the site boundary is up to 2 pmpy then this criterion is satisfied | Yes |

5.4 PROPAGATION AND CUMULATIVE RISK

There are design and safety management system controls (summarised in Table 2) that are designed to prevent hazardous events occurring. These include designing to Australian and international standards and codes, hazardous area assessments, and controls on ignition sources, e.g. permits to work. Should these prevention controls fail and an incident occur then propagation is possible for some events, e.g. due to radiant heat from jet or flash fires, or explosion overpressures.

Propagation from potential natural gas releases is a low likelihood, e.g. the low pipe failure likelihoods in Table 8 and the low risk levels detailed in Table 9. Compliance and certification to the boiler codes ensures the risk of incidents achieves ALARP.

Correspondingly, it is reasonable to conclude that the proposed modifications do not make a significant contribution to the existing cumulative risk in the area.

5.5 SOCIETAL RISK

The criteria in HIPAP 4 for individual risk do not necessarily reflect the overall risk associated with any proposal. In some cases, for instance, where the 1 pmpy contour approaches closely to residential areas or sensitive land uses, the potential may exist for multiple fatalities as the result of a single accident. One attempt to make comparative assessments of such cases involves the calculation of societal risk.

Societal risk results are usually presented as F-N curves, which show the frequency of events (F) resulting in N or more fatalities. To determine societal risk, it is necessary to quantify the population within each zone of risk surrounding a facility. By combining the results for different risk levels, a societal risk curve can be produced.

In this study of the modified Shoalhaven Starches site, the risk of off-site fatality is below the HIPAP 4 risk criteria. As the nearest house is approximately 400 m away from the co-generation building and the low likelihoods for pipe failures, the concept of societal risk applying to populated areas is therefore not applicable for this project.

5.6 RISK TO THE BIOPHYSICAL ENVIRONMENT

The main concern for risk to the biophysical environment is generally with effects on whole systems or populations. For the proposed modifications involving natural gas, steam, boiler feedwater and power, there are no solid, liquid or gaseous effluents that could significantly impact the environment.

Whereas any adverse effect on the environment is obviously undesirable, the results of this study show that the risk of losses of containment is broadly acceptable.

6 CONCLUSION AND RECOMMENDATIONS

The risks associated with the proposed modifications at the Shoalhaven Starches Bomaderry site have been assessed and compared against the DoP risk criteria.

The results presented in this report show compliance with all risk criteria.

Societal risk, area cumulative risk and environmental risk are also concluded to be acceptable.

The primary reason for the low risk levels from the modifications is the low likelihood of significant pipe failures leading to off-site impact from jet or flash fires, or explosions.

Based on the analysis in this PHA, the following recommendations are made:

1. Provide natural gas leak detection in the proposed co-generation plant building with, at least, an alarm in the control room.
2. Provide an actuated valve on the natural gas supply pipe outside of the co-generation plant building for isolation in an emergency.
3. Given the high natural gas pressure in the supply pipeline, class the pipe as a critical pipe and therefore perform routine inspections and integrity checks.
4. **Include the pipe design controls as detailed in AS2885, in particular, for the section of the low pressure pipe under Abernethy's Creek given the risk of corrosion and possible scouring and wash-away events.**

7 APPENDIX A – METEOROLOGICAL DATA

**Preliminary Hazard Analysis, Shoalhaven Starches,
Co-Generation Plant**

Appendix A - Meteorological Data

The following data is a summary of climate data obtained from the Bureau of Meteorology. The data summarises the local weather / wind conditions for various atmospheric stability classes and wind directions from 2010 to 2017.

| Wind Direction | Stability Class / Wind Speed (m/s) | | | | | | | |
|----------------|------------------------------------|------------|-------------|-------------|------------|-------------|------|--|
| | Percentages: | | | | | | | |
| | A2 | B3 | C5 | D5 | E3 | F1.5 | | |
| N | 1.5 | 2.2 | 1.4 | 3.9 | 0.5 | 5.8 | 15.4 | |
| NE | 0.5 | 0.7 | 1.4 | 2.7 | 0.2 | 0.2 | 5.6 | |
| E | 0.4 | 0.7 | 2.4 | 3.4 | 0.2 | 0.3 | 7.4 | |
| SE | 0.3 | 0.6 | 1.6 | 3.6 | 0.2 | 0.5 | 6.8 | |
| S | 0.2 | 0.6 | 2.4 | 10.8 | 0.5 | 0.8 | 15.4 | |
| SW | 0.1 | 0.2 | 0.7 | 4.5 | 0.8 | 1.2 | 7.6 | |
| W | 0.2 | 0.8 | 3.8 | 9.9 | 2.0 | 3.8 | 20.6 | |
| NW | 0.6 | 2.0 | 3.9 | 9.3 | 2.3 | 2.9 | 21.1 | |
| | | | | | | | | |
| Totals: | 3.9 | 8.0 | 17.7 | 48.1 | 6.9 | 15.5 | | |

8 REFERENCES

- 1 Department of Planning and Infrastructure (NSW) *Hazardous Industry Planning Advisory Paper No 6 – Hazard Analysis*, January, 2011
- 2 Department of Planning and Infrastructure (NSW) *Hazardous Industry Planning Advisory Paper No 4 – Risk Criteria for Land Use Safety Planning*, January, 2011
- 3 ICI HAZAN Course Manual, 1997
- 4 Centre for Chemical Process Safety, *Guidelines for Chemical Process Quantitative Risk Analysis*, 2000
- 5 UK HSE, *Failure Rate and Event Data for use within Risk Assessments*, 28/06/2012
- 6 UKOOA, *IP Research Report, Ignition Probability Review, Model Development and Look-Up Correlations*, January 2006