



PCU025650



2 September 2011

Kate McDonald  
NSW Department of Planning and Infrastructure  
GPO Box 39  
Sydney NSW 2001

Department of Planning  
Received  
5 SEP 2011  
Scanning Room

Dear Ms McDonald,

**MP10\_0171 Mixed Use Residential, Retail and Commercial Development, at 330 Church Street Parramatta**

The proposed development is currently on a site serviced by an Endeavour Energy indoor substation (1841) which supplies the existing vacant building.

The applicant's proposal shows a new indoor substation within the East Tower development of this site. It appears from the applicants plans that the existing substation (1841) would need to be demolished to enable the development to proceed. There are also associated easements over this existing substation which would need to be extinguished.

This new development is likely to have a significant electrical load requirement.

Accordingly, it is essential that prior to approval of this development, the developer makes arrangements for electricity supply with Endeavour Energy. This will enable a determination of a suitable size indoor substation room for the ultimate electrical load of the new site as well as the available electrical capacity in the Endeavour Energy network and any other requirements that may apply.

Your contact in relation to the finalisation of a suitable connection arrangement in the first instance would be Mr David Ho (Network Connections Branch) at Endeavour Energy on 9853 7901.

Yours faithfully

Matthew Webb  
Manager Strategic Asset Management  
Network Development  
In reply please quote file no.: 2011/00095/001