



PCU025525



29 August 2011

Enguang Lee
NSW Department of Planning
GPO Box 39
Sydney NSW 2001

Department of Planning
Received
1 SEP 2011
Scanning Room

Dear Mr Lee

**ENVIRONMENTAL ASSESSMENT:
CONSTRUCTION OF BUILDINGS 6,9,10 & 17 (STAGE 2 RESIDENTIAL DEVELOPMENT) AT 61
MOBBS LANE, EPPING (FORMER CHANNEL 7 SITE) MP11-0048**

In response to the Public Notification to the above project, Endeavour Energy offers the following comments.

The estimated 221 apartments under this assessment for Stage 2 are expected to be supplied with electricity initially sourced from the existing high voltage network. This supply will need to be of underground construction and would require the installation of a substation on the applicants site so that low voltage supplies can be made available to the apartment blocks.

The developer or their representative will need to submit an "Application for Connection of Load" to enable the connection of these loads.

Full development of the former Channel 7 site will also require a number of new substation sites to be installed at suitable locations on site so that low voltage supplies can be made available to the various apartment blocks. This will require further assessment by Endeavour Energy when an "Application for Connection of Load" is submitted by the applicant to determine if electrical capacity is available and whether electrical headworks are required on the network.

Your contact officer is John Phillips (Network Planner) on 9853 6571 at Endeavour Energy.

Yours faithfully

for 

Matthew Webb
Manager Strategic Asset Management
Network Development
Endeavour Energy

In reply please quote file no.: 2010/00451/001