



File Ref. No: FRN25/600 BFS26/1383 7000000373
TRIM Doc. No: D26/34295
Contact: Inspector Chris Naisby

3 March 2026

RITA HATEM
NSW Department of Planning, Housing and Infrastructure
Locked Bag 5022
PARRAMATTA NSW 2124

Dear Rita,

Re: Advice on Environmental Impact Statement (EIS) – GAROO SOLAR FARM – 291 GAROO ROAD, GAROO NSW 2340 (SSD-79747209)


Fire and Rescue NSW (FRNSW) acknowledge correspondence received on 26 February 2026, requesting advice on the EIS for GAROO SOLAR FARM – 291 GAROO ROAD, GAROO NSW 2340 (SSD-79747209). FRNSW have reviewed the EIS with particular focus to Appendix Q – Preliminary Hazard Analysis

The EIS details a 360MW/1440MWh Battery Energy Storage System (BESS). It has been the experience of FRNSW that BESS Facilities present special problems of fighting fire and suitable additional provisions are likely to be required in accordance with E1D17 and E2D21 of the National Construction Code 2022¹. FRNSW therefore recommend the following conditions:

1. Prior to construction a Fire Safety Study (FSS) is developed in accordance with the requirements of the Hazardous Industry Planning Advisory Paper (HIPAP) No.2² and submitted to FRNSW for review.
 - The FSS is to be used to inform the design and as such it is FRNSW Position³ that the FSS be developed to the satisfaction of FRNSW prior to any further submission being made to FRNSW; this includes: an Initial Fire Safety Report (IFSR) and / or Performance-Based Design Brief / Fire Engineering Brief Questionnaire (FEBQ).
 - The FSS should be prepared consistent with the FRNSW Fire Safety Guideline Technical Information – Large scale external lithium-ion battery energy storage systems – Fire safety study considerations⁴.
2. Prior to occupation or commissioning an Emergency Plan (EP) is developed for the site in accordance with HIPAP No.1⁵.
3. Prior to occupation or commissioning an Emergency Services Information Package (ESIP) is developed for the site in accordance with FRNSW fire safety guideline – Emergency services information package and tactical fire plans⁶.

Project proponents undertaking the FSS are to engage directly with FRNSW by submitting all correspondence electronically to FireSafety@fire.nsw.gov.au and reference FRNSW file number FRN25/600. Further information regarding FRNSW Meetings⁷ and FRNSW Written Reports⁸ can be found at the FRNSW Building Fire Safety Industry Portal⁹.

Yours sincerely,



Richard Jay
A/Team Leader
Fire Safety Liaison Unit

Cc: Rita.Hatem@planning.nsw.gov.au

¹ <https://ncc.abcb.gov.au/editions/ncc-2022>

² <https://www.planning.nsw.gov.au/sites/default/files/2023-03/hazardous-and-offensive-planning-advisory-paper-no-2-fire-safety-study-guidelines.pdf>

³ <https://www.fire.nsw.gov.au/page.php?id=9447&position=51>

⁴ <https://www.fire.nsw.gov.au/gallery/files/pdf/guidelines/Tech%20info%20sheet%20-%20Large-scale%20external%20LiBESS%20-%20Fire%20safety%20study%20considerations.pdf>

⁵ <https://www.planning.nsw.gov.au/sites/default/files/2023-03/hazardous-industry-planning-advisory-paper-no-1-emergency-planning.pdf>

⁶ <https://www.fire.nsw.gov.au/gallery/files/pdf/guidelines/03%20Emergency%20services%20information%20package%20and%20tactical%20fire%20plans.pdf>

⁷ <https://www.fire.nsw.gov.au/page.php?id=9193>

⁸ <https://www.fire.nsw.gov.au/page.php?id=9156>

⁹ <https://www.fire.nsw.gov.au/page.php?id=9140>