



Australian Government
Civil Aviation Safety Authority

AIR NAVIGATION, AIRSPACE AND AERODROMES BRANCH

CASA Ref: F25/30984-90

DPIE ref: SSD-73456206-Mod-1 Email 12 June 2026

Cameron Thomson

cameron.thomson@dpi.nsw.gov.au

The NSW DPHI

ADVICE ON MODIFICATION - UNSW E25 BIOLINK BUILDING PROJECT MOD 1 - CASA COMMENTS

The Department has sent CASA a request for advice in relation to the Modification 1 - Design changes and removal of contributions. The only item that could possibly affect Aviation Safety is the maximum height. The Modification Report advises "Minor increase in the maximum building height from 32.89m (RL 86.35) to 33.24m (RL 86.686). Total building height increased to RL 96.298 due to new mechanical flues to satisfy compliance requirements". The Architectural Drawings confirms a height to the top of the flue to be RL 96.298m. The Aviation Impact Assessment Report V1.7 7 Apr 26 remains valid.

There are other buildings in the vicinity on campus RL 100m+. CASA has no objections to the building proposal including Mod-1 increase in height to RL 96.298m. The proposed building including Mod-1 will not be a risk to Aviation Safety.

Yours sincerely

David Alder

David Alder
Aerodrome Engineer

22 June 2026