



File Ref. No: FRN25/896 BFS26/4538 7000002752
TRIM Doc. No: D26/106653
Contact: Senior Firefighter Sarah Tobin

15 July 2026

RASMUS ALTENKAMP
NSW Department of Planning, Housing and Infrastructure
Locked Bag 5022
PARRAMATTA NSW 2124

Dear Rasmus,

Re: Advice on Environmental Impact Statement (EIS) – AIR LIQUIDE CO2 PROCESSING PLANT – BOLONG RD, BOMADERRY NSW (SSD-80824235)

Fire and Rescue NSW (FRNSW) acknowledge correspondence received on 18 June 2026, requesting advice on the EIS for AIR LIQUIDE CO2 PROCESSING PLANT – BOLONG RD, BOMADERRY NSW (SSD-80824235).

FRNSW have reviewed the EIS with particular focus to the Hazard and Risk Assessment. FRNSW recommend the following conditions:

1. Prior to occupation or commissioning an Emergency Plan (EP) is developed for the site in accordance with HIPAP No.1ⁱ.
2. Prior to occupation or commissioning an Emergency Services Information Package (ESIP) is developed for the site in accordance with FRNSW fire safety guideline – Emergency services information package and tactical fire plansⁱⁱ.

For further information please contact the Fire Safety Liaison Unit, referencing FRNSW file number BFS26/4538. Please ensure that all correspondence in relation to this matter is submitted electronically to FireSafety@fire.nsw.gov.au.

Yours sincerely,

Station Officer Richard Jay
Manager
Fire Safety Liaison Unit

Cc: rasmus.altenkamp@dphi.nsw.gov.au

ⁱ <https://www.planning.nsw.gov.au/sites/default/files/2023-03/hazardous-industry-planning-advisory-paper-no-1-emergency-planning.pdf>

ⁱⁱ <https://www.fire.nsw.gov.au/gallery/files/pdf/guidelines/03%20Emergency%20services%20information%20package%20and%20tactical%20fire%20plans.pdf>