

17 April 2020

Contact: *Justine Clarke*

Telephone: *02 9865 2402*

Our ref: *D2020/35253*

Shaun Williams
Planning Officer, Industry Assessments
Department of Planning, Industry and Environment
GPO Box 39
Sydney NSW 2001

Dear Mr Williams

SSD 9601 Horsley Park Brickworks Plant 2 Upgrade – Supplementary Response to Submissions

Thank you for your email dated 8 April 2020 seeking WaterNSW's comment on the supplementary response to submissions (SRTS) report for the above development. The applicant has now addressed WaterNSW comments sufficiently and it is considered that their response is reasonable in relation to the potential impact to WaterNSW lands, assets and infrastructure. WaterNSW therefore notes the SRTS and reiterates suggested conditions for consideration in the final determination (our ref: D2019/121186).

Requested conditions:

- *The proposal must not result in an increase in overland flow of water into the Pipelines corridor of either quantity, quality or velocity. The development must be designed, operated and maintained to ensure post-development flows do not exceed pre-development flows into and through the Pipelines corridor.*
- *Stormwater directed to or across the Pipelines corridor is not acceptable, except at an approved point of discharge for the development.*
- *The proposal must have a neutral or beneficial impact on water quality.*
- *Erosion and sediment controls are to be designed, installed and maintained in accordance with the Blue Book, Landcom (2004) Managing Urban Stormwater: Soils and Construction.*
- *24 hour all weather access to the WaterNSW Pipelines corridor shall be retained or provided for WaterNSW staff and contractors.*
- *All incidents that affect or could affect the WaterNSW Pipelines corridor shall be reported to WaterNSW on the 24 hour Incident Notification Number 1800 061 069 as a matter of urgency.*

If you have any questions regarding this letter, please contact Justine Clarke at justine.clarke@waternsw.com.au.

Yours sincerely

A handwritten signature in black ink, appearing to read "AK", with a long horizontal flourish extending to the right.

ALISON KNIHA
Catchment Protection Planning Manager