



## Department of Planning and Environment

Ingrid Berzins  
Planning and Assessment Group  
NSW Department of Planning and Environment  
Email: [Ingrid.berzins@planning.nsw.gov.au](mailto:Ingrid.berzins@planning.nsw.gov.au)

03 March 2022

Dear Ms Berzins

### **Re: Wentworthville Northside West Clinic Extension (SSD-17899480) - Environmental Impact Statement (EIS)**

I refer to your email of 1 February 2022 to the Department of Planning and Environment (DPE) Water and the Natural Resources Access Regulator (NRAR) about the above matter.

The project is for construction of a three-storey extension to Wentworthville Northside West Clinic and a new car park as well as internal and external alterations to the existing building.

The following recommendation is provided by NRAR.

#### Pre-Determination

Should groundwater be intercepted a Water Access Licence (WAL) under the Water Management Act 2000 must be obtained unless the take is less than or equal to 3ML of water per year for any aquifer interference activities listed in Clause 7 of Schedule 4 of the Water Management (General) Regulation 2018. For more information visit <https://www.dpie.nsw.gov.au/nrar/how-to-apply/water-licences/Groundwater>.

Any further referrals to DPE Water and NRAR can be sent by email to [water.assessments@dpie.nsw.gov.au](mailto:water.assessments@dpie.nsw.gov.au) or to the following coordinating officer within DPE Water:  
Donna Priestley – Senior Project Officer  
E: donna.priestley@dpie.nsw.gov.au  
M: 0456 738 727

Yours sincerely

Liz Rogers  
Senior Project Officer, Assessments, Knowledge Division  
**Department of Planning and Environment: Water**