



File Ref. No: FRN22/711 BFS22/913 8000019985  
TRIM Doc. No: D22/20012  
Contact: Station Officer Aaron Ross

16 March 2022

Gabrielle Allan  
NSW Department of Planning, Industry and Environment  
Locked Bag 5022  
PARRAMATTA NSW 5022

Dear Gabrielle Allan,

**Re: Advice on Environmental Impact Statement (EIS) – MOD 9 - Gas Management Infrastructure (DA60-03-2001-Mod-9) Exhibition (EXH-38038682)**

Fire and Rescue NSW (FRNSW) acknowledge correspondence received on the 04 March 2022, requesting advice on the Modification Report, MOD 9 - Gas Management Infrastructure (DA60-03-2001-Mod-9) Exhibition (EXH-38038682).

FRNSW have reviewed the Modification Report and make the following comments:

1. The proposal is located within a Rural Fire Service (RFS) district within the Wollongong LGA and is therefore covered by the "Illawarra Bush Fire Risk Management Plan". The RFS are the appropriate agency for advice and comment regarding Asset Protection Zones (APZ), Bushfire Attack Levels (BAL), vegetation management, access, and water supply objectives.
2. It is deemed that the proposal has limited scope and application in regard to fire and life safety in the built environment.

Due to the uniqueness and complexity of the site, and to ensure first responders have information readily available to render safe any incident, FRNSW make the following recommendations:

1. That a comprehensive ERP is developed for the site in accordance with HIPAP No.1.
2. That an Emergency Services Information Package (ESIP) be prepared in accordance with FRNSW fire safety guideline – Emergency services information package and tactical fire plans.<sup>1</sup>

---

<sup>1</sup> [https://www.fire.nsw.gov.au/gallery/files/pdf/guidelines/guidelines\\_ESIP\\_and\\_TFP.pdf](https://www.fire.nsw.gov.au/gallery/files/pdf/guidelines/guidelines_ESIP_and_TFP.pdf)

For further information please contact the Operational Liaison and Special Hazards Unit, referencing FRNSW file number BFS22/913. Please ensure that all correspondence in relation to this matter is submitted electronically to [firesafety@fire.nsw.gov.au](mailto:firesafety@fire.nsw.gov.au).

Yours sincerely,

A handwritten signature in black ink, appearing to read 'John Hawes', with a stylized flourish at the end.

Superintendent John Hawes  
Manager  
Operational Liaison Special Hazards Unit

Cc: [gabrielle.allan@dpie.nsw.gov.au](mailto:gabrielle.allan@dpie.nsw.gov.au)