



Your ref: SSD 17352813
File no: MC-21-00001

8 April 2022

NSW Department of Planning, Industry and Environment
GPO Box 39
SYDNEY NSW 2001

Recipient Delivery David.Koppers@planning.nsw.gov.au

Attention: Mr Koppers

Dear Mr Koppers

**SSD 17352814 – Huntingwood Processing Facility Expansion – 65
Huntingwood Drive, Huntingwood**

Thank you for your correspondence dated 25 March 2022 requesting our advice for the above matter.

We have reviewed the proposal and we object to it until our issues listed in the attachment to this letter have all been addressed.

We request that the information responding to these issues be referred back to us for comments and conditions, before any final determination of this application is made by the Department.

If you would like to discuss this matter further, please contact our Manager Development Assessment, Judith Portelli on 9839 6228.

Yours faithfully

Peter Conroy
Director City Planning and Development

Connect - Create - Celebrate

Council Chambers - 62 Flushcombe Road - Blacktown NSW 2148

Telephone: (02) 9839 6000 - DX 8117 Blacktown

Email: council@blacktown.nsw.gov.au - Website: www.blacktown.nsw.gov.au

All correspondence to: The Chief Executive Officer - PO Box 63 - Blacktown NSW 2148

Blacktown Council's submission to SSD 17352813 – Huntingwood Processing Facility Expansion

1. Drainage Engineering Issues

- a. Tertiary treatments in series are not permitted.
 - Provide separate and total catchments for each Jellyfish.
 - Provide the complete jellyfish calculations as per the WSUD developer handbook chapter 12.13 and in particular 12.13.3.
 - The jellyfish levels are not as per 12.13.3. inlets and outlets are to be set at different levels.
 - Provide the 1EY HGL for the jellyfish calculations.
- b. Revise stormfilter designs and catchment plans as a result.
- c. Provide invert levels of drainage network and ensure that backwater levels from proprietary systems are considered.
- d. Submit amended plans and updated MUSIC (standard) model.