



File Ref. No: BFS22/1543
TRIM Doc. No: D22/31354
Contact: Station Officer Lynden Moyes

26 April 2022

Mandana Mazaheri
NSW Department of Planning, Industry and Environment
Locked Bag 5022
PARRAMATTA NSW 2124

Dear Mandana,

Re: Advice on Environmental Impact Statement (EIS) - Kurri Kurri Lateral Pipeline Project - SSI-22338205

Fire and Rescue NSW (FRNSW) acknowledge correspondence received on the 7 April, 2022, requesting advice on the EIS for **Kurri Kurri Lateral Pipeline Project - SSI-22338205**. FRNSW have reviewed the EIS along with the Preliminary Hazard Analysis (PHA).

After a review of the documentation FRNSW make the following recommendations:

1. That adequate separation distance is maintained around surface infrastructure (such as offtake facility and compressor station) to negate the radiant heat effects from worst credible scenario events as described in the PHA.
2. That a comprehensive Emergency Response Plan (ERP) is developed for the site in accordance with HIPAP No.1.
3. That an Emergency Services Information Package (ESIP) be prepared in accordance with FRNSW fire safety guideline – [Emergency services information package and tactical fire plans](#).
4. An Emergency Information Cabinet is located at the entry to each of the surface sites and copies of the ESIP and ERP are located in the cabinets.

For further information please contact the Operational Liaison and Special Hazards Unit, referencing FRNSW file number BFS22/1543. Please ensure that all correspondence in relation to this matter is submitted electronically to firesafety@fire.nsw.gov.au.

Yours sincerely,

A handwritten signature in black ink, appearing to read "John Hawes".

Superintendent John Hawes
Manager
Operational Liaison Special Hazards Unit

Cc: mandana.mazaheri@planning.nsw.gov.au