



File Ref. No: FRN13/2616 BFS22/1088 8000020154  
TRIM Doc. No: D22/21933  
Contact: Station Officer Aaron Ross

23 March 2022

Emma Barnet  
NSW Department of Planning, Industry and Environment  
Locked Bag 5022  
PARRAMATTA NSW 2124

Dear Emma Barnet,

**Re: Advice on Response to Submissions (RTS) – Kings Park Metal Recovery and Recycling Facility Expansion (SSD-10396)**

Fire and Rescue NSW (FRNSW) acknowledge correspondence received on 23 December 2021, requesting advice on the RTS for Kings Park Metal Recovery and Recycling Facility Expansion (SSD-10396). FRNSW also acknowledge correspondence from Sell & Parker received on 24 February 2022, with additional information regarding the Final Stockpile Plan and Evacuation Plans. FRNSW have reviewed the RTS along with the Final Stockpile Plan and submitted Evacuation Plans.

FRNSW note the expansion is for increased throughput from the existing approved threshold of 350,000 Tonnes Per Annum (tpa) to 600,000 tpa and is purely operational and does not involve changes to installed infrastructure or processes on site. FRNSW further note there will be no changes to fire vehicle access or manoeuvrability during active operational hours.

FRNSW make the following recommendations:

1. That the FRNSW fire safety guideline for Fire Safety in Waste Facilities that includes legislated requirements and development considerations (planning) is continued to be utilised and consulted<sup>1</sup>.
2. That the ERP developed for the site in accordance with HIPAP No.1 is updated and current.
3. That the Emergency Services Information Package (ESIP) prepared in accordance with FRNSW fire safety guideline – Emergency services information package and tactical fire plans<sup>2</sup> is updated and current.

---

<sup>1</sup> [https://www.fire.nsw.gov.au/gallery/files/pdf/guidelines/guidelines\\_fire\\_safety\\_in\\_waste\\_facilities.pdf](https://www.fire.nsw.gov.au/gallery/files/pdf/guidelines/guidelines_fire_safety_in_waste_facilities.pdf)

<sup>2</sup> [https://www.fire.nsw.gov.au/gallery/files/pdf/guidelines/guidelines\\_ESIP\\_and\\_TFP.pdf](https://www.fire.nsw.gov.au/gallery/files/pdf/guidelines/guidelines_ESIP_and_TFP.pdf)

For further information please contact the Operational Liaison and Special Hazards Unit, referencing FRNSW file number BFS22/1088. Please ensure that all correspondence in relation to this matter is submitted electronically to [firesafety@fire.nsw.gov.au](mailto:firesafety@fire.nsw.gov.au).

Yours sincerely,

A handwritten signature in black ink, appearing to be 'J. Hawes', written over a faint circular stamp.

Superintendent John Hawes  
Manager  
Operational Liaison Special Hazards Unit

Cc: [emma.barnet@planning.nsw.gov.au](mailto:emma.barnet@planning.nsw.gov.au)