

12 October 2022

TfNSW Reference: SYD20/01146/08
Departments Reference SSD-9794683

Bruce Zhang
Industry Assessments
Department of Planning and Environment
GPO Box 39
SYDNEY NSW 2001

Email: Bruce.Zhang@planning.nsw.gov.au

**MODIFICATION AMENDED PLANS FOR OAKDALE WEST ESTATE STAGE 3 - WAREHOUSES 2A, 2C, 2D, 2E - 2
- 18 ALDINGTON ROAD, KEMPS CREEK**

Reference is made to the Department's referral dated 21 May 2022 with regard to the abovementioned State Significant Development Application (SSDA), which was referred to Transport for NSW (TfNSW) Services for comments.

As advised previously in our correspondence 20 November 2021, TfNSW raised concerns regarding the proximity of the building 2C-2 car entry access to the proposed signalised intersection at the future Southern Link Road (SLR). TfNSW does not support the modification to position the driveway a further 31 metres closer to the Southern Link Road.

Should you have any further enquiries in relation to this matter, please do not hesitate to contact Brett Morrison, Development Assessment Officer, by email at development.sydney@transport.nsw.gov.au.

Yours sincerely,



David Rohloff
Senior Manager Land Use Assessment Central and Western
Planning and Programs,
Greater Sydney Division

OFFICIAL