



File Ref. No: FRN21/1739 BFS22/5117 8000024111
TRIM Doc. No: D22/88123
Contact: Station Officer Luke Loseby

6 October 2022

JACK TURNER
NSW Department of Planning and Environment
Locked Bag 5022
PARRAMATTA NSW 2124

Dear Jack,

Re: Advice on Amendment Report - KURRI KURRI LATERAL PIPELINE PROJECT (SSI-22338205)

Fire and Rescue NSW (FRNSW) acknowledge correspondence received on the 4 October 2022, requesting advice on the Amendment Report - KURRI KURRI LATERAL PIPELINE PROJECT (SSI-22338205). FRNSW have reviewed the Submission Report and Amendment Report.

FRNSW note the 'Adequate separation distance' response at 4.6.1 of the Submissions report, given the relocation of the JGN offtake facility, and the response that 'thermal radiation impacts could extend off-site beyond the boundary of the JGN Offtake Facility' FRNSW recommend that:

1. Adequate separation distance be maintained around the JGN Offtake Facility and consideration is given to potential future developments within these distances.

FRNSW note the 'Post Approval' response at 4.6.2 of the Submissions report, the response to the Emergency Services Information Package (ESIP) and the Emergency Information Cabinet location when implemented, would satisfy the recommendations made by FRNSW in our previous letter out concerning this matter dated 26 April 2022 (D22/31354).

The response regarding the Emergency Response Plan (ERP) focusses on the bushfire threat assessment and management, however, Hazardous Industry Planning Advisory Paper No.1 Emergency Planning (HIPAP 1) states that the ERP should be sufficiently comprehensive to cover the full range of activities at the facility. FRNSW recommend that:

2. The Emergency Response Plan (ERP) should consider all types of emergencies, as listed in section 3.6.1 of HIPAP 1, and should not be limited to emergencies relating to bushfire.

For further information please contact the Operational Liaison and Special Hazards Unit, referencing FRNSW file number BFS22/5117. Please ensure that all correspondence in relation to this matter is submitted electronically to firesafety@fire.nsw.gov.au.

Yours sincerely,

A handwritten signature in black ink, appearing to be 'J. O'Carroll', written over a horizontal line.

Superintendent James O'Carroll
Manager
Operational Liaison and Special Hazards Unit

Cc: jack.turner@planning.nsw.gov.au