



File Ref. No: FRN23/2399 BFS23/3886 8000029501
TRIM Doc. No: D23/67218
Contact: Senior Firefighter Barton Hill

24 July 2023

Nestor Tsambos
NSW Department of Planning and Environment
Locked Bag 5022
PARRAMATTA NSW 2124

Dear Nestor,

Re: Advice on Secretary's Environmental Assessment Requirements (SEARs) – MAYFAIR SOLAR FARM (SSD-60074458)

Fire and Rescue NSW (FRNSW) acknowledge correspondence received on 14/07/2023, requesting input into the preparation of the SEARs for the MAYFAIR SOLAR FARM (SSD-60074458). FRNSW have reviewed the SEARs along with the Scoping Report and make the following comments:

There is currently insufficient information available regarding the fire safety and emergency response management aspects of the project. FRNSW notes the Scoping Report details a 60 MW BESS. It is the experience of FRNSW that BESS facilities present special problems of firefighting when responding to and managing an incident. FRNSW requests to be consulted and given the opportunity to review the hazard and risk analysis and provide comment regarding the proposed fire and life safety systems at the preliminary and final design phases of the project.

For further information please contact the Operational Liaison and Special Hazards Unit, referencing FRNSW file number BFS23/3886. Please ensure that all correspondence in relation to this matter is submitted electronically to firesafety@fire.nsw.gov.au.

Yours sincerely,

7914 

A/ Superintendent David Absalom
Manager
Operational and Liaison and Special Hazards Unit

Cc: nestor.tsambos@dpie.nsw.gov.au

