



File Ref. No: FRN24/1182 BFS24/2052 8000034782
TRIM Doc. No: D24/43229
Contact: Senior Firefighter Barton Hill

12 April 2024

PRAGYA MATHEMA
NSW Department of Planning and Environment
Locked Bag 5022
PARRAMATTA NSW 2124

Dear Pragya,

Re: Advice on Secretary's Environmental Assessment Requirements (SEARs) – MALLEE SOLAR FARM - DANSONS ROAD, MALLEE (SSD-69576706)

Fire and Rescue NSW (FRNSW) acknowledge correspondence received on 10 April 2024, requesting input into the preparation of the SEARs for the MALLEE SOLAR FARM - DANSONS ROAD, MALLEE (SSD-69576706). FRNSW have reviewed the SEARs along with the Scoping Report with particular focus to section 3 Project description and section 6.5 Hazards and risk.

FRNSW notes the Scoping Report details a 300MW/1200MWH BESS. BESS facilities present special problems of firefighting and special hazards exist that may require additional fire safety and management measures.

There is currently insufficient information available regarding the fire safety and emergency response management aspects of the project. If required, FRNSW will review and provide comment at the Exhibition stage of the project.

For further information please contact the Operational Liaison and Special Hazards Unit, referencing FRNSW file number BFS24/2052. Please ensure that all correspondence in relation to this matter is submitted electronically to firesafety@fire.nsw.gov.au.

Yours sincerely,

8579 Lynden Moyes

A/ Superintendent Lynden Moyes
Manager
Operational and Liaison and Special Hazards Unit

Cc: pragya.mathema@dpie.nsw.gov.au