



File Ref. No: FRN24/1749 BFS24/3343 8000035936
TRIM Doc. No: D24/068709
Contact: Senior Firefighter Gavin Scott

12 June 2024

MEGAN RAMSDALE
NSW Department of Planning and Environment
Locked Bag 5022
PARRAMATTA NSW 2124

Dear Megan,

Re: Advice on Secretary's Environmental Assessment Requirements (SEARs) – GARA BATTERY ENERGY STORAGE SYSTEM – 86 WOODLANDS ROAD (SSD-71680710)

Fire and Rescue NSW (FRNSW) acknowledge correspondence received on 6 June 2024, requesting input into the preparation of the SEARs for the GARA BATTERY ENERGY STORAGE SYSTEM – 86 WOODLANDS ROAD (SSD-71680710). FRNSW have reviewed the SEARs along with the Table 2 – Project summary.

FRNSW notes the Scoping Report details a 400MW/1760MWH BESS. BESS facilities present special problems of firefighting and special hazards exist that may require additional fire safety and management measures.

There is currently insufficient information available regarding the fire safety and emergency response management aspects of the project. If required, FRNSW will review and provide comment at the Exhibition stage of the project.

For further information please contact the Operational Liaison and Special Hazards Unit, referencing FRNSW file number BFS24/3343. Please ensure that all correspondence in relation to this matter is submitted electronically to firesafety@fire.nsw.gov.au.

Yours sincerely,

A handwritten signature in black ink, appearing to read "James O'Carroll".

Superintendent James O'Carroll
Manager
Operational and Liaison and Special Hazards Unit

Cc: megan.ramsdale@planning.nsw.gov.au