



File Ref. No: FRN24/3489 BFS24/7790 8000039527  
 TRIM Doc. No: D24/140315  
 Contact: Senior Firefighter Michael Millar

2 December 2024

EWAN REID  
 NSW Department of Planning, Housing and Infrastructure  
 Locked Bag 5022  
 PARRAMATTA NSW 2124

Dear Ewan,

**Re: Advice on Secretary's Environmental Assessment Requirements (SEARs) – HANWORTH BATTERY ENERGY STORAGE SYSTEM – HANWORTH ROAD, BANNABY (SSD-78179499).**

Fire and Rescue NSW (FRNSW) acknowledge correspondence received on 27 November 2024, requesting input into the preparation of the SEARs for the HANWORTH BATTERY ENERGY STORAGE SYSTEM – HANWORTH ROAD, BANNABY (SSD-78179499). FRNSW have reviewed the SEARs along with the Scoping Report with particular focus to Section 6.9. Hazards.


The Scoping Report details a 1.2 GW/4.8 GWh Battery Energy Storage System (BESS). It has been the experience of FRNSW that BESS Facilities present special problems of fighting fire and suitable additional provisions are likely to be required in accordance with E1D17 and E2D21 of the National Construction Code 2022<sup>1</sup>.

FRNSW will likely recommend a Fire Safety Study (FSS) be developed in accordance with the Hazardous Industry Planning Advisory Paper No 2<sup>2</sup> as a condition of consent. The FSS should be used to inform the design and as such it is FRNSW Position<sup>3</sup> that the FSS be developed to the satisfaction of FRNSW prior to any further submission being made to FRNSW; this includes: an Initial Fire Safety Report (IFSR) and / or Performance-Based Design Brief / Fire Engineering Brief Questionnaire (FEBQ).

The FSS should be prepared consistent with the relevant FRNSW Fire Safety Guidelines and FRNSW Technical Information Sheets<sup>4</sup> with particular focus to Large-scale external lithium-ion battery energy storage systems – Fire safety study considerations<sup>5</sup>.

Project proponents undertaking the FSS are to engage directly with FRNSW by submitting all correspondence electronically to [FireSafety@fire.nsw.gov.au](mailto:FireSafety@fire.nsw.gov.au) and reference FRNSW file number FRN24/3489. Further information regarding FRNSW Meetings<sup>6</sup> and FRNSW Written Reports<sup>7</sup> can be found at the FRNSW Building Fire Safety Industry Portal<sup>8</sup>.

Yours sincerely,



Superintendent Jim O'Carroll  
Manager  
Operational Liaison and Special Hazards Unit

Cc: [ewan.reid@planning.nsw.gov.au](mailto:ewan.reid@planning.nsw.gov.au)

---

<sup>1</sup> <https://ncc.abcb.gov.au/editions/ncc-2022>

<sup>2</sup> <https://www.planning.nsw.gov.au/sites/default/files/2023-03/hazardous-and-offensive-planning-advisory-paper-no-2-fire-safety-study-guidelines.pdf>

<sup>3</sup> <https://www.fire.nsw.gov.au/page.php?id=9447&position=51>

<sup>4</sup> <https://www.fire.nsw.gov.au/page.php?id=9166>

<sup>5</sup> <https://www.fire.nsw.gov.au/gallery/files/pdf/guidelines/Tech%20info%20sheet%20-%20Large-scale%20external%20LIBESS%20-%20Fire%20safety%20study%20considerations.pdf>

<sup>6</sup> <https://www.fire.nsw.gov.au/page.php?id=9193>

<sup>7</sup> <https://www.fire.nsw.gov.au/page.php?id=9156>

<sup>8</sup> <https://www.fire.nsw.gov.au/page.php?id=9140>