



File Ref. No: FRN21/3156 BFS25/5985 8000044795
 TRIM Doc. No: D25/101003
 Contact: Senior Firefighter Michael Millar

4 September 2025

CAMERON ASHE
 NSW Department of Planning, Housing and Infrastructure
 Locked Bag 5022
 PARRAMATTA NSW 2124

Dear Cameron,

Re: Advice on Environmental Impact Statement (EIS) – COBBORA SOLAR FARM – (SSD-29491142).


Fire and Rescue NSW (FRNSW) acknowledge correspondence received on 28 August 2025, requesting advice on the EIS for COBBORA SOLAR FARM – (SSD-29491142). FRNSW have reviewed the EIS with particular focus to the Appendix M (Preliminary Hazard Analysis).

The EIS details a 400MW/1600MWH Battery Energy Storage System (BESS). It has been the experience of FRNSW that BESS Facilities present special problems of fighting fire and suitable additional provisions are likely to be required in accordance with E1D17 and E2D21 of the National Construction Code 2022¹. FRNSW therefore recommend the following conditions:

1. Prior to construction a Fire Safety Study (FSS) is developed in accordance with the requirements of the Hazardous Industry Planning Advisory Paper (HIPAP) No.2² and submitted to FRNSW for review.
 - The FSS is to be used to inform the design and as such it is FRNSW Position³ that the FSS be developed to the satisfaction of FRNSW prior to any further submission being made to FRNSW; this includes: an Initial Fire Safety Report (IFSR) and / or Performance-Based Design Brief / Fire Engineering Brief Questionnaire (FEBQ).
 - The FSS should be prepared consistent with the FRNSW Fire Safety Guideline Technical Information – Large scale external lithium-ion battery energy storage systems – Fire safety study considerations⁴.
2. Prior to occupation or commissioning an Emergency Plan (EP) is developed for the site in accordance with HIPAP No.1⁵.
3. Prior to occupation or commissioning an Emergency Services Information Package (ESIP) is developed for the site in accordance with FRNSW fire safety guideline – Emergency services information package and tactical fire plans⁶.

Project proponents undertaking the FSS are to engage directly with FRNSW by submitting all correspondence electronically to FireSafety@fire.nsw.gov.au and reference FRNSW file number FRN21/3156. Further information regarding FRNSW Meetings⁷ and FRNSW Written Reports⁸ can be found at the FRNSW Building Fire Safety Industry Portal⁹.

Yours sincerely,



Superintendent James O'Carroll
Manager
Fire Safety Liaison Unit

Cc: cameron.ashe@dpie.nsw.gov.au

¹ <https://ncc.abcb.gov.au/editions/ncc-2022>

² <https://www.planning.nsw.gov.au/sites/default/files/2023-03/hazardous-and-offensive-planning-advisory-paper-no-2-fire-safety-study-guidelines.pdf>

³ <https://www.fire.nsw.gov.au/page.php?id=9447&position=51>

⁴ <https://www.fire.nsw.gov.au/gallery/files/pdf/guidelines/Tech%20info%20sheet%20-%20Large-scale%20external%20LiBESS%20-%20Fire%20safety%20study%20considerations.pdf>

⁵ <https://www.planning.nsw.gov.au/sites/default/files/2023-03/hazardous-industry-planning-advisory-paper-no-1-emergency-planning.pdf>

⁶ <https://www.fire.nsw.gov.au/gallery/files/pdf/guidelines/03%20Emergency%20services%20information%20package%20and%20tactical%20fire%20plans.pdf>

⁷ <https://www.fire.nsw.gov.au/page.php?id=9193>

⁸ <https://www.fire.nsw.gov.au/page.php?id=9156>

⁹ <https://www.fire.nsw.gov.au/page.php?id=9140>