

Our ref: Ridgely Creek Battery Energy Storage System-Mod-1 (SSD-48756517-Mod-1)

Mr David Walker  
Principal Town Planner

The Trustee for Ridgely Creek BESS Trust  
Suite 23.05, One International Towers  
100 Barangaroo Avenue Sydney  
New South Wales 2000

4 May 2026

---

**Subject:** Request for Additional Information

Dear Mr Walker

I refer to the assessment for the Ridgely Creek Battery Energy Storage System-Mod-1 (SSD-48756517-Mod-1). After careful consideration, the department is requesting that you provide additional information to confirm and provide details of the maximum Effective Energy Storage Capacity at the beginning of service life, as defined in Figure 1 of IEC 62933-1 Ed. 2.0 b:2024, Electrical Energy Storage (EES) Systems – Part 1 for each battery enclosure, and subsequently for the total BESS.

You are requested to provide the information, or notification that the information will not be provided, to the department by Monday 18 May 2026. If you cannot meet this deadline or do not intend to provide the additional information, please advise the department via the NSW planning portal.

The assessment period ceases to run between the date of this letter and the date you provide the additional information (or notification that the information will not be provided), in accordance with Part 4 Division 4 of the Environmental Planning and Assessment Regulation 2021.

If you have any questions, please contact Fadi Shakir on 02 9274 6277 or via email at [fadi.shakir@planning.nsw.gov.au](mailto:fadi.shakir@planning.nsw.gov.au).

Yours sincerely,



Andrew McIntyre  
Principal Planning Officer  
Renewable Assessments

