

19 May 2022

**RE: President Private Hospital
Authority Services**

Dear Stephen

President Private Hospital is located on the corner of President Avenue and Hotham Road, Kirrawee, NSW.

Investigations indicate that the site has access to the 225mm diameter Authority Sewer main located adjacent to President Avenue. The Sewer main is likely to be sufficient to serve the new expansion to the hospital; however, a Section 73 Application is required to be submitted to Sydney Water for approval.

A 200mm Authority Water Main is located on President Avenue. The water main has a maximum flow of 20L/s (pressure expected to be maintained for 95% of the time). To meet the sprinkler and Fire hydrant requirements Fire Tanks and Fire Pumps will be necessary. The available flow in the main appears sufficient for the domestic supply. A Section 73 Application is required to be submitted to Sydney Water for approval.

Regards,

A handwritten signature in blue ink, appearing to read "Sean Foord". The signature is stylized with a long horizontal line extending to the right.

Sean Foord
Associate Hydraulic and Fire