

Rob Beckett

From: Brendan.M Hurley [REDACTED]
Sent: Friday, 19 June 2020 11:52 AM
To: Tatsiana Bandaruk; Rob Beckett
Cc: Fire Safety
Subject: Culcairn Solar Farm (SSD 10288) Response To Submissions. BFS20/1800

**Culcairn Solar Farm (SSD 10288)
Response To Submissions**

Dear Tatsiana,

Thank you for your submission of the Response to Submissions for the above development to Fire & Rescue NSW (FRNSW) for agency review and comment.

It is understood that the RTS has been prepared by Sarah Hillis of NGH Pty Ltd on behalf of Neoen Australia Pty Ltd (the Applicant) to address matters identified in the EIS.

FRNSW reaffirm comments and recommendations previously submitted in preparation of the SEARs and maintain that they remain relevant in addressing fire and life safety considerations for the proposed development. Furthermore, it is recommended that should Development Consent be granted, a Condition of Consent be included that would require the Applicant to prepare a comprehensive fire safety study (FSS) for the Battery Energy Storage Systems (BESS) component of the development. The FSS should be developed in accordance with the requirements of Hazardous Industry Planning Advisory Paper No.2 (HIPAP No.2), and in consultation with and to the satisfaction of FRNSW.

If you have any queries regarding the above please contact the Fire Safety Infrastructure Liaison Unit, referencing FRNSW file number BFS20/1800. Please ensure that all correspondence in relation to this matter is submitted electronically to firesafety@fire.nsw.gov.au.

Regards
Brendan



A/INSPECTOR BRENDAN HURLEY
TEAM LEADER INFRASTRUCTURE LIAISON
FIRE SAFETY | Fire and Rescue NSW

[REDACTED]
1 Amarina Ave, Greenacre, NSW 2190

PREPARED FOR ANYTHING.

www.fire.nsw.gov.au



The information in this transmission may be confidential and/or protected by legal professional privilege, and is intended only for the person or persons to whom it is addressed. If you are not the intended recipient of this message you must not read, forward, print, copy, disclose, use or store in any way the information in this e-mail or any attachment it may contain. Please notify the sender immediately and delete or destroy all copies of this e-mail and any attachment it may contain.

Views expressed in the message are those of the individual sender, and are not necessarily the views of Fire and Rescue NSW (FRNSW). Use of electronic mail is subject to FRNSW policy and guidelines. FRNSW reserves the right to filter, inspect, copy, store and disclose the contents of electronic mail messages, as authorised by law.

This message has been scanned for viruses.
