



NSW RURAL FIRE SERVICE

Department of Planning and Environment (Sydney Offices)
GPO Box 39
Sydney NSW 2001

Your reference: SSD-10360337
Our reference: DA20201215004744-EIS & DA
Exhibition-1

ATTENTION: Brent Devine

Date: Monday 14 March 2022

Dear Sir/Madam,

Development Application

State Significant - EIS & DA Exhibition - Educational Establishment

St Philip's Christian College - 10 Lomas Lane & 210 Wine Country Drive NULKABA NSW 2325, 1//DP126765, 1//DP744377, 2//DP600895, 518//DP837571

I refer to your correspondence regarding the above proposal which was received by the NSW Rural Fire Service on 16/02/2022.

The NSW Rural Fire Service raises no objection to the proposed development, subject to the following conditions:

Emergency Management

The intent of measure is to provide suitable emergency and evacuation arrangements for occupants.

1. A Bush Fire Emergency Management and Evacuation Plan is prepared consistent with the:

- The NSW RFS document: *A Guide to Developing a Bush Fire Emergency Management and Evacuation Plan*; and,
- *NSW RFS Schools Program Guide*

The Bush Fire Emergency Management and Evacuation Plan should include planning for the early relocation of occupants.

Note: A copy of the Bush Fire Emergency Management and Evacuation Plan should be provided to the Local Emergency Management Committee for its information prior to occupation of the development. An Emergency Planning Committee needs to be established to consult with residents (and their families in the case of aged care accommodation and schools) and staff in developing and implementing an Emergency Procedures Manual. Detailed plans of all emergency assembly areas including on site and off site arrangements - as stated in AS 3745:2010 are to be clearly displayed, and an annual emergency evacuation exercise is to be conducted.

Asset Protection Zones

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au

Intent of measures: to provide suitable building design, construction and sufficient space to ensure that radiant heat levels do not exceed critical limits for firefighters and other emergency services personnel undertaking operations, including supporting or evacuating occupants.

2. At commencement of building works, and in perpetuity to ensure ongoing protection from the impact of bush fires, asset protection zones must be provided as shown on the plans prepared by Newcastle Bushfire Consulting (Figure 1: Site Constraints Map, dated 20 January 2022, p. 10). The whole asset protection zone is to be managed as an inner protection area.

When establishing and maintaining an inner protection area the following requirements apply in accordance with the requirements of Appendix 4 of *Planning for Bush Fire Protection 2019*:

- tree canopy cover should be less than 15% at maturity;
- trees at maturity should not touch or overhang the building;
- lower limbs should be removed up to a height of 2 m above the ground;
- tree canopies should be separated by 2 to 5 m;
- preference should be given to smooth-barked and evergreen trees;
- large discontinuities or gaps in the shrubs layer should be provided to slow down or break the progress of fire towards buildings;
- shrubs should not be located under trees;
- shrubs should not form more than 10% ground cover;
- clumps of shrubs should be separated from exposed windows and doors by a distance of at least twice the height of the vegetation;
- grass should be kept mown (as a guide, grass should be kept to no more than 100mm in height); and
- leaves and vegetation debris should be removed regularly.

3. Landscaping within the required asset protection zone must comply with Appendix 4 of *Planning for Bush Fire Protection 2019*. In this regard, the following principles are to be incorporated:

- A minimum 1 metre wide area (or to the property boundary where the setbacks are less than 1 metre), suitable for pedestrian traffic, must be provided around the immediate curtilage of the building;
- Planting is limited in the immediate vicinity of the building;
- Planting does not provide a continuous canopy to the building (i.e. trees or shrubs are isolated or located in small clusters);
- Landscape species are chosen to ensure tree canopy cover is less than 15% (IPA), and less than 30% (OPA) at maturity and trees do not touch or overhang buildings;
- Avoid species with rough fibrous bark, or which retain/shed bark in long strips or retain dead material in their canopies;
- Use smooth bark species of trees species which generally do not carry a fire up the bark into the crown;
- Avoid planting of deciduous species that may increase fuel at surface/ ground level (i.e. leaf litter);
- Avoid climbing species to walls and pergolas;
- Locate combustible materials such as woodchips/mulch, flammable fuel stores away from the building;
- Locate combustible structures such as garden sheds, pergolas and materials such as timber garden furniture away from the building; and
- Low flammability vegetation species are used.

4. A 20 metre break in the vegetation shall be managed with the vehicle crossings that dissect the riparian corridor that circles the sporting fields.

Construction Standards

The intent of measure is to provide suitable building design, construction and sufficient space to ensure that radiant heat levels do not exceed critical limits for firefighters and other emergency services personnel undertaking operations, including supporting or evacuating occupants.

5. New construction of the following buildings must comply with section 3 and section 5 (BAL 12.5) of the Australian Standard AS3959-2018 *Construction of buildings in bushfire-prone areas* or the relevant requirements of the *NASH Standard - Steel Framed Construction in Bushfire Areas* (incorporating amendment A - 2015) as well as complying with the construction requirements in Section 7.5 of *Planning for Bush Fire Protection 2019*:

- Buildings A3 and A4 - Junior School
- Building G - Performing Arts Centre
- Buildings H2 and H3 - Sports Hall

Access - Property Access

The intent of measure is to provide safe operational access for emergency services personnel in suppressing a bush fire while residents are accessing or egressing an area.

6. Access roads for special fire protection purpose (SFPP) developments must comply with general requirements of Table 6.8b of *Planning for Bush Fire Protection 2019*:

- access roads are two-wheel drive, all-weather roads;
- access is provided to all structures;
- traffic management devices are constructed to not prohibit access by emergency services vehicles;
- access roads must provide suitable turning areas in accordance with Appendix 3 of *Planning for Bush Fire Protection 2019*; and
- one way only public access roads are no less than 3.5 metres wide and have designated parking bays with hydrants located outside of these areas to ensure accessibility to reticulated water for fire suppression.

Water and Utility Services

The intent of measure is to provide adequate services of water for the protection of buildings during and after the passage of a bush fire, and to locate gas and electricity so as not to contribute to the risk of fire to a building.

7. The provision of water, electricity and gas must comply with the following in accordance with Table 6.8c of *Planning for Bush Fire Protection 2019*:

- reticulated water is to be provided to the development where available;
- fire hydrant, spacing, design and sizing complies with the relevant clauses of Australian Standard AS 2419;
- hydrants are and not located within any road carriageway;
- reticulated water supply to urban subdivisions uses a ring main system for areas with perimeter roads;
- fire hydrant flows and pressures comply with the relevant clauses of AS 2419;
- all above-ground water service pipes are metal, including and up to any taps;
- where practicable, electrical transmission lines are underground;
- where overhead, electrical transmission lines are proposed as follows:
 - lines are installed with short pole spacing (30m), unless crossing gullies, gorges or riparian areas; and
 - no part of a tree is closer to a power line than the distance set out in accordance with the specifications in *ISSC3 Guideline for Managing Vegetation Near Power Lines*.
- reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 and the requirements of relevant authorities, and metal piping is used;
- reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 - *The storage and handling of LP Gas*, the requirements of relevant authorities, and metal piping is used;
- all fixed gas cylinders are kept clear of all flammable materials to a distance of 10m and shielded on the hazard side;
- connections to and from gas cylinders are metal; polymer-sheathed flexible gas supply lines are not used; and
- above-ground gas service pipes are metal, including and up to any outlets.

For any queries regarding this correspondence, please contact Adam Small on 1300 NSW RFS.

Yours sincerely,

Kalpana Varghese
**Supervisor Development Assessment & Plan
Built & Natural Environment**