

Level 11, 345 George Street
Sydney NSW 2000
02 9241 4188
sydney@northrop.com.au
ABN 81 094 433 100

16.09.2020

Ref: SY192718-EL20-A

St Ignatius' College Riverview Limited
C/- epm Projects Pty Ltd
Level 2, 146 Arthur Street
North Sydney NSW 2060

To whom it may concern,

Re: St Ignatius' College Redevelopment - Stage 2 - Lighting Statement

The lighting design throughout the St Ignatius' College Redevelopment will be designed to be compliant with:

- Australian Standard AS/NZS 4282:2019

External lighting is proposed to comprise ground lighting, pole-mounted lights and architectural accent lighting, which are to be designed to have minimal upward lighting aspect, maintain compliance with AS4282:2019 (Control of the effects of Obtrusive Lighting) with respect to shielding neighbouring properties from glare and light spillage. External lighting will operate via a combination of in-switchboard time clocks, externally mounted photoelectric cells and conventional button panels within the Administration Area.

Yours faithfully,

A handwritten signature in black ink, appearing to read "Tommy Sailing".

Tommy Sailing
Electrical & ICT Engineer
Northrop Consulting Engineers Pty Ltd