

RE: Notice of Exhibition: Shop-top housing - 120-122 Smith Street, Wollongong (SSD-122745741) - Air Services

Summarize



Airport Developments <Airport.Developments@AirservicesAustr>

To Maddy Gunethilake

Cc Paula Bizimis; airspace.protection@casa.gov.au

This sender Airport.Developments@AirservicesAustralia.com is from outside your organization.

Reply Reply All Forward

Tue 30/06/2026 1:13 PM

OFFICIAL

Good afternoon Maddy,

I refer to your request for an Airservices assessment of the proposed activity at 120-122 Smith Street, Wollongong.

Airspace Procedures

With respect to procedures designed by Airservices in accordance with ICAO PANS-OPS and Document 9905, at a height of 108.50 m (356ft) AHD the development will not affect any sector or circling altitude, nor any instrument approach or departure procedure at Wollongong Hospital.

The development will not affect the Sydney RTCC.

Note: procedures not designed by Airservices at Wollongong Hospital were not considered in this assessment.

Communications/Navigation/Surveillance (CNS) Facilities

We have assessed the proposed activity to the above specified height for any impacts to Airservices Precision/Non-Precision Navigation Aids, Anemometers, HF/VHF/UHF Communications, A-SMGCS, Radar, PRIM, ADS-B, WAM or Satellite/Links and have no objections to it proceeding.

Note: Meteorological instruments not owned by Airservices were not considered in this assessment. The Bureau can be contacted at airport.developments@bom.gov.au

Air Traffic Control (ATC) Operations

There are no additional instructions/concerns from ATC.

Vertical Obstacle Notification

As this proposed activity is more than 30m (99ft) AGL, please follow the below notification process:

1. Complete the Vertical Obstacle Notification Form: [ATS-FORM-0085_Verical_Obstruction_Data_Form.pdf \(airservicesaustralia.com\)](#)
2. Submit completed form to: VOD@airservicesaustralia.com as soon as the development reaches the maximum height.

For further information regarding the reporting of tall structures, please contact the VOD team:

- Email - VOD@airservicesaustralia.com
- Or refer to: [Civil Aviation Safety Regulation Part 175 — Airservices and You - Airservices \(airservicesaustralia.com\)](#)

Summary

The proposed activity does not impact Airservices operations or facilities Wollongong Hospital.

Kind regards,
Amelia



Amelia Gontar (She/Her)

Aeronautical Information Specialist/Airport Developments
Da Vinci Building 101, 2A Borneia Road,
Brisbane Airport QLD 4008, Australia
www.airservicesaustralia.com



We acknowledge the Traditional Owners of Country throughout Australia and recognise their continuing connection to land, waters and culture. We pay our respects to their Elders past, present and emerging.