

Good Afternoon,

Transgrid reference number: 2022-107

Proposal: Notice of Exhibition – Great Western Battery Energy
Storage System (SSD-12346552)

Please see Transgrid response below:

- i. This is also not a customer project yet. We have received a connection enquiry but CPA is not yet executed.
- ii. The proponent will need to engage TransGrid via executing a connection Processes Agreement to finalise the connection to Transgrid's network.
- iii. The EIS will need to include all connection assets including the new transmission line cut in to the existing transmission line, a new transmission line/substation and access roads for the new infrastructure assets.
- iv. No further comment from Property and guided by Lumea's response., Transgrid Property will need to provide advice to Lumea upon request.
- v. I can advise that Lumea had requested for a landowner consent to be provided by ETMHC and awaiting further correspondence by PM Tim Barrass since November 2021.
- vi. The EIS (as per the link below) includes a underground transmission line connection from BESS to TG's Wallerawang 330kV substation and upgrades to the Wallerawang 330kV substation.
- vii. Transgrid will provide further comments/ review as part of the CPA process (including undertaking a due diligence review of the EIS/ environmental approval).

Regards

Michael

Michael Platt

Development Assessment and Control Officer | Community and Policy

Transgrid | 200 Old Wallgrove Road, Wallgrove, NSW, 2766

T: (02) 9620 0161 **M:** 0427 529 997

E: Michael.Platt@transgrid.com.au **W:** www.transgrid.com.au

