



NSW RURAL FIRE SERVICE

Department of Planning and Environment (Sydney Offices)
GPO Box 39
Sydney NSW 2001

Your reference: SSD-21184278
Our reference: DA20210603002251-SEARS-1

ATTENTION: Sally Munk

Date: Monday 7 June 2021

Dear Sir/Madam,

Development Application

State Significant – SEARS – Waste or resource management facility

Woodland Advanced Recovery Centre 609 COLLECTOR RD TARAGO NSW 2580, (none)

I refer to your correspondence regarding the above proposal which was received by the NSW Rural Fire Service on 21/05/2021.

In recognition of the potential for the development to increase the level of bush fire risk within the landscape and be impacted upon during a bush fire event, the following matters should be addressed in the Environmental Impact Statement:

- the aim and objectives of *Planning for Bush Fire Protection 2019*;
- identification of potential ignition sources during construction and operation of the development;
- storage of fuels and other hazardous materials;
- proposed bush fire protection measures for the development, including vegetation management and fire suppression capabilities;
- operational access for fire fighting appliance to the site; and
- emergency and evacuation planning.

For any queries regarding this correspondence, please contact Bradley Bourke on 1300 NSW RFS.

Yours sincerely,

Anna Jones

**Supervisor Development Assessment & Plan
Built & Natural Environment**

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au