

# FIRE SAFETY STRATEGY

## Jalco Tenancy Fitout

8 Johnston Crescent, Horsley Park

**Report Number:**

212002\_Jalco Tenancy\_FSS\_01

**Date:**

30/08/2021

**ESR**

Level 29, 20 Bond Street Sydney NSW 2000



**Affinity Fire Engineering (UK) Ltd**  
40 Bowling Green Lane  
London, EC1R 0NE  
+44 (0) 20 3384 0050  
[enquiries@affinity-eng.com](mailto:enquiries@affinity-eng.com)

**Affinity Fire Engineering**  
Suite 6.06, 6A Glen Street  
Milsons Point NSW 2061  
+61 2 9194 0590  
[enquiries@affinity-eng.com](mailto:enquiries@affinity-eng.com)

**Affinity Fire Engineering**  
Suite 123, 757 Bourke Street  
Docklands VIC 3008  
+61 3 8616 0686  
[enquiries@affinity-eng.com](mailto:enquiries@affinity-eng.com)

# REPORT DETAIL

**Project:** Jalco Tenancy Fitout  
**Address:** 8 Johnston Crescent, Horsley Park  
**Document:** Draft Issue - Fire Safety Strategy  
**Report No. & Ref.:** 212002\_FSS\_01

## Report Revision History

Rev	Date	Comment	Prepared By	Reviewed By
01	30/08/2021	Draft Issue	<b>Thomas Newton</b> <i>MEng Fire Safety Certifier - Fire Safety</i>	<b>Joshua Raines</b> <i>BEng (Civil) (Hons)</i>

### Copyright ©

All rights reserved. No part of this document may be reproduced, published, transmitted or adapted in any form or by any means without the written permission of AFFINITY Fire Engineering.

### Disclaimer

The information contained in this document is provided for the sole use of the recipient and no reliance should be placed on the information by any other person. In the event that the information is disclosed or furnished to any other person, AFFINITY Fire Engineering accepts no liability for any loss or damage incurred by that person whatsoever as a result of using the information.

# EXECUTIVE SUMMARY

---

Affinity Fire Engineering Pty Ltd has been engaged by ESR to develop a preliminary Fire Safety Strategy for the tenancy fitout of Warehouse 1 at 8 Johnston Crescent, Horsley Park in NSW. The tenancy shall be occupied by Jalco Australia Pty Ltd where the functional use of the space shall be for the manufacturing of washing liquids with onsite storage prior to final dispatch.

This Fire Safety Strategy (FSS) outlines the fire engineering principles that will be utilised in ensuring that the prescriptive non-compliances with the Deemed-to-Satisfy (DTS) provisions of the Building Code of Australia 2019 Amendment 1 (BCA) [1], as noted herein, are resolved through a fire engineered Performance Solution in order to conform to the building regulations.

The complete fire engineered analysis will form the Fire Engineering Report, and as such is not documented herein. This Fire Safety Strategy does however outline the construction and management requirements considered necessary to achieve an acceptable level of life safety within the building and satisfy the Performance Requirements of the BCA.

# CONTENTS

<b>1</b>	<b>INTRODUCTION &amp; SCOPE</b>	<b>1</b>
1.1	Overview	1
1.2	Fire Safety Objectives	1
1.3	Regulatory Framework of the Fire Engineering Assessment	2
1.4	Sources of Information	5
1.5	Limitations and Assumptions	5
<b>2</b>	<b>BUILDING CHARACTERISTICS</b>	<b>7</b>
2.1	Overview	7
2.2	Site Location	7
2.3	Building Description	8
2.4	Jalco Australia Fitout	9
2.5	Building Structure	10
2.6	Building Characteristic Assessment	11
<b>3</b>	<b>OCCUPANT CHARACTERISTICS</b>	<b>12</b>
3.1	Overview	12
3.2	Dominant Occupant Characteristics Assessment	12
<b>4</b>	<b>HAZARDS AND PROTECTIVE MEASURES</b>	<b>15</b>
4.1	Overview	15
4.2	Fire Hazards	15
4.3	Dangerous Goods	15
4.4	Insulated Sandwich Panels	17
4.5	Rooftop Solar Panels	18
4.6	Review of Relevant Fire Statistics	18
<b>5</b>	<b>BCA DTS NON-COMPLIANCE REVIEW</b>	<b>22</b>
5.1	Overview	22
5.2	BCA DTS Non-Compliance Assessment and Acceptance Criteria	22
<b>6</b>	<b>PROPOSED FIRE SAFETY STRATEGY</b>	<b>26</b>
6.1	Passive Fire Construction	26

---

6.2	Egress Provisions	29
6.3	Active Fire Protection Systems	30
6.4	Occupant Fire Fighting Facilities	31
6.5	Fire Brigade Intervention	32
6.6	Building Management Procedures	35
6.7	Dangerous Goods	35
<b>7</b>	<b>REFERENCES</b>	<b>38</b>
<b>APPENDIX A</b>	<b>FIRE STATISTICS</b>	<b>A-1</b>
<b>APPENDIX B</b>	<b>FIRE BEHAVIOUR</b>	<b>B-1</b>
<b>APPENDIX C</b>	<b>FIRE LOADS</b>	<b>C-1</b>

DRAFT

# 1 INTRODUCTION & SCOPE

---

## 1.1 Overview

This Fire Safety Strategy has been undertaken and nominates Performance Solutions for assessing compliance with the nominated Performance Requirements of the BCA [1] in accordance with the methodologies defined in the IFEG [3] and provide a workable and safe Fire Safety Strategy.

## 1.2 Fire Safety Objectives

The objective of the Fire Engineering Assessment is to develop a Fire Safety System, which satisfied the Performance Requirements of the NCC whilst maintaining an acceptable level of life safety, protection of adjacent property and adequate provisions for Fire Brigade intervention. At a community level, fire safety objectives are met if the relevant legislation and regulations are complied with. As stated in the NCC, *"Compliance with the NCC is achieved by satisfying the Performance Requirements"*. In addition to this, certain non-regulatory objectives exist as detailed below.

### 1.2.1 Fire Brigade Objectives

The overall philosophical Fire Brigade objectives throughout Australia are to protect life, property and the environment from fire, according to the Fire Brigade Intervention Model (FBIM) [12] as per the Fire Services State and Territory Acts and Regulations.

Over and above the requirements of the NCC, the Fire Brigade has functions with regard to property and environmental protection and considerations regarding occupational health and safety for its employees.

### 1.2.2 Building Regulatory Objectives

The following items are a summary of the fire and life safety objectives of the NCC:

- ▶ **Life safety of occupants** - the occupants must be able to leave the building (or remain in a safe refuge) without being subject to hazardous or untenable conditions. The objective of the Fire Engineering Assessment is to demonstrate that the proposed building design and fire safety systems would minimise the risk of exposing building occupants to hazardous or untenable conditions in an event of a fire.
- ▶ **Life safety of fire fighters** - fire fighters must be given a reasonable time to rescue any remaining occupants before hazardous conditions or building collapse occurs. The objective of the Fire Engineering Assessment is to demonstrate that the proposed building design and fire safety systems would facilitate fire brigade intervention and minimise the risk of exposing fire fighters to hazardous or untenable conditions in an event of a fire.

- ▶ **Protection of adjoining buildings** - structures must not collapse onto adjacent property and fire spread by radiation should not occur. The objective of the Fire Engineering Assessment is to demonstrate that the proposed building design and fire safety systems would minimise the risk of fire spreading from one building to another.

### 1.2.3 Non-Prescribed Objectives

Fire Engineering has an overarching benefit to many facets of the built environment where non-prescribed objectives can have an influence on the Fire Safety Strategy adopted. The client and stakeholders for the design have not requested any additional nonprescribed objectives are required to be met through the preparation of the FER.

## 1.3 Regulatory Framework of the Fire Engineering Assessment

### 1.3.1 National Construction Code Series - Building Code of Australia

One of the goals of the BCA [1] is the achievement and maintenance of acceptable standards of safety from fire for the benefit of the community. This goal extends no further than is necessary in the public interest and is considered to be cost effective and not needlessly onerous in its application.

Section A2.1 of the BCA [1] outlines how compliance with the Performance Requirements can be satisfied. These are as follows:

1. Performance Solution; or
2. Deemed-to-Satisfy Solution; or
3. Combination of (1) and (2).

Sections A2.2 of the BCA provides several different methods for determining that a Performance Solution complies with the Performance Requirements. These methods are summarised as follows:

- 1) A Performance Solution is achieved by demonstrating-
  - (a) Compliance with all relevant Performance Requirements; or
  - (b) The solution is at least equivalent to the Deemed-to-Satisfy Provisions.
- 2) A Performance Solution must be shown to comply with the relevant Performance Requirements through one or a combination of the following Assessment Methods:
  - (a) Evidence of suitability in accordance with Part A5 that shows the use of a material, product, plumbing and drainage product, form of construction or design meets the relevant Performance Requirements.
  - (b) Verification Methods including the following:
    - (i) The Verifications Methods in the NCC
    - (ii) Other Verification Methods accepted by the appropriate authority that show compliance with the relevant Performance Requirements.
  - (c) Expert Judgment.
  - (d) Comparison with the Deemed-to-Satisfy Provisions.

- 3) Where a Performance Requirement is satisfied entirely by a Performance Solution, in order to comply with (1) the following method must be used to determine the Performance Requirement or Performance Requirements relevant to the Performance Solution:
  - (a) Identify the relevant Performance Requirements from the Section or Part to which the Performance Solution applies.
  - (b) Identify Performance Requirements from the other Section or Parts that are relevant to any aspects of the Performance Solution proposed or that are affected by the application of the Performance Solution.
- 4) Where a Performance Requirement is proposed to be satisfied by a Performance Solution, the following steps must be undertaken:
  - (a) Prepare a performance-based design brief in consultation with relevant stakeholders.
  - (b) Carry out analysis, using one or more of the Assessment Methods listed in (2), as proposed by the performance-based design brief.
  - (c) Evaluate results from (b) against the acceptance criteria in the performance-based design brief.
  - (d) Prepare a final report that includes--
    - (i) all Performance Requirements and/or Deemed-to-Satisfy Provisions identified through A2.2(3) or A2.4(3) as applicable; and
    - (ii) identification of all Assessment Methods used; and
    - (iii) details of steps (a) to (c); and
    - (iv) confirmation that the Performance Requirement has been met; and
    - (v) details of conditions or limitations, if any exist, regarding the Performance Solution.

Section A2.3 of the BCA states that a solution that complies with the Deemed-to-Satisfy Provisions is deemed to have met the Performance Requirements. A Deemed-to-Satisfy Provision can be shown compliance with the Deemed-to-Satisfy Provisions through one or more of the following Assessment Methods:

- (a) Evidence of suitability in accordance with Part A5 that shows the use of a material, product, plumbing and drainage product, form of construction or design meets the relevant Performance Requirements.
- (b) Expert Judgement.

As described in Section A2.4 a combination of Performance Solutions and Deemed-to-Satisfy Solutions may be used to satisfy the Performance Requirements. When using a combination of solutions, compliance can be shown through the following, as appropriate:

- (a) Section A2.2 for assessment against the relevant Performance Requirements.
- (b) Section A2.3 for assessment against the relevant Deemed-to-Satisfy Provisions.

Where a Performance Requirement is satisfied by a Performance Solution in combination with a Deemed-to-Satisfy Solution, in order to comply with (1), the following method must be used to determine the Performance Requirement or Performance Requirements relevant to the Performance Solution:



- (a) Identify the relevant Deemed-to-Satisfy Provisions of each Section or Part that are to be the subject of the Performance Solution.
- (b) Identify the Performance Requirements from the same Sections or Parts that are relevant to the identified Deemed-to-Satisfy Provisions.
- (c) Identify Performance Requirements from other Sections or Parts that are relevant to any aspects of the Performance Solution proposed or that are affected by the application of the Deemed-to-Satisfy Provisions that are subject of the Performance Solution.

### 1.3.2 International Fire Engineering Guidelines (IFEG)

The IFEG [3] document has been developed for use in fire safety design and assessment of buildings and reflects world's best practice. The document is intended to provide guidance for fire engineers as they work to develop and assess strategies that provide acceptable levels of safety.

The document is particularly useful in providing guidance in the design and assessment of Performance Solution against the Performance Requirements of the BCA. The prescribed methodology set out in the IFEG has been generally adopted in this Fire Engineering Report (FSS) for the assessment of each individual deviation from the prescriptive provisions (relative to fire safety) as identified by the PCA as is the expected understanding of the NSW Legislation and building process.

The IFEG is not adopted in whole as there are professionals employed in the building process that determine the level of compliance with the building code and regulations that restrict one from working outside their expertise. Conformation of compliance with the applicable BCA is the role of the BCA consultant/Principle Certifying Authority.

### 1.3.3 Stakeholders

The Performance Solution has been developed collaboratively with the relevant stakeholders as identified in the table below:

Table 1-1: Relevant Stakeholders

Role	Name	Organisation
Developer	Grace Macdonald	ESR
Architect	Hong Lau	HLA Architects
Dangerous Goods Consultant	Renton Parker	Riskcon Engineering
BCA Consultant	Tom Johnston Dean Goldsmith	Blackett Maguire + Goldsmith
Bushfire Consultant	Mick George	Eco Logical Australia
Accredited Fire Safety Engineer / Fire Safety Consultant	Tom Newton Joshua Raines	Affinity Fire Engineering

*It should be noted that at times some parties may have a vested interest in the outcome of the Fire Engineering assessment. Such parties can include local fire brigades, insurers, Environmental Protection Authority (EPA), project control groups, end users and community representatives. Although not always a legislative requirement, the design team should give due consideration to their inclusion in the Fire Engineering process. Where not required by legislation it is the client's decision to involve such parties, especially local fire brigade, to ensure a transparent and adequate fire safety solution for all. Where we are not notified of the inclusion of such parties it is assumed the client / representative has given due consideration to the above.*

## 1.4 Sources of Information

The following sources of information have been relied upon in the preparation of this document:

- ▶ Site architectural plans produced by HA Architects as indicated in Table 1-2.
- ▶ Dangerous Goods Reports prepared by Riskcon Engineering;
  - Dangerous Goods Design Report Ref: RCE-21008\_Jalco\_DGDesign\_Final\_8Jul21\_Rev(2)
  - Preliminary Hazard Analysis Ref: RCE-21008\_Jalco\_PHA\_Final\_8Jul21\_Rev(1)
- ▶ Bushfire Protection Assessment dated 16 June 2020 (Ref: 20WOL-15510, version 2)
- ▶ BCA Compliance Report prepared by Blackett Maguire + Goldsmith dated 16/08/2021 (Ref: 210011, revision 2)

Table 1-2: Referenced Architectural Drawings

Drawing no.	Description	Issue	Date
200226 - DA - MS-A010	Estate Master Plan	P5	12/03/2021
200226 - DA - 201-A100	Lot 201 Site & Facility Plan	P22	30/07/2021

## 1.5 Limitations and Assumptions

In this instance, this Fire Safety Strategy has been developed based on applicable limitations and assumptions for the development which are listed as follows:

- ▶ This report is specifically limited to the project described in Section 2.
- ▶ This report is based on the information provided by the team as listed in Section 1.4.
- ▶ Building and occupant characteristics are as per Section 2 and 3 of this document. Variations to these assumptions may affect the Fire Engineering Strategy and therefore they should be reviewed by Affinity Fire Engineering should they differ.
- ▶ As per any building design, DtS or otherwise, the report is limited to the fire hazards and fuel loads as prescribed in Section 5. In line with the methodology and overarching strategy with the BCA, this report does not provide guidance in respect of multiple fire ignitions or sabotage of fire safety systems.
- ▶ This does not provide guidance on the storage of Dangerous Goods, flammable liquids, explosive materials or high temperature production equipment. Where present expert advice from an accredited Dangerous Goods Risk Consultant must be sought.
- ▶ The development complies with the DtS provisions of the NCC [1] with all aspects relating to fire and life safety unless otherwise specifically stated in this report. Where not specifically mentioned, the design is expected to meet the NCC DtS requirements of all relevant codes and legislation at the time of construction and / or at the time of issue of this report.

- ▶ The assessment is limited to the objectives of the NCC and does not consider property damage such as building and contents damage caused by fire, potential increased insurance liability and loss of business continuity.
- ▶ Malicious acts or arson with respect to fire ignition and safety systems are limited in nature and are outside the objectives of the NCC. Such acts can potentially overwhelm fire safety systems and therefore further strategies such as security, housekeeping and management procedures may better mitigate such risks.
- ▶ This report is prepared in good faith and with due care for information purposes only and should not be relied upon as providing any warranty or guarantee that ignition or a fire will not occur.
- ▶ This Fire Safety Strategy (FSS) is only applicable to the completed building. This report is not suitable, unless approved otherwise, to the building in a staged handover.
- ▶ Where parties nominated in Section 1.3.3 have not been consulted or legislatively are not required to be, this report does not take into account, nor warrant, that fire safety requirements specific to their needs have been complied with.

DRAFT

## 2 BUILDING CHARACTERISTICS

### 2.1 Overview

Building characteristics are assessed as part of the Fire Safety Strategy due the following:

1. The location can affect the time for fire brigade intervention and potential external fire exposure issues.
2. The structure will impact on the ability to resist a developing fire and support condition to allow occupants to escape the building and the fire brigade to undertake fire-fighting to the degree necessary.
3. The floor area determines the potential fire size and area required to be evacuated in the event of a fire.
4. BCA details such as Type of Construction, classification and height will dictate passive and active fire safety systems.

### 2.2 Site Location

The development site is located within the newly formed Horsley Logistics Park in Horsley Park. This site is Lot 201 of DP 1244593 with a future street address of 8 Johnston Crescent, Horsley Park.

The site is situated in the south-western corner of the estate and afforded street access from the north via Johnston Crescent. The site is otherwise bound by rural properties along the southern and western boundaries with the eastern and north-western edges of the allotment neighbouring adjacent industrial allotments. Figure 2-1 illustrates the site within the local context.




Figure 2-1: Allotment Location relative to Existing Local Setting (SixMaps 2021)

In regard to Fire and Rescue operations, the site influences the likely fire brigade intervention times and given the close proximity to nearby FRNSW fire stations, the local fire authority is expected to facilitate relatively convenient and expedient fire brigade response. The site is located in a rural suburb of an outer city however is expected to be provided with services and facilities expected in a developed setting. The likely two nearest fire brigade stations provided with permanent staff are Bonnyrigg Heights and

Huntingwood fire stations approximately 14km and 9km from site respectively when considering actual driving conditions.

The site generally includes a Class 6 retail café and a Class 7b storage and dispatch facility with the Jalco tenancy incorporating Class 8 manufacturing classification. The layout of the Horsley Logistics Park is shown in Figure 2-2 with Lot 201 highlighted as being in the south-western corner of the estate.




Figure 2-2: Horsley Park Industrial Estate – Lot 201 Highlighted

## 2.3 Building Description

The building within which the Jaco tenancy fitout shall be located comprises of three tenancies, denoted as Warehouse 1, Warehouse 2 and Warehouse 3. The Jalco Australia fitout shall be positioned within Warehouse 1.

The southern side of the allotment will be occupied by the warehouse facility with external carparking and hardstand for dispatch vehicles and emergency vehicular perimeter access. The building is a single structure considered a large-isolated building for compliances purposes, yet divided into three (3) separate tenancies. Each tenancy is provided with dedicated dispatch dock, main administration offices and smaller dock offices within the building structure. The three tenancies have an approximate combined floor area of 38,120m<sup>2</sup>.

An emergency vehicular access road shall be provided around the large warehouse building, with the fire sprinkler services infrastructure situated in the south-western corner of the site adjacent Warehouse Tenancy 3. The site FDCIE shall be located within a dedicated room in the main entry of Warehouse Tenancy 1 which will also form the Fire Control Centre for the building. The layout of the site is illustrated in Figure 2-3 to indicate the denoted title of each tenancy which is used throughout this report.






Figure 2-3: Allotment Layout and Fire Services Infrastructure

## 2.4 Jalco Australia Fitout

The Jalco Australia fitout shall incorporate a manufacturing section where raw materials will enter from the eastern side of the facility, through mixing and manufacturing plant located centrally within the tenancy and the final bottled goods palletised for temporary storage in high bay racking in the western side of the tenancy prior to final dispatch for retail distribution from the northern loading docks.

The raw materials used for the manufacture of the liquid detergent products are stored in large tanks ranging from 30kL to 70kL along the eastern side of the warehouse. The storage tanks are connected to the blending tanks within the tenancy where the products are mixed prior to being placed with retail sized containers. The Dangerous Goods report prepared by Riskcon Engineering has determined that, "most of the raw substances utilised in the business operations are DGs and will be separately banded based upon DG Class and compatibility. Adequate separation distances between incompatible substances will be ensured."

The Dangerous Goods report has also stated that while several of the raw ingredients are flammable and/or combustible, as they are processed the materials are diluted such that upon completion of mixing and prior to processing through the package filling machinery, the contents will no longer be considered DGs due to the high-water content.

The central tenancy area contains the bottling plant equipment to the south and empty bottle block storage to the north. As noted above, once the stock has been filled the retail ready produce will be stored in the high bay storage racking that occupies the western portion of the tenancy.



All new materials used in the construction will conform with the testing methodology outlined in the DTS provisions so to mitigate the spread of fire and smoke in turn minimising the fire related risks to occupants and firefighters.

It is highlighted that the service area for the mixing tanks incorporates a mezzanine level that has been constructed to have a clear height below the mezzanine floor less than 6m. This has been confirmed by Blackett Maguire + Goldsmith to maintain the existing building's rise in storeys of two (2) and hence the provision for type C Construction.

## 2.6 Building Characteristic Assessment

The following table summarises the characteristics of the subject building, relevant to fire and life safety.

Table 2-1: Building Characteristics Assessment

CHARACTERISTIC	DESCRIPTION – BUILDING	DESCRIPTION – TENANCY 1
BCA Classification	Class 5 – Offices Class 7b – Warehouse	Class 5 – Offices Class 7b – Warehouse Class 8 - Manufacturing
Rise in Storeys	Two (2)	Two (2)
Type of Construction	Type C Construction	Type C Construction
Total Floor Area	Approx. 77,250m <sup>2</sup>	Approx. 20,270m <sup>2</sup>



## 3 OCCUPANT CHARACTERISTICS

### 3.1 Overview

The occupant characteristics are assessed as part of the Fire Engineering Review due to the following:

1. Population numbers can dictate the time required to evacuate the building and the required life safety systems to be provided due to evacuation times.
2. Physical and mental attributes affects the occupants capacity to respond to various fire cues and react accordingly.
3. Familiarity of occupants can affect the time taken to evacuate the building and subsequent active/passive requirements.

### 3.2 Dominant Occupant Characteristics Assessment

Characteristic	Description
Population numbers	<p>The following specific number have been provided by Jalco Australia (as documented in the BCA Compliance Report);</p> <ul style="list-style-type: none"><li>▶ Manufacturing &amp; Storage Areas: 50 persons</li><li>▶ Office Areas: 25 persons</li></ul> <p>Generally, the occupant numbers in the building are expected to less than the occupant densities (m<sup>2</sup>/person) listed in the NCC Table D1.13 for the various areas and the building layout. However for conservatism and allow flexibility in future tenant uses, all fire engineering shall conservatively adopt population numbers per the following densities from NCC Table D1.13:</p> <ul style="list-style-type: none"><li>▶ 1 person per 30m<sup>2</sup> in the storage spaces</li><li>▶ 1 person per 10m<sup>2</sup> in the office areas</li><li>▶ 1 person per 3m<sup>2</sup> in the retail areas</li></ul>
Physical and mental attributes	<p><b>Staff</b></p> <p>Staff in the building are expected to be awake and alert at all times. Staff are expected to have a level of understanding where they can recognise an emergency situation and have the ability to take and implement decisions independently. In addition, staff are expected to respond at all times, and to be unaffected by physical or sensory disabilities. Staff are not expected to be mentally impaired by drugs, alcohol, fatigue or other adverse conditions to degrees greater than in other business places.</p>

Characteristic	Description
	<p><b>Visitors</b></p> <p>This occupant group is expected to be awake and alert. Visitors may also exhibit physical and mental disabilities to the degree and frequency of the general public. It should be noted that some visitors may consist of young children as well as elderly occupants and these occupant groups are expected to be accompanied by an adult.</p> <p><b>Firefighters</b></p> <p>This occupant group will be equipped with breathing apparatus and specialist equipment to prevent them from being adversely affected by fire hazards. They are expected to be trained in emergency response and be capable of undertaking fire suppression and coordination of evacuation of the building.</p> <p><b>Maintenance personnel</b></p> <p>This occupant group is expected to be awake and alert at all times. Maintenance personnel are expected to be able-bodied individuals who are capable of making independent decisions and evacuate themselves.</p>
	<p><b>Staff</b></p> <p>Staff are expected to have a complete knowledge of the building layout and be able to coordinate evacuation of other occupant groups in an emergency.</p> <p><b>Visitors</b></p> <p>Visitors may not have complete knowledge of evacuation routes in the subject building and are likely to choose to exit via the route they entered the building if not directed/guided by staff to the nearest exit.</p> <p><b>Firefighters</b></p> <p>This occupant group is not expected to have any familiarity of the building layout, however are assumed to obtain the required information from the site block plans and tactical fire plans available prior to entering the building. Notwithstanding this, they will be equipped with breathing apparatus and specialist equipment to prevent them from being adversely affected by fire hazards.</p> <p><b>Maintenance personnel</b></p> <p>This occupant group is expected to have a reasonable familiarity with the building as they would have to undergo site specific induction prior to commencement of work on site.</p>
	<p><b>Familiarity with the building</b></p>
Pre-movement time	Pre-movement times can vary and is highly dependent on a combination of a variety of factors [4] such as:

Characteristic	Description
	<ul style="list-style-type: none"><li>▶ Familiarity with building</li><li>▶ Commitment to activity being undertaken at the time of fire ignition</li><li>▶ Mental capabilities (ability to assess risks and make appropriate decisions, alertness)</li><li>▶ Physical capabilities</li><li>▶ Group dynamics</li><li>▶ Occupant relationships / social affiliations</li><li>▶ Frequency of false alarms</li></ul> <p>Documents such as PD7974-6:2004 [7] and CIBSE Guide E [10] provide guidance on estimating pre-movement times for various occupancies.</p>
Travel speed	<p>Travel speeds for individuals can vary depending on factors such as:</p> <ul style="list-style-type: none"><li>▶ Age and sex,</li><li>▶ Physical capabilities (ambulant, semi-ambulant, bed-ridden)</li><li>▶ Occupant density / crowding</li><li>▶ Perceived danger</li></ul> <p>Based on a literature review of work carried out by Boyce et al. [13], Nelson and Mowrer [14], Pauls [15], Milinskii, Pelecheno [16], Pretechskii [17] and Shi et al. [18], the following travel speeds are adopted for an average horizontal travel speed:</p> <ul style="list-style-type: none"><li>▶ 1.2m/s is assumed for an able-bodied adult where congestion is unlikely [10] such as in the carpark areas; and</li><li>▶ 1.0m/s is assumed for an able-bodied adult where congestion is likely [10] such as in the warehouse areas; and</li><li>▶ 0.8m/s for semi-ambulant occupants requiring assistance to evacuate, walking aid or wheelchair users [14] such as in the administration and office areas.</li></ul>

## 4 HAZARDS AND PROTECTIVE MEASURES

---

### 4.1 Overview

The fire hazard analysis forms the basis for the review of non-compliances within the buildings. In assessing expected and statistically validated hazards, preventative and protective measures are developed commensurate with those expected risks. The following section reviews applicable hazards and recommends possible measures to address those risks. Furthermore, hazards identified can form a justified basis for selected scenarios in fire engineering assessments.

### 4.2 Fire Hazards

#### 4.2.1 Building Layout And Egress

Exits are provided around the building's perimeter to allow for multiple alternative egress opportunities. Due to the open nature of the tenancy, there are limited dead end travel routes to exits, however due to the building's expansive floorplate, extended travel distances to the nearest exit and between alternative exits are present.

#### 4.2.2 General Activities

The Jalco Australia fitout shall incorporate a manufacturing section where raw materials will be fed through from the eastern side of the facility, through mixing and manufacturing plant located centrally within the tenancy and the final bottled goods palletised for temporary storage in high bay racking prior to final dispatch for retail distribution.

The business operations will therefore incorporate regular hot form plant equipment, a potentially noisy environment and contain a number of flammable and toxic materials.

### 4.3 Dangerous Goods

Where Dangerous Goods are present, they shall be stored in accordance with the Regulatory requirements. Any storage of Dangerous Goods will require review and assessment by a suitably qualified Risk Consultant to determine the associated hazards and required preventive measures to meet BCA Clause E1.10 and E2.3.

In this instance Dangerous Goods have been listed as being utilised within the facility as part of the business operations. A professional assessment of these items and their perceived risks has been undertaken by Riskcon Engineering whereby the following documents have detailed various design measures and requirements to combat the increased risks associated with these materials.

- ▶ Dangerous Goods Design Report Ref: RCE-21008\_Jalco\_DGDesign\_Final\_8Jul21\_Rev(2)
- ▶ Preliminary Hazard Analysis Ref: RCE-21008\_Jalco\_PHA\_Final\_8Jul21\_Rev(1)

The Preliminary Hazard Analysis and Dangerous Goods assessment has detailed the following materials and provided the recommendations detailed in the excerpt below.

### 3.3 Quantities of Dangerous Goods Stored and Handled

A combination of different classes and packing groups of DGs are proposed to be stored at the site. A breakdown of these DGs is provided in **Table 3-1**. A full breakdown of the product list has been provided in **Appendix A**.

**Table 3-1: Quantities of DGs Stored and Handled**

Class	PG	Description	Quantity (L)	Storage
2.1	n/a	Flammable gases – LPG	3,920	Bulk Tank
3	II	Flammable Liquids	10,000	Flammable dispensary
	III		60,000	
4.1	II	Flammable Solid	1,000	
	III		1,000	
5.1	II	Oxidising Agents	44,000	Liquid Storage Shed
	II		1,000	DAF
6.1	II	Toxic Substances	5,000	Liquid Storage Shed
8	II	Corrosive Substances – Acids and Bases	60,000	Tank Farm
	III		100,000	
8	II	Corrosive Substances	25,000	Liquid Storage Shed
	III		30,000	
8	II	Corrosive Substance	1,000	DAF
9	III	Environmentally Hazardous Substances	150,000	Liquid Storage Shed

6

Jalco Australia Pty Limited  
Document No. RCE-21008\_Jalco\_PHA\_Final\_8Jul21\_Rev(1)  
Date 8/07/2021

**Riskcon**  
engineering

Class	PG	Description	Quantity (L)	Storage
9	III	Miscellaneous DG	30,000	Tank Farm
C1	n/a	Combustible Liquid	50,000	Flammable dispensary
C2	n/a		30,000	Flammable dispensary

### 7.2 Recommendations

Notwithstanding the conclusions following the analysis of the facility, the following recommendations have been made:

- The warehouse and/or site boundaries shall be capable of containing 702 m3 which may be contained within the warehouse footprint, site stormwater pipework and any recessed docks or other containment areas that may be present as part of the site design.
- The civil engineers designing the site containment shall demonstrate the design is capable of containing at least 702 m3.
- A storm water isolation point (i.e. penstock isolation valve) shall be incorporated into the design. The penstock shall automatically isolate the storm water system upon detection of a fire (smoke or sprinkler activation) to prevent potentially contaminated liquids from entering the water course.

Figure 4-1: Extract from Riskcon Preliminary Hazard Analysis (Ref: RCE-21008\_Jalco\_PHA\_Final\_8Jul21\_Rev(1))

## 6.2 Recommendations

The following recommendations have been made based on the assessment within this report:

### DG Storage Requirements:

Each DG storage area has different requirements based on the particular substances which are being stored. Consistent to majority of the stores is the need for bunding, ventilation and separation from protected places. Detailed summaries of the items to be included in the design of each DG store are provided in the following sections:

- Liquid Storage Shed: Table 4-2: Liquid Storage Shed Storage Requirements, in accordance with AS/NZS 3833:2007
- Flammable Liquids Dispensary: Table 4-4: Flammable Liquids Dispensary Storage Requirements, in accordance with AS 1940:2017
- Bulk Tanks (Acids): Table 4-6: Bulk Acid Storage Requirements, in accordance with AS/NZS 3780:2008
- Bulk Tanks (Bases): Table 4-8: Bulk Base Tanks Design Requirements, in accordance with AS 3780:2008.
- DAF: Table 4-10: DAF Facility Design Requirements, in accordance with AS 3780:2008
- LPG Tank: Table 4-12: LP Gas Storage Requirements, in accordance with AS/NZS 1596:2014

### DG Documents:

Ensure the following documentation is supplied on site in accordance with the Work Health and Safety Regulation 2017 (Ref. [1]):

- A Dangerous Goods Register, indicating the type of chemical, any notations that may be required from the risk assessment and the Safety Data Sheet for the chemical.

Figure 4-2: Extract from Riskcon Dangerous Goods Report (Ref: RCE-21008\_Jalco\_DGDesign\_Final\_8Jul21\_Rev(2))

All the above measures, and those detailed elsewhere within the Dangerous Goods reports should be implemented into the project works.

## 4.4 Insulated Sandwich Panels

Should the tenancy fitout incorporate a temperature controlled space, or where future tenancy fit outs will contain temperature controlled areas with freezers and cool rooms and the like, these enclosures shall be constructed using Insulated Sandwich Panels (ISPs) that meet the following requirements to ensure a suitable degree of fire protection and life safety is incorporated into the design;

- ▶ All sandwich panels must be installed in accordance with the "Insulated Panel Council Australasia (IPCA) Code of Practice (CoP) - Version 4.3".
- ▶ The panels must be installed by an accredited installer as recognised by the Code of Practice prepared by IPCA (refer website: <http://www.insulatedpanelcouncil.org/code-compliant-companies>).
- ▶ Certification must be provided from the accredited installer prior to final occupation certificate being issued for the building.
- ▶ All future works, modifications or repairs must be completed using ISP with the same core and material type (i.e. the panel must not be substituted with a product having an EPS or PUR core).
- ▶ Signage and block plans will be required around the site adjacent to each sprinkler and hydrant block plan to alert fire fighters to the;
  - Location of all sandwich panels installed.
  - Type of sandwich panels installed (commercial brand and core material).

## 4.5 Rooftop Solar Panels

Solar photovoltaic systems contribute to an increased probability of a fire event, primarily due to electrical risks [6]. Additionally, should the solar panels be subjected to a fire event, attending fire brigade can be exposed to hazardous toxins from the combustion of the panel materials.

Storage battery systems pose a significant risk to attending brigade with coming in to contact with the photovoltaic system. Drenching with hoses may disconnect or expose wiring to water in which create live current exposure to personnel or possibly additional fires through sparks or short circuits.

Where the design incorporates provisions for rooftop solar panels to offset the building's energy requirements, the following design measures shall be included to mitigate the risk to the attending fire fighters in the event of a fire as per FRNSW requirements.

- ▶ A minimum of an A3 sized block plan shall be provided at all Fire Indicating Panels to alert the attending fire fighters of the presence of all key components inclusive, but not limited to the location of the solar panels, inverters, operating voltage and current, location of storage equipment and respective battery type.
- ▶ The location of the all associated isolation switches, AC and DC isolators for the shut-off of generated electricity shall be displayed at all Fire Indicating Panels with brief instructions of the safe process to subdue the hazard.

## 4.6 Review of Relevant Fire Statistics

The following discussion is based on the fire statistics attached in APPENDIX A.

### 4.6.1 Warehouse

From the National Fire Protection Association (NFPA) report on 'Structure Fires in U.S. Warehouses' [29] statistics specific to warehouses can be analysed.

A total of 1,270 structure fires were reported in warehouses between 2007 and 2011. The fires recorded resulted in 4 occupant fatalities, 23 occupant injuries and \$188 million in direct property damage per year. Overall, 19% of fires were intentionally set, however no civilian injuries were reported from these fires. Shop tools and industrial equipment caused 8% of fires; however these fires resulted in 27% of the civilian injuries recorded annually. The leading area of fire origin in warehouses comes from unclassified storage areas, resulting in 13% of fires and 18% civilian injuries.

Figure 4-3 illustrates the leading cause of structure fires in warehouses, while Figure 4-4 indicates the leading areas of origin.






Figure 4-3: Leading Causes of Structure Fires in Warehouses




Figure 4-4: Structure Fires In Warehouses By Area Of Origin

The most common ignition sources in order of likelihood in warehouse structure fires are:

- ▶ Intentional (18%)
- ▶ Electrical distribution or lighting equipment (18%)
- ▶ Heating equipment (8%)
- ▶ Exposure fire (7%)
- ▶ Smoking materials (5%)

The most common fire origins in order of likelihood in warehouse structure fires are:

- ▶ Unclassified storage area (11%)
- ▶ Shipping receiving or loading (10%)
- ▶ Storage room, area, tank or bin (7%)
- ▶ Vacant structural area (5%)
- ▶ Unclassified outside area (4%)
- ▶ Storage of supplies, tools or dead storage (4%)



- ▶ Exterior roof surface (4%)
- ▶ Trash, rubbish chute or container (4%)

#### 4.6.2 Offices

NFPA statistics published for the years 2007-2011 estimates an average of 3,340 structure fires in office properties per year. Fires in office properties accounted for less than one in every 100 (0.7%) reported structure fires from 2007-2011. These fires caused annual averages of 4 civilian deaths and 44 civilian injuries. One in every four fires was caused by cooking. Electrical distribution and lighting equipment was the second leading major cause. The percentage of fires, civilian injuries and deaths that occurred in 2007-2011 at different times of the day are presented in the figure below.




Figure 4-5: Percentage Of Fires, Civilian Injuries And Deaths At Different Times Of The Day (Offices)

The following graph that shows the ratio of injuries and deaths to total number of fires has been developed from the data presented in the previous figure. It can be noted that the number of fires during the day is almost four times as many as those during the night. The number of fires peak at midday and are the lowest in the night. This is likely due to the fact that office tenancies are generally unoccupied during the night.




Figure 4-6: Number Of Fires, Ratio Of Injuries/Fires And Deaths/Fires For Different Times Of The Day (Offices)

The most common ignition sources in order of likelihood in office structure fires are:

- ▶ Cooking equipment (29%)
- ▶ Electrical distribution and lighting equipment (12%)
- ▶ Heating equipment (11%)
- ▶ Intentional (10%)
- ▶ Smoking materials (9%)

The most common fire origins in order of likelihood in office structure fires are:

- ▶ Kitchen or cooking area (22%)
- ▶ Unclassified outside area (4%)
- ▶ Lavatory, bathroom, locker room (4%)
- ▶ Lobby or entrance way (3%)
- ▶ Attic or ceiling/roof assembly or concealed space (2%)
- ▶ Duct for HVCA, cable, exhaust, heating or AC (2%)
- ▶ Machinery room or elevator machinery (2%)
- ▶ Unclassified storage area (2%)

## 5 BCA DTS NON-COMPLIANCE REVIEW

### 5.1 Overview

In this instance the BCA DTS non-compliances have been formulated based on a regulatory review undertaken by the project building surveyor and / or design team and through Affinity Fire Engineering experience of similar buildings of the size and nature as the subject development. Where not listed herein the building is required to achieve compliance with relevant DTS provisions and relevant codes, reports and Standards.

The following table lists the proposed departures from the DTS provisions of the BCA for the development and the analysis methodology proposed for the Fire Engineering assessment, which is to be generally in accordance with the IFEG [3].

### 5.2 BCA DTS Non-Compliance Assessment and Acceptance Criteria

Table 5-1: Summary of Performance Solutions

VARIATIONS, ASSOCIATED METHODOLOGY AND ACCEPTANCE CRITERIA
<b>Egress Provisions &amp; Rationalised Automatic Smoke Exhaust System</b>
<b>Relevant Regulatory Requirement:</b>
BCA Clause D1.4 states that in a Class 5 and 7 building the travel distance to the point of choice must not exceed 20m and to the nearest exit must not exceed 40m where more than one exit is available.
BCA Clause D1.5 states that the travel distance between alternative exits must not exceed 60m.
BCA Clause E2.2 (Table 2.2a) requires large isolated buildings which have floor area or volume greater than 18,000m <sup>2</sup> or 108,000m <sup>3</sup> respectively to be equipped with an automatic smoke exhaust system in compliance with the requirements of BCA Specification E2.2b.
<b>Performance Requirement</b>
The relevant Performance Requirements are DP4 & EP2.2
<b>Non-compliance with DTS provisions:</b>
Travel distances have been identified as being non-compliant within the tenancy fitout as detailed below;
▶ Warehouse Tenancy 1:
<ul style="list-style-type: none"><li>Up to 95m to an exit in lieu of 40m.</li><li>Up to 185m between alternative exits in lieu of 60m.</li></ul>

## VARIATIONS, ASSOCIATED METHODOLOGY AND ACCEPTANCE CRITERIA

Furthermore, the automatic smoke exhaust system serving the large-isolated warehouse building shall not meet the following DTS design requirements:

- ▶ The smoke exhaust capacity in Tenancy 1 shall be designed to cater for the fire risks and have a bespoke extraction rate to be determined through fire egress and CFD modelling.
- ▶ The smoke exhaust system shall automatically initiate on fire trip.
- ▶ No automatic smoke exhaust shall be provided to the ancillary areas such as the offices, workshops, liquid storage shed, dock offices or amenities.

### Relevant IFEG Sub-Systems:

ABCDEF

### Approaches and Method of Analysis:

The assessment methodology shall be undertaken in accordance with BCA Clauses A2.2(1)(a) and A2.2(2)(b)(ii) in an absolute and quantitative evaluation of occupant evacuation. The analysis shall compare the time at which tenable conditions are deemed to be exceeded against the time required for occupant evacuation and fire brigade intervention to demonstrate that occupants can safely evacuate and fire fighters can enter for fire intervention activities.

## Fire Hydrant System Design

### Relevant Regulatory Requirement:

BCA Clause E1.3 requires that a fire hydrant system be provided and installed in accordance with AS2419.1:2005 which in turn requires that:

- ▶ All portions of the building are within reach of a 10m hose stream issuing from a 60m length of hose for external hydrants and 30m length of hose from internal hydrants.
- ▶ External hydrants located at the wall of the building must be provided with a radiant heat shield (90/90/90 FRL) a minimum 2m each side of the hydrant and 3m above the base of the hydrant.

### Performance Requirement

The relevant Performance Requirement is EP1.3

### Non-compliance with DTS provisions:

The following non-conformances have been identified and intended to be addressed through a Performance Based Solution:

- ▶ The required 90/90/90 FRL protecting wall behind each external hydrant is to be omitted through the Performance Solution with the design relying on the sprinkler system installed throughout the building.
- ▶ Hydrants located beneath dispatch awnings shall be classified as external hydrants for the purposes for system coverage and thus allowance for the use of two hose lengths.

### Relevant IFEG Sub-Systems:

## VARIATIONS, ASSOCIATED METHODOLOGY AND ACCEPTANCE CRITERIA

ABCDEF

### **Approaches and Method of Analysis:**

The assessment will adhere to BCA Clause A2.2(1)(a) and A2.2(2)(b)(ii) and will be qualitative and absolute, with minor quantitative elements. The Performance Solution for external hydrant design relies on the area's ability to maintain tenable conditions for fire fighters to connect to the hydrant point. That is; the awnings will allow free-venting of smoke, the external wall of the building will reduce exposure to thermal hazards and the sprinkler system will minimise fire sizes both internally and beneath the awning. Furthermore, should a fire be located under the awning itself at the non-compliant hydrant, adjacent external hydrants are available to enable suppression of the fire.

### **50m Fire Hose Reels**

#### **Relevant Regulatory Requirement:**

BCA Clause E1.4 requires that fire hose reels are installed in accordance with AS2441:2005 within a building having a fire compartment greater than 500m<sup>2</sup>. This requires that all points on the floor are to be within reach of a 4m hose stream issuing from a nozzle at the end of the hose, with the hose length not exceeding 36m.

#### **Performance Requirement**

The relevant Performance Requirement is EP1.1

#### **Non-compliance with DTS provisions:**

Due to the large floor areas of the tenancy hose reels with a length of 50m in lieu of 36m are proposed to be used to achieve coverage within the ground floor area of the warehouse.

#### **Relevant IFEG Sub-Systems:**

ABCDEF

### **Approaches and Method of Analysis:**

The assessment methodology will adhere to BCA Clauses A2.2(1)(a) and A2.2(2)(d). The analysis will be comparative and qualitative in demonstrating that the provisions of 50m hose reels in the tenancy will not adversely affect occupant safety.

### **Access Stairs to the Tank Mezzanine**

#### **Relevant Regulatory Requirement:**

BCA Clause D2.13 requires that stair treads and risers must comply with BCA Table D2.13; with a concession within BCA Clause D2.18 allowing the use of AS1657 compliant pathways in plant areas only.

#### **Performance Requirement**

## VARIATIONS, ASSOCIATED METHODOLOGY AND ACCEPTANCE CRITERIA

The relevant Performance Requirement is DP2 and DP6.

### **Non-compliance with DTS provisions:**

Stairs providing access up to the tank service mezzanine and around plant machinery shall be designed in accordance with AS 1657:2018 with the elevated walkways varying in width but having a minimum width of 1,000mm.

As such while the egress width shall be maintained compliant the tread and riser dimensions will not meet the BCA DtS requirements.

### **Relevant IFEG Sub-Systems:**

ABCDEF

### **Approaches and Method of Analysis:**

The assessment shall adhere to BCA Clauses A2.2(1)(b) and A2.2(2)(d) in a comparative and qualitative analysis of which shall demonstrate that occupant evacuation is not significantly disadvantaged by the subject egress paths. The Performance Solution documented shall be compared to other areas of the subject building which is permitted to use the DTS compliant designs.

## 6 PROPOSED FIRE SAFETY STRATEGY

---

The fire safety strategy outlined below has been proposed to satisfy the fire and life safety objectives specified for this project by the relevant stakeholders. In addition, the fire safety strategy is required to adequately address the specific fire and life safety hazards identified for the proposed development, and as such have been generally derived from the preventative and protective measures outlined within the BCA, and fire engineering literature and research.

The specified fire safety strategy will undergo analysis as part of a Fire Engineering Report to ascertain whether the relevant Performance Requirements of the BCA are satisfied. The information herein is therefore pending completion of the fire engineering analysis and as such is possible to change and or modification through the detailed design phase of the project.

### 6.1 Passive Fire Construction

#### 6.1.1 Fire Resisting Construction

All modification and any new works to the building structure including floors, walls, columns and shafts shall be constructed in accordance with the requirements of BCA Clause C1.1, Specification C1.1 for Type C Construction.

#### 6.1.2 Separation of Equipment

Rooms containing equipment listed below must be fire separated from the remainder of the building by construction in accordance with Specification C1.1 or 120/120/120 FRL construction, whichever is greater, with any door opening into that room consisting of a --/120/30 FRL self-closing fire door.

- ▶ Lift motors and lift control panels (unless the lift installation does not have a machine-room); or
- ▶ Emergency generators used to sustain emergency equipment operating in emergency mode; or
- ▶ Central smoke control plant (other than smoke exhaust systems designed for high temperature operation); or
- ▶ Boilers; or
- ▶ A battery system installed in the building that have a total voltage of 12 volts or more and a storage capacity of 200kWh or more.

Electricity supply systems inclusive of electricity substations located within a building and main switchboards located within the building which sustains emergency equipment operating in the emergency mode (i.e. the smoke exhaust fan switchboard) must meet the requirements of BCA Clause C2.13. This includes the requirements of being separated from any other part of the building by construction having:

- ▶ An FRL of not less than 120/120/120: and

- ▶ Any doorway in that construction protected with a self-closing fire door having an FRL of not less than --/120/30.

It is specifically highlighted that the electrical boards feeding the smoke exhaust system must provide an essential power supply and be contained within a 120min FRL enclosure per the above BCA Clause C2.13 requirements.

### 6.1.3 Finishes and Linings

Where practicable, internal finishes, internal linings and internal materials used throughout the building should be non-combustible to reduce the spread of fire and the generation of toxic smoke products.

All modification and any new works to wall, floor and ceiling, and roof and ceiling assemblies must be tested and rated for their fire hazard properties in accordance with the prescriptive requirements of BCA Clause C1.10 and Specification C1.10.

### 6.1.4 External Claddings

All modification and any new works to the external cladding forming the building must comply with the DTS provisions of the BCA as defined by BCA Specification C1.1. Aluminium composite panels (ACP) containing a polyethylene (PE) core should not be used on the façade.

- ▶ The requirements of the Bushfire Report dated 16 June 2020 (Ref: 20WOL-15510 version 2) shall be adopted to ensure the BAL protective measures are incorporated into the design.

### 6.1.5 Insulated Sandwich Panels

Where the tenancy fitout contains temperature-controlled areas with Freezers and Cool Rooms and the like, these enclosures shall be constructed using Insulated Sandwich Panels (ISP) that meet the following requirements to ensure a suitable degree of fire mitigation.

- ▶ All sandwich panels must be installed in accordance with the "Insulated Panel Council Australasia (IPCA) Code of Practice (CoP) - Version 4.3".
- ▶ The panels must be installed by an accredited installer as recognised by the Code of Practice prepared by IPCA (refer website: <http://www.insulatedpanelcouncil.org/code-compliant-companies>).
- ▶ Certification must be provided from the accredited installer prior to final occupation certificate being issued for the building.
- ▶ All future works, modifications or repairs must be completed using ISP with the same core and material type (i.e. the panel must not be substituted with a product having an EPS or PUR core).
- ▶ Signage and block plans will be required around the site adjacent to each sprinkler and hydrant block plan to alert fire fighters to the following:
  - Location of all sandwich panels installed.
  - Type of sandwich panels installed (commercial brand and core material).



### 6.1.6 Rooftop Solar Panels

Where solar panels are installed on the warehouse roof, the following measures shall be provided:

- ▶ A minimum A3 sized block plan shall be provided at the Main FDCIE and Fire Pump Room to alert attending FRNSW personnel and be inclusive of the following as a minimum:
  - Large warning text stating "WARNING: SOLAR PANELS ON WAREHOUSE ROOF" to alert attending fire fighters.
  - Signage shall be constructed of all-weather fade resistant material with red lettering not less than 25mm in height with contrasting coloured background.
  - Signage shall identify the presence and location of the solar electrical generation system.
  - Location of all associated isolation switches, AC and DC isolators for the shut-off generated electricity should be displayed at the Main FDCIE and Fire Pump Room.
  - Block plans shall clearly indicate the location and type of any inverters, storage equipment type and operating voltage and current.
- ▶ Where solar panels are designed to be automatically isolated on fire trip, signage shall be provided at the Main FDCIE and Fire Pump Room detailing this provision that can clearly be identified by attending fire brigade.

### 6.1.7 Smoke-proof Construction

As part of the Performance Solution to conditionally permit the omission of automatic smoke exhaust from the main Administration Offices of each tenancy, these areas shall all be smoke separated from the warehouse parts of the building and meet the following requirements:

- ▶ All shared walls and ceilings/roofs between the offices and warehouse parts of the building shall meet the smoke proofing construction requirements of BCA Specification C2.5 – Clause 3 which includes, but not limited to:
  - Air handling systems that link the warehouse and office parts must shut down on general fire trip within Warehouse 1, Warehouse 2 and Warehouse 3 and be provided with smoke dampers where air-handling ducts penetrate the smokeproof construction into the warehouse.
  - All doors opening from the office into the warehouse part of the building shall be smoke doors in accordance with BCA Specification C3.4.
    - These doors shall be fitted with self-closers and medium temperature smoke seals (200°C smoke for 30 minutes and tested to AS1530.7:2007 and must meet the smoke leakage rates specified in AS6905-2007).
- ▶ Note, no smoke separation is required to the remaining ancillary areas which are not afforded automatic smoke exhaust (workshop, dock offices or amenities and the like).

## 6.2 Egress Provisions

### 6.2.1 Alarm & Evacuation Strategy

Activation of any sprinkler head, smoke detector or manual call point shall initiate the building occupant warning alarm tones throughout the building of alarm origin.

Given the presence of dangerous goods, any fire alarm signal in the building should initiate throughout all areas of all tenancies immediately.

Dedicated fire wardens shall ensure that all clients, visitors, maintenance contractors and staff of Tenancy 1 are promptly evacuated if a fire is identified anywhere in that building.

### 6.2.2 Egress Provisions

With exception of the following items being addressed through a fire engineered Performance Solution, travel distances to a point of choice or single exit to be not more than 20m, the distance to the nearest of two or more alternative exits must not exceed 40m and the distance between alternative exits must be no closer than 9m and no further apart than 60m.

- ▶ The fire engineering assessment shall address travel distances that have been identified as being non-compliant in the following listed locations of the main warehouse and production areas:
  - Up to 95m to an exit in lieu of 40m.
  - Up to 185m between alternative exits in lieu of 60m.

**Design Note 1:** Additional exit and egress doors may be required and/or modification to future fit-outs to ensure the travel distance limitation defined by Fire & Rescue NSW of *"no point in a fire compartment is to be more than 100m from a hydrant external to that compartment"*. This shall be determined through the detailed design phase on the project.

**Design Note 2:** Travel distances and egress provisions from the tank farm mezzanine will be via the non-fire-isolated access stairs and these should be located as required to ensure travel distances are compliant with the prescriptive DtS provisions.

### 6.2.3 Door Hardware, Operation and Mechanisms

All doors serving as required exits shall have hardware, door swings, latch operations and signage in accordance with the prescriptive requirements of BCA Clauses D2.19, D2.20, D2.21 and D2.23.

### 6.2.4 Signage and Lighting

Exit and emergency lighting is to be provided throughout the building in accordance with the prescriptive DTS provisions of BCA Clause E4.2, E4.4, E4.5, E4.6, E4.8 and AS2293.1:2018.

- ▶ Exit signs are to be pictograph 'running man' signs as per the prescriptive requirements of AS2293.1:2018.
- ▶ All exit and directional exits signs are to be power operated illuminated signs.

## 6.3 Active Fire Protection Systems

### 6.3.1 Building Alarm and Communication System

All modification and any new works to the building occupant warning system shall be in accordance with the prescriptive requirements of Specification E1.5 and Clause 6 of Specification E2.2a of DTS provisions and AS1670.1:2018.

- ▶ The existing system shall be extended and modified as required to ensure compliant coverage of the system.
- ▶ Activation of the any automatic smoke detector, fire sprinkler head or manual call point shall initiate the Building Occupant Warning System (BOWS) throughout all areas of all tenancies in the building.

The tenancy shall be provided with a verbal command capability to facilitate emergency response and evacuation instructions during an emergency by the assigned fire wardens. This may be incorporated into the building occupant warning system at the FDCIE or via an audio communication system.

### 6.3.2 Automatic Fire Sprinkler System

All modification and any new works to the fire sprinkler system shall be in accordance with the prescriptive requirements of BCA Specification E1.5 and AS2118.1:2017 Amendment 1.

- ▶ The existing system shall be extended and modified as required to ensure compliant coverage of the system taking into account the storage arrangements, commodities and material processes.
- ▶ The recommendations of the dangerous good consultant must be adopted as detailed in the Riskcon Dangerous Goods Report and Preliminary Hazard Analysis Assessment.

### 6.3.3 Automatic Smoke Hazard Management Systems

The existing automatic smoke exhaust system shall be modified and extended to cater for the additional fire loads presented by the production equipment and Dangerous Goods in the facility. All modifications and any new works to the system shall be in accordance with the prescriptive requirements of BCA Specification E2.2a and AS1668.1:2015 with the following exceptions:

- ▶ The smoke exhaust capacity in Tenancy 1 shall be designed to cater for the fire risks and have a bespoke extraction rate to be determined through fire egress and CFD modelling. The final extraction rates and fan locations shall be determined through consultation with Fire & Rescue NSW and the Dangerous Good consultant at the Construction Certificate stage of the project.
- ▶ The smoke exhaust system shall automatically initiate on fire trip.
- ▶ No automatic smoke exhaust shall be provided to the ancillary areas such as the offices, workshops, liquid storage shed, dock offices or amenities.

As part of the fire engineered Performance Solution for Smoke Hazard Management, the following minimum measures must be provided;

- The system must be designed in accordance with BCA Specification E2.2b and AS1668.1:2015 unless noted otherwise.
- Fan initiation switches shall be located at the FDCIE, or an adjacent panel located dedicated Fire Control Centre building.

- Signs alerting the Fire Brigade to the operation of the smoke exhaust system must be provided.
- Fire rated fans and fire rated cabling shall be designed to operate at 200°C for a period no less than 60-minutes.
- Automatic smoke exhaust systems shall be connected to the site's essential power source.
- Multiple fans be are to be provided to each tenancy and be evenly distributed to otherwise comply with the requirements of Specification E2.2b Clause 5 of the BCA.
- Even distributed make-up air shall be provided at low level through permanent perforation to the dispatch roller shutter doors and/or louvres in the façade. Note that manual opening of the dispatch rollers doors is not considered an acceptable method of achieving the required makeup air supply.
- The recommendations of the dangerous good consultant must be adopted as detailed in the Riskcon Dangerous Goods Report and Preliminary Hazard Analysis Assessment.

## **6.4 Occupant Fire Fighting Facilities**

### **6.4.1 Fire Hose Reel**

The existing fire hose reel system shall be modified and extended to cater for the additional fire loads presented by the production equipment and Dangerous Goods in the facility and the internal fitout of the tenancy.

All modification and any new works to the fire hose reels are to be in accordance with the prescriptive DTS provisions of BCA Clause E1.4 and AS2441:2005 with the following exceptions conditionally permitted:

- ▶ Fire hose reels with 50m length hoses may be utilised to achieve coverage. Where 50m long hoses are used;
  - They must be tested to meet the requirements of AS1221:1997 other than the specification of a maximum hose length of 36m.
  - Coverage to any part of the tenancy by a 50m long hose line must be achieved with no more than 2 bends.
- ▶ To ensure that the provision of 50m hose reels does not impact on life safety, on-site staff training in the use of the hose reels is to be undertaken by the nominated fire wardens.

Locations should be signposted and readily accessible to occupants. Use of facilities should be monitored for abuse, mistreatment and servicing. The fire hose reels shall be located within 4m of an exit and provide coverage to all areas of the building based on a 50m or 36m hose length with a 4m water stream.

- ▶ The recommendations of the dangerous good consultant must be adopted as detailed in the Riskcon Dangerous Goods Report and Preliminary Hazard Analysis Assessment.

## 6.4.2 Portable Fire Fighting Equipment

Portable fire extinguishers are to be provided throughout the tenancy in accordance with Table E1.6 of the BCA with the type of extinguisher selected in accordance with AS2444:2001.

▶ General office areas	Dry Powder (ABE type)	2.5Kg
▶ Computer/server rooms	CO <sub>2</sub>	3.5 Kg
▶ Plant rooms	Dry Powder (ABE)	2.5 Kg
▶ Designated exits	Dry Powder (ABE)	4.5 Kg
▶ Adjacent each fire hose reel cabinet	Dry Powder (ABE)	4.5 Kg

The recommendations of the dangerous good consultant must be adopted as detailed in the Riskcon Dangerous Goods Report and Preliminary Hazard Analysis Assessment.

## 6.5 Fire Brigade Intervention

### 6.5.1 Fire Brigade Alarm Signalling Equipment

An automatic link shall be provided directly to an approved monitoring centre on activation of any automatic smoke detection system, fire sprinkler system or manual call point installed in the tenancy.

- ▶ The ASE unit shall ensure compliance with DTS Provisions and AS1670.3:2018 and programmed to have an individual call out address to the main entry of Tenancy 1 Office should a fire originate within Warehouse Tenancy 1.
- ▶ To assist fire fighter navigation throughout the site additional site plans are to be provided at the FDCIE. These block plans must meet the block plan requirements of AS2118.1:2017, AS2419.1:2005 and AS1670.1:2018 as a minimum and include:
  - An illustration the entire allotment and surrounding roads and hardstands that are to be used for fire brigade perimeter access
  - The location of all sub-stations and electrical MSBs
  - The location of the fire services pumps, tanks and booster assemblies.
  - Dangerous Goods manifest and details of the storage locations throughout the tenancy.
- ▶ The recommendations of the dangerous good consultant must be adopted as detailed in the Riskcon Dangerous Goods Report and Preliminary Hazard Analysis Assessment.

### 6.5.2 Fire Hydrant System

The existing fire hydrant system shall be modified and extended to cater for the additional fire loads presented by the production equipment and Dangerous Goods in the facility and the internal fitout of the tenancy. All modification and any new works to the fire hydrant system shall be in accordance with the prescriptive requirements of BCA Clause E1.3 and AS2419.1:2005 Amendment 1 with the following exceptions conditionally permitted:

- ▶ The required 90/90/90 FRL protecting wall behind each external hydrant is to be omitted through the Performance Solution with the design relying on the sprinkler system installed throughout the building.

- ▶ Hydrants located beneath awnings shall be classified as external hydrants for the purposes for system coverage and thus allowance for the use of two hose lengths.

As part of the Performance Solution and typical Fire & Rescue NSW requirements, the system shall incorporate the following measures:

### System Design Measures

- ▶ The system shall incorporate a ring main and associated isolated valves as required for a large isolated building. Isolation valves shall be numbered with those corresponding numbers indicated on the hydrant block plan.
- ▶ All connection points must be fitted with Storz hose couplings which comply with Clause 7.1 and 8.5.11 of AS2419.1:2005, as well as comply with FRNSW Technical Information D15/45534 for *"FRNSW compatible Storz hose connections"*. Further information is available from FRNSW available at [www.fire.nsw.gov.au](http://www.fire.nsw.gov.au).
- ▶ Hydrants located beneath dispatch awnings shall have alternative external fall-back hydrants available to provide full coverage under the entire awning where a hydrant is located beneath.
  - A fall back hydrant shall be located more than 10m away from the awning, in open space, and provide full coverage of the dispatch awning as indicated in and (based on indicative attack hydrant locations).
- ▶ Per the request of FRNSW, as far as possible the hydrant system should consist of external hydrant points, with internal hydrants only provided to where there are shortfalls in coverage from external hydrants.
  - Where internal hydrants are required;
    - They must be designed to allow progressive movement through the building such that an internal hydrant is within 50m of an external hydrant and 25m of an internal hydrant.
    - A localised block plan must also be provided at every hydrant pictorially and numerically illustrating the location of the next available additional hydrant. These localised block plans should be of a size appropriate to their notice and location and be of all-weather fade resistant construction.

Note that the existing fire hydrant system serving the site has been designed in accordance with AS2419.1:2005 Amendment 1 to enable three (3) hydrant hoses flowing simultaneously (each at 10L/s for a total flow capacity of 30L/s) for a period not less than 4 hours. External hydrants are provided around the perimeter of the site, and these shall be extended to incorporate additional internal hydrants as required to achieve compliant coverage through the new fitout.

The design capacity of the system will need to be reviewed by the Dangerous Goods consultant to ensure that the existing system is adequate for the expected dangerous goods commodities within the facility.

### Fire Hydrant Booster Arrangement


As part of the fire hydrant system design, the following must be incorporated to the booster assembly arrangement;

- ▶ The fire hydrant booster assembly must ensure adequate staging area for pumping appliances as per FRNSW Fire Guideline requirements *"Access for fire brigade vehicles and firefighters"* available at <https://www.fire.nsw.gov.au/>.



- ▶ The hydrant block plans must be provided at the FDCIE and highlight the perimeter vehicular access provisions around the building through to the fire sprinkler infrastructure.
- ▶ The booster assembly must not be located within 10m of any high voltage electrical equipment or any gas meters and associated valves.

As detailed in FRNSW Fire Guideline requirements *"Access for fire brigade vehicles and firefighters"*, any hardstand serving a suction-connection outlet is to have a working space which extends a minimum 18m from the point of connection to allow a suction hose to be connected to the fire appliance. This is demonstrated in Figure 6-1.



**Figure 14 Hardstand area serving a suction-connection outlet**

Figure 6-1: FRNSW Access For Fire Brigade Vehicles & Firefighters Excerpt (State Govt NSW 2019)

Notwithstanding, a detailed design of the fire appliance staging area relative to the suction connection point and booster assembly must be undertaken by the fire hydrant design consultant to meet the desired requirements. Note that a minimum 6m clear width must be maintained past any appliance staging area to meet the requirements of BCA Clause C2.4.

### 6.5.3 Vehicular Perimeter Access

The existing emergency vehicular perimeter access pathway shall be maintained clear of obstructions to achieve continuous access around the site and through the tenancy dispatch hardstand. Any new works or modifications to the existing hardstand and adjacent building shall ensure that the vehicular access path is maintained no less than 6m clear width and facilitates the turning arc and sweep for both pumper and aerial appliances.

- ▶ All road surfaces must be designed and constructed in all-weather surface capable of supporting all FRNSW appliances in accordance with BCA Clause C2.4 and FRNSW Fire Guideline requirements *"Access for fire brigade vehicles and firefighters"* (available from [www.fire.nsw.gov.au](http://www.fire.nsw.gov.au)) with the following exceptions conditionally permitted:

To facilitate the perimeter access non-conformances the following measures shall be provided as part of the Performance Solution:

- ▶ Sweep paths along the perimeter access path must be confirmed by traffic engineer to facilitate the turning circle of FRNSW general fire appliance and specialist fire appliances as detailed in FRNSW Fire Safety Guideline *"Access for fire brigade vehicles and firefighters"*.

- ▶ Security gates positioned across the vehicular access pathway must have an unobstructed width no less than 6.0m and be;
  - Manually openable gates: are to be locked with a loose chain and padlock unlockable by fire brigade 003 keys; and
  - Mechanically driven gates: must be provided with a manual override that is accessible to attending fire brigade personnel with block plans indicating the manual overridable gates inclusive with pictorial step-by-step instructions at each FDCIE.
- ▶ Roadway gradients shall not hinder vehicle response and must be suitable for heavy vehicles in accordance with Australian Standards and FRNSW Fire Safety Guideline *“Access for fire brigade vehicles and firefighters”*.
- ▶ The fire appliance access road and surface are all weather and are capable of supporting the maximum appliance weights expected during fire conditions. The roadway should be designed to withstand a uniformly distributed load over the entire area as per the Fire and Rescue requirements. This would provide the necessary stability for fire-fighting appliances (pumping), and if necessary, the use of a heavier fire-fighting (aerial) appliances.

## 6.6 Building Management Procedures

The ongoing management of the building is as important in maintaining a high level of life safety as the provisions recommended during the design phase of the building.

### 6.6.1 Maintenance of Fire Safety Equipment

The fire detection systems, fire sprinkler systems, emergency warning systems, fire hydrants, hose reels, portable fire extinguishers, emergency lighting and any other fire safety equipment shall be tested and maintained in accordance with Australian Standard AS1851 or other relevant testing regulatory.

### 6.6.2 No Smoking Policy

A no-smoking policy shall be implemented and enforced through all internal areas of the building.

### 6.6.3 Fire Safety Manual

A fire safety manual shall be developed for the site to provide an overview of all fire safety procedures and systems within the building. The manual should also record false alarms, outcomes from fire drills and provide details of the ongoing maintenance and inspection procedures. The manuals should be reviewed annually and a lessons learned exercise undertaken. Any conclusions drawn from this exercise should be implemented into the fire safety procedures.

## 6.7 Dangerous Goods

Where Dangerous Goods are present, they shall be stored in accordance with the Regulatory requirements. Any storage of Dangerous Goods will require review and assessment by a suitably qualified Risk Consultant to determine the associated hazards and required preventive measures to meet BCA Clause E1.10 and E2.3.



In this instance Dangerous Goods have been listed as being utilised within the facility as part of the business operations. A professional assessment of these items and their perceived risks has been undertaken by Riskcon Engineering whereby the following documents have detailed various design measures and requirements to combat the increased risks associated with these materials.

- ▶ Dangerous Goods Design Report Ref: RCE-21008\_Jalco\_DGDesign\_Final\_8Jul21\_Rev(2)
- ▶ Preliminary Hazard Analysis Ref: RCE-21008\_Jalco\_PHA\_Final\_8Jul21\_Rev(1)

The Preliminary Hazard Analysis and Dangerous Goods assessment has detailed the following materials and provided the recommendations detailed in the excerpt below. All the following measures, and those detailed elsewhere within the Dangerous Goods reports should be implemented into the project works.

## 7.2 Recommendations

Notwithstanding the conclusions following the analysis of the facility, the following recommendations have been made:

- The warehouse and/or site boundaries shall be capable of containing 702 m<sup>3</sup> which may be contained within the warehouse footprint, site stormwater pipework and any recessed docks or other containment areas that may be present as part of the site design.
- The civil engineers designing the site containment shall demonstrate the design is capable of containing at least 702 m<sup>3</sup>.
- A storm water isolation point (i.e. penstock isolation valve) shall be incorporated into the design. The penstock shall automatically isolate the storm water system upon detection of a fire (smoke or sprinkler activation) to prevent potentially contaminated liquids from entering the water course.

Figure 6-2: Extract from Riskcon Preliminary Hazard Analysis (Ref: RCE-21008\_Jalco\_PHA\_Final\_8Jul21\_Rev(1))

## 6.2 Recommendations

The following recommendations have been made based on the assessment within this report:

### DG Storage Requirements:

Each DG storage area has different requirements based on the particular substances which are being stored. Consistent to majority of the stores is the need for bunding, ventilation and separation from protected places. Detailed summaries of the items to be included in the design of each DG store are provided in the following sections:

- Liquid Storage Shed: Table 4-2: Liquid Storage Shed Storage Requirements, in accordance with AS/NZS 3833:2007
- Flammable Liquids Dispensary: Table 4-4: Flammable Liquids Dispensary Storage Requirements, in accordance with AS 1940:2017
- Bulk Tanks (Acids): Table 4-6: Bulk Acid Storage Requirements, in accordance with AS/NZS 3780:2008
- Bulk Tanks (Bases): Table 4-8: Bulk Base Tanks Design Requirements, in accordance with AS 3780:2008.
- DAF: Table 4-10: DAF Facility Design Requirements, in accordance with AS 3780:2008
- LPG Tank: Table 4-12: LP Gas Storage Requirements, in accordance with AS/NZS 1596:2014

### DG Documents:

Ensure the following documentation is supplied on site in accordance with the Work Health and Safety Regulation 2017 (Ref. [1]):

- A Dangerous Goods Register, indicating the type of chemical, any notations that may be required from the risk assessment and the Safety Data Sheet for the chemical.

Figure 6-3: Extract from Riskcon Dangerous Goods Report (Ref: RCE-21008\_Jalco\_DGDesign\_Final\_8Jul21\_Rev(2))

### 6.7.1 Hot Works Policy

A hot works policy should be put in place and rigorously enforced to ensure that all hot works, including grinding and welding, are managed to avoid the accidental ignition of fires.

### 6.7.2 Emergency Management Plan

An Emergency Management Plan (EMP) must be developed in accordance with AS3745:2010. The EMP must;

- ▶ Developed by an emergency planning committee (EPC).
- ▶ Implement emergency control organisation (ECO) procedures for the building.
- ▶ Specifically address the types of emergencies that may arise from the industry and/or activities associated with the business operations.
- ▶ Ongoing training, education and execution of the emergency management procedures to be regularly conducted with all building occupants.
- ▶ An evacuation plan should be developed for the site in accordance with AS3745:2010 and standard fire orders should be displayed throughout the building.

The EMP shall also incorporate a specific bushfire response plan that includes;

- ▶ All emergency response requirements of the Bushfire Report dated 16 June 2020 (Ref: 20WOL-15510 version 2); and
- ▶ Instructive verbal commends for staff to evacuate via the northern exits and not via the southern exit doors that are towards the bushfire risks; and
- ▶ Regular training and/or induction of staff to ensure they are aware of the management control measures and procedures during a bushfire event.

### 6.7.3 Fire Drills and General Fire Safety Training

All fire wardens are to be trained in first-aid firefighting and emergency response. All staff shall be inducted with a fire safety brief including the actions necessary on the activation of the building emergency warning system and the location of all emergency egress paths and fire exits. In addition periodic fire drills should be undertaken and any lessons learned included in future fire safety procedures.

## 7 REFERENCES

---

1. Australian Building Codes Board, "NCC - Building Code of Australia - Volume One, 2019 - Amendment 1", Canberra ACT 2020."
2. Australian Building Codes Board, "NCC - Guide to Volume One - Amendment 1", Canberra ACT 2020.
3. Australian Building Codes Board, "International Fire Engineering Guidelines", Canberra ACT 2005.
4. Society of Fire Protection Engineers, "The SFPE Handbook of Fire Protection Engineering", 4<sup>th</sup> edition, 2008.
5. Drysdale D, "An Introduction to Fire Dynamics", 3<sup>rd</sup> edition, John Wiley & Sons, UK, 2011.
6. Davis R. (2014), "Fire Concerns With Roof-Mounted Solar Panels", SFPE Fire Protection Engineering Emerging Trends Newsletter, Issue 92, 2014.
7. PD7974-6:2004, "The application of fire safety engineering principles to fire safety design of buildings - Part 6: Human factors", BSI British Standards.
8. PD7974.7:2003, "Application of fire safety engineering principles to the design of buildings - Part 7: Probabilistic risk assessment", BSI British Standards.
9. Spearpoint, M., "Fire Engineering Design Guide", 3<sup>rd</sup> edition, New Zealand Centre for Advanced Engineering, May 2008.
10. The Chartered Institute of Building Services Engineers, "Fire Safety Engineering CIBSE Guide E", 3rd Edition, May 2010.
11. Drysdale D, "An Introduction to Fire Dynamics", 3<sup>rd</sup> edition, John Wiley & Sons, UK, 2011.
12. "Fire Brigade Intervention Model V2.2", Australasian Fire Authorities Council, October 2004.
13. Boyce, K., Shields, T., and Silcock, G., "Toward the Characterization of Building Occupancies for Fire Safety Engineering: Capabilities of Disabled People Moving Horizontally and on an Incline", Fire Technology, Vol. 35, No. 1, February 1999, pp. 51-67.
14. Nelson, H.E. "BUD" and Mowrer, F.W., "Emergency Movement", The SFPE Handbook of Fire Protection Engineering (3rd Edition), National Fire Protection Association, Quincy, MA 02269, 2002 pp. 3/367-380.
15. Pauls, J. L. "Movement of People in Building Evacuations", Human Response to Tall Buildings, Chap 21. Dowden, Hutchinson and Ross, Stroudsburg, PA, 1977.
16. Pelecheno N, Malkawi A, "Evacuation simulation models: Challenges in modelling high rise building evacuation with cellular automata approaches", Automation in Construction Journal 2008 (Vol. 17), pp.377-385.
17. Predtechenskii, V.V. and Milinskii, A.I., Planning for foot traffic in buildings (translated from Russian). Stroizdat publishers, Moscow, 1969. English translation published for National Bureau of Standards and the National Science Foundation, Washington, by Amerind Publishing Co. Pvt. Ltd, New Delhi, India, 1978.

18. Shi, L, Xie, Q, Cheng, X, Chen, L, Zhou, Y, Zhang, R, "Developing a database for emergency evacuation model", pp. 1724-1729 Building and Environment, 2009.
19. Hall, J.R. "U.S. Experience with Sprinklers", National Fire Protection Association, June 2013.
20. Turner, M. "Fire Brigade's Fight for Sprinklers in New Underground Car Park." Fire, 79 (972): 32-34, 1986.
21. Thomas, IR., "Fires in Carparks", Fire Australia February 2004, Eastside Printing, 2004.
22. BHP Steel: Structural steel Development Group, Report No MRL/Ps69/89/006. "Fire Safety in Car Parks".
23. Li, Y and Spearpoint, M. Analysis of vehicle fire statistics in New Zealand parking buildings. Fire Technology, Vol. 43, No. 2, 2007, pp.93-106.
24. BS EN 1991-1-2:2002, 'Eurocode 1: Actions on structures – Part 1-2: General actions – Actions on structures exposed to fire', British Standards, March 2009.
25. AS 1530.4, "Methods for fire tests on building materials, components and structures, Part 4: Fire resistance tests of elements of construction", Standards Australia, 2005.
26. Bushfire CRC, "Window and Glazing Exposure to Laboratory-Simulated Bushfires", Doc: 2006-205, May 2006.
27. Rakic J, "The Performance of Unit Entry Doors when Exposed to Simulated Sprinkler Controlled Fires", Lorient International, Lindfield, NSW, Australia.
28. England JP, Chow V, Yunlong Liu, (2007) Modelling Smoke Spread through Barrier Systems Retrieved from <http://www.yunlong.com.au/pdf/PEngland.pdf>
29. Campbell, R., 'Structure Fires in Warehouse Properties', NFPA Research, January 2016.

## APPENDIX A FIRE STATISTICS

### PROBABILITY OF FIRE STARTS

The probability of a fire start in a range of building uses, based on UK data, can be established using the data presented in Table 7-1 [8]; the applicable occupancy type is highlighted.

Table 7-1: Overall probability of fire starts for various occupancies, UK data

Occupancy	Probability Of Fire Starts (% Per Year)
<i>Industrial</i>	4.4
<i>Storage</i>	1.3
<i>Offices</i>	0.6
<i>Assembly entertainment</i>	12.0
<i>Assembly non-residential</i>	2.0
<i>Hospitals</i>	30.0
<i>Schools</i>	4.0
<i>Dwellings</i>	0.3

### PROBABILITY OF CIVILIAN INJURY AND FATALITY

The probability of injuries and deaths for various occupancy types based on UK data [8] is presented in the following table.

Table 7-2: Probability of occupant injury and fatality by occupancy type, UK data averages for the years 1995 and 1997-1999

Type Of Occupancy	No Of Fires	Probability Of Occupant Injury Per Fire Event (%)	Probability Of Occupant Death Per Fire Event (%)
<i>Further education</i>	535	3.18	0.00
<i>Schools</i>	1669	3.06	0.00
<i>Licensed premises</i>	3317	7.90	0.08
<i>Public recreational buildings</i>	2581	1.86	0.05
<i>Shops</i>	5671	5.01	0.06
<i>Hotels</i>	1021	11.36	0.24
<i>Hostels</i>	1338	4.48	0.04
<i>Hospitals</i>	3063	3.69	0.11
<i>Care homes</i>	1616	8.04	0.28
<i>Offices</i>	1988	11.02	0.02
<i>Factories</i>	5299	5.40	0.08

## APPENDIX B FIRE BEHAVIOUR

### FIRE GROWTH RATE

As the fire increases in size, the rate of fire growth accelerates. The growth rate of a fire can result in various hazards for occupants due to the following:

- ▶ Protective and preventative measures may not be adequate
- ▶ Occupants may have insufficient time to evacuate
- ▶ Occupants may perceive a reduced threat from slow growing fires


The rate of fire growth is generally expressed in terms of an energy release rate. The most commonly used relationship is what is commonly referred to as a quadratic t-squared fire. In such a fire, the rate of heat release is given by the expression:

$$Q = \left( \frac{t}{k} \right)^2$$


Where; t is time from ignition of the fire (seconds) and k is the growth time (seconds) for the fire to reach a heat output of 1.055 MW.

The continued growth of a fire defined by the above equation relies on both a sufficient source of fuel and air and assumes that flashover has not been reached. The rate of fire growth can be estimated from the results of a number of fire tests that have been performed on various fuel commodities.

National Fire Protection Association Standard NFPA 92B, provides information on the relevance of t-squared approximation to real fire as depicted in Figure 7-1.



(a) t-squared fire, rates of energy release



(b) Relation of t-squared fires to some fire tests

Figure 7-1: NFPA 92B design fires and heat release rates

A slow fire growth is not considered to be the most challenging in terms of fire and life safety or fire brigade intervention. The continued growth of a fire defined by the above equation relies on both a sufficient source of fuel and air and assumes that flashover has not been reached. The rate of fire growth can be estimated from data published in CIBSE Guide E [10] and BS9999:2008 are listed below:

- ▶ Assembly hall seating : Medium-Fast
- ▶ Dwelling : Medium
- ▶ Office : Medium
- ▶ Hotel bedroom : Medium
- ▶ Hotel reception : Medium
- ▶ Meeting room : Medium
- ▶ Picture Gallery : Slow
- ▶ Reception area : Slow
- ▶ Restaurant/Canteen : Medium
- ▶ Shop : Fast
- ▶ Teaching laboratories : Fast
- ▶ Warehouse : Medium/Fast/Ultra-fast
- ▶ Waiting Room : Slow

From the above list, it can be concluded that the likely fire scenarios in the building may be approximated by the standard Ultra-fast time-squared fire growth rate curve.



## APPENDIX C FIRE LOADS

The fire load within a room or compartment will influence the duration and severity of a fire and resultant hazard to occupants. The effective fire load for the building has been estimated by consideration of the typical spaces within the building.

The IFEG has published further fire load densities for broad occupancy groupings (extracted from CIB 1983) as provided in the table below. The CIB compilation emphasises that at least the 95% fractile should be selected for design purposes. The following fire loads have been extracted from the IFEG and are considered applicable to the subject building:

Table 7-3: Fuel load densities for different occupancy groups

Occupancy	Densities in mega-joules per square metre			
	Mean (MJ/m <sup>2</sup> )	Percent fractile		
		80	90	95
Dwelling	780	870	920	970
Hospital	230	350	440	520
Hospital storage	2000	3000	3700	4400
Hotel bedroom	310	400	460	510
Offices	420	570	670	760
Shops	600	900	1100	1300
Manufacturing	300	470	590	720
Manufacturing and storage <150kg/m <sup>2</sup>	1180	1800	2240	2690
Libraries	1500	2250	2550	-
Schools	285	360	410	450

### WAREHOUSES (U.S.A.)

The following data has been extracted from the fire statistics data published by the NFPA for the years 2009-2013. The sum of each column of data may not equal totals due to rounding errors.

Table 7-4: Leading causes of structure fires in warehouse properties (2009-2013 annual averages)

Cause	Fires	Civilian Injuries
Intentional	220 (18%)	4 (21%)
Electrical distribution and lighting equipment	220 (18%)	8 (38%)
Heating equipment	90 (8%)	0 (0%)
Exposure fire	90 (7%)	0 (0%)

Cause	Fires	Civilian Injuries
Smoking materials	60 (5%)	0 (0%)
Cooking equipment	50 (4%)	0 (0%)
Lightning	20 (2%)	0 (0%)

Based on the table above, it can be noted that the leading cause is generally equipment used by the building occupants. Electrical distribution and lighting equipment is the leading cause of fires and civilian injuries, accounting for over a third of civilian injuries (38%). The following table indicates the majority of deaths and injuries occur in storage and loading bays of warehouse buildings.

Table 7-5: Structure fires in warehouse properties by area of origin (2009-2013 annual averages)

Cause	Fires	Civilian Injuries
Unclassified storage area	140 (11%)	4 (19%)
Shipping receiving or loading area	120 (10%)	2 (10%)
Storage room, area, tank or bin	80 (7%)	1 (4%)
Vacant structural area	60 (5%)	0 (0%)
Unclassified outside area	50 (4%)	1 (3%)
Storage of supplies or tools or dead storage	50 (4%)	0 (0%)
Exterior roof surface	50 (4%)	0 (0%)
Trash or rubbish chute, area or container	40 (4%)	0 (0%)
Unclassified equipment or service area	40 (4%)	0 (2%)
Processing or manufacturing area, or workroom	40 (3%)	1 (5%)
Unclassified area of origin	40 (3%)	1 (5%)
Office	40 (3%)	1 (7%)
Exterior wall surface	40 (3%)	0 (0%)
Maintenance or paint shop area	30 (3%)	1 (5%)

Cause	Fires	Civilian Injuries
Unclassified structural area	30 (2%)	0 (0%)
Garage or vehicle storage area	30 (2%)	1 (6%)
Kitchen or cooking area	20 (2%)	0 (0%)
Wall assembly or concealed space	20 (2%)	0 (0%)
Machinery room or area or elevator machinery room	20 (2%)	0 (0%)
Other known area of origin	280 (23%)	6 (27%)

The following table lists the extent of fire spread in warehouse properties and the corresponding number of civilian injuries.

Table 7-6: Structure fires in warehouse properties by extent of flame (2009-2013 annual averages)

Extent Of Fire Spread	Fires	Civilian Injuries
Confined fire identified by incident type	280 (23%)	0 (0%)
Confined to object of origin	170 (14%)	6 (32%)
Confined to room of origin	260 (21%)	4 (19%)
Confined to floor of origin	70 (6%)	1 (6%)
Confined to building of origin	370 (31%)	7 (38%)
Beyond building of origin	60 (5%)	1 (5%)